

**Well Driller's Report**

Date printed **2019/08/29**

Drilled by	Work Type	Drill Method	Work Completed
Well Use <b>Drinking Water, Domestic</b>	<b>New Well</b>	<b>Cable Tool</b>	<b>06/04/2004</b>

Casing Information		Casing above ground			Drive Shoe Used?
Well Log	Casing Type	Diameter	From	End	Slotted?
9902	Steel	15.24cm	0m	18.29m	

Aquifer Test/Yield							
Method	Initial Water Level (BTC)	Pumping Rate	Duration	Final Water Level (BTC)	Estimated Safe Yield	Flowing Well?	Rate
Air	2.44m	68.25 lpm	1hr	9.14m	68.25 lpm	No	0 lpm
<i>(BTC - Below top of casing)</i>							

Well Grouting
There is no Grout information.

Drilling Fluids Used	Disinfectant	Pump Installed
None	<b>Bleach (Javex)</b>	<b>Submersible</b>
	Qty <b>4.55L</b>	Intake Setting (BTC) <b>12.19m</b>

Driller's Log				
Well Log	From	End	Colour	Rock Type
9902	0m	1.83m	Brown	Rock
9902	1.83m	8.23m	Black	Mud
9902	8.23m	15.24m	Grey	Clay
9902	15.24m	18.90m	Grey	Coarse Gravel

Overall Well Depth  
**18.90m**

Bedrock Level  
**0m**

Water Bearing Fracture Zone		
Well Log	Depth	Rate
9902	18.29m	68.25 lpm

Setbacks		
Well Log	Distance	Setback From
9902	19.81m	Septic Tank
9902	27.43m	Leach Field
9902	12.19m	Right of any Public Way Road

**Well Driller's Report**

Date printed **2019/08/29**

Drilled by	Work Type	Drill Method	Work Completed
Well Use <b>Drinking Water, Domestic</b>	<b>New Well</b>	<b>Rotary</b>	<b>10/15/2004</b>

Casing Information		Casing above ground			Drive Shoe Used?
Well Log	Casing Type	Diameter	From	End	Slotted?
<b>10421</b>	<b>Steel</b>	<b>15.24cm</b>	<b>0m</b>	<b>17.37m</b>	

Aquifer Test/Yield							
Method	Initial Water Level (BTC)	Pumping Rate	Duration	Final Water Level (BTC)	Estimated Safe Yield	Flowing Well?	Rate
<b>Air</b>	<b>243.84m</b>	<b>3.41 lpm</b>	<b>0hr</b>	<b>243.84m</b>	<b>3.41 lpm</b>	<b>No</b>	<b>0 lpm</b>
<i>(BTC - Below top of casing)</i>							

Well Grouting	Drilling Fluids Used	Disinfectant	Pump Installed
<b>There is no Grout information.</b>	None	<b>Bleach (Javex)</b>	<b>N/A</b>
		Qty <b>0L</b>	Intake Setting (BTC) <b>0m</b>

Driller's Log					Overall Well Depth
Well Log	From	End	Colour	Rock Type	<b>243.84m</b>
<b>10421</b>	<b>0m</b>	<b>0.91m</b>	<b>Brown</b>	<b>Clay</b>	<b>Bedrock Level 0.91m</b>
<b>10421</b>	<b>0.91m</b>	<b>22.86m</b>	<b>White</b>	<b>Limestone</b>	
<b>10421</b>	<b>22.86m</b>	<b>182.88m</b>	<b>Grey</b>	<b>Conglomerate</b>	
<b>10421</b>	<b>182.88m</b>	<b>243.84m</b>	<b>Grey</b>	<b>Conglomerate</b>	

Water Bearing Fracture Zone		
Well Log	Depth	Rate
<b>10421</b>	<b>207.26m</b>	<b>1.14 lpm</b>
<b>10421</b>	<b>237.74m</b>	<b>2.28 lpm</b>

Setbacks		
Well Log	Distance	Setback From
<b>10421</b>	<b>24.38m</b>	<b>Septic Tank</b>
<b>10421</b>	<b>9.14m</b>	<b>Right of any Public Way Road</b>

**Well Driller's Report**

Date printed **2019/08/29**

Drilled by	Work Type	Drill Method	Work Completed
Well Use <b>Drinking Water, Domestic</b>	<b>New Well</b>	<b>Rotary</b>	<b>11/09/2004</b>

Casing Information		Casing above ground			Drive Shoe Used?
Well Log	Casing Type	Diameter	From	End	Slotted?
<b>10424</b>	<b>Steel</b>	<b>15.24cm</b>	<b>0m</b>	<b>12.80m</b>	

Aquifer Test/Yield							
Method	Initial Water Level (BTC)	Pumping Rate	Duration	Final Water Level (BTC)	Estimated Safe Yield	Flowing Well?	Rate
<b>Air</b>	<b>121.92m</b>	<b>0 lpm</b>	<b>1hr</b>	<b>121.92m</b>	<b>0 lpm</b>	<b>No</b>	<b>0 lpm</b>
<i>(BTC - Below top of casing)</i>							

Well Grouting	Drilling Fluids Used	Disinfectant	Pump Installed
<b>There is no Grout information.</b>	None	<b>Bleach (Javex)</b>	<b>N/A</b>
		Qty <b>0L</b>	Intake Setting (BTC) <b>0m</b>

Driller's Log				
Well Log	From	End	Colour	Rock Type
<b>10424</b>	<b>0m</b>	<b>0.61m</b>	<b>Brown</b>	<b>Clay</b>
<b>10424</b>	<b>0.61m</b>	<b>11.58m</b>	<b>White</b>	<b>Limestone</b>
<b>10424</b>	<b>11.58m</b>	<b>15.24m</b>	<b>Grey</b>	<b>Conglomerate</b>
<b>10424</b>	<b>15.24m</b>	<b>22.86m</b>	<b>White</b>	<b>Limestone</b>
<b>10424</b>	<b>22.86m</b>	<b>121.92m</b>	<b>Grey</b>	<b>Conglomerate</b>

Overall Well Depth  
**121.92m**

Bedrock Level  
**0.61m**

Water Bearing Fracture Zone
<b>There is no water bearing fracture zone information.</b>

Setbacks		
Well Log	Distance	Setback From
<b>10424</b>	<b>36.58m</b>	<b>Septic Tank</b>
<b>10424</b>	<b>9.14m</b>	<b>Right of any Public Way Road</b>

**Well Driller's Report**

Date printed **2019/08/29**

Drilled by	Work Type	Drill Method	Work Completed
Well Use <b>Drinking Water, Domestic</b>	<b>New Well</b>	<b>Rotary</b>	<b>12/13/2005</b>

Casing Information		Casing above ground			Drive Shoe Used?
Well Log	Casing Type	Diameter	From	End	Slotted?
<b>12985</b>	<b>Steel</b>	<b>15.24cm</b>	<b>0m</b>	<b>6.10m</b>	

Aquifer Test/Yield							
Method	Initial Water Level (BTC)	Pumping Rate	Duration	Final Water Level (BTC)	Estimated Safe Yield	Flowing Well?	Rate
<b>Air</b>	<b>68.58m</b>	<b>6.82 lpm</b>	<b>1hr</b>	<b>0m</b>	<b>6.82 lpm</b>	<b>No</b>	<b>0 lpm</b>
<i>(BTC - Below top of casing)</i>							

Well Grouting	Drilling Fluids Used	Disinfectant	Pump Installed
<b>There is no Grout information.</b>	None	<b>Bleach (Javex)</b>	<b>N/A</b>
		Qty <b>4.55L</b>	Intake Setting (BTC) <b>0m</b>

Driller's Log					Overall Well Depth
Well Log	From	End	Colour	Rock Type	
<b>12985</b>	<b>0m</b>	<b>4.57m</b>	<b>Brown</b>	<b>Mud and Gravel</b>	<b>68.58m</b>
<b>12985</b>	<b>4.57m</b>	<b>68.58m</b>	<b>Grey</b>	<b>Granite</b>	Bedrock Level <b>4.57m</b>

Water Bearing Fracture Zone		
Well Log	Depth	Rate
<b>12985</b>	<b>39.62m</b>	<b>4.55 lpm</b>
<b>12985</b>	<b>57.91m</b>	<b>2.28 lpm</b>

Setbacks		
Well Log	Distance	Setback From
<b>12985</b>	<b>24.38m</b>	<b>Septic Tank</b>
<b>12985</b>	<b>25.91m</b>	<b>Leach Field</b>
<b>12985</b>	<b>91.44m</b>	<b>Right of any Public Way Road</b>

**Well Driller's Report**

Date printed **2019/08/29**

Drilled by	Work Type	Drill Method	Work Completed
Well Use <b>Drinking Water, Domestic</b>	<b>Other - Not Specified</b>	<b>Rotary</b>	<b>08/15/2007</b>

Casing Information	Casing above ground	Drive Shoe Used?
<b>There is no casing information.</b>		

Aquifer Test/Yield							
Method	Initial Water Level (BTC)	Pumping Rate	Duration	Final Water Level (BTC)	Estimated Safe Yield	Flowing Well?	Rate
<b>Air</b>	<b>91.44m</b>	<b>5.69 lpm</b>	<b>0hr 30min</b>	<b>18.29m</b>	<b>3.41 lpm</b>	<b>No</b>	<b>0 lpm</b>
<i>(BTC - Below top of casing)</i>							

Well Grouting	Drilling Fluids Used	Disinfectant	Pump Installed
<b>There is no Grout information.</b>	None	<b>Bleach (Javex)</b>	<b>N/A</b>
		Qty <b>0L</b>	Intake Setting (BTC) <b>0m</b>

Driller's Log	Overall Well Depth
<b>There is no rock layer information.</b>	<b>0m</b>
	Bedrock Level
	<b>0m</b>

Water Bearing Fracture Zone		
Well Log	Depth	Rate
<b>15796</b>	<b>91.44m</b>	<b>5.69 lpm</b>

Setbacks		
Well Log	Distance	Setback From
<b>15796</b>	<b>42.67m</b>	<b>Septic Tank</b>
<b>15796</b>	<b>45.72m</b>	<b>Leach Field</b>
<b>15796</b>	<b>106.68m</b>	<b>Right of any Public Way Road</b>

**Well Driller's Report**

Date printed **2019/08/29**

Drilled by	Work Type	Drill Method	Work Completed
Well Use <b>Non-Drinking Water, Heat Pump</b>	<b>New Well</b>		<b>12/08/2007</b>

Casing Information		Casing above ground			Drive Shoe Used?
Well Log	Casing Type	Diameter	From	End	Slotted?
<b>15877</b>	<b>Steel</b>	<b>15.24cm</b>	<b>0m</b>	<b>8.23m</b>	

Aquifer Test/Yield							
Method	Initial Water Level (BTC)	Pumping Rate	Duration	Final Water Level (BTC)	Estimated Safe Yield	Flowing Well?	Rate
<b>Air</b>	<b>137.16m</b>	<b>68.25 lpm</b>	<b>0hr 30min</b>	<b>12.19m</b>	<b>68.25 lpm</b>	<b>No</b>	<b>0 lpm</b>
<i>(BTC - Below top of casing)</i>							

Well Grouting	Drilling Fluids Used	Disinfectant	Pump Installed
<b>There is no Grout information.</b>	None	<b>N/A</b>	<b>N/A</b>
		Qty <b>0L</b>	Intake Setting (BTC) <b>0m</b>

Driller's Log					Overall Well Depth
Well Log	From	End	Colour	Rock Type	
<b>15877</b>	<b>0m</b>	<b>2.44m</b>	<b>Brown</b>	<b>Clay</b>	<b>137.16m</b>
<b>15877</b>	<b>2.44m</b>	<b>137.16m</b>	<b>Grey</b>	<b>Limestone</b>	Bedrock Level <b>2.44m</b>

Water Bearing Fracture Zone		
Well Log	Depth	Rate
<b>15877</b>	<b>22.86m</b>	<b>4.55 lpm</b>
<b>15877</b>	<b>129.54m</b>	<b>63.7 lpm</b>

Setbacks		
Well Log	Distance	Setback From
<b>15877</b>	<b>22.86m</b>	<b>Right of any Public Way Road</b>

**Well Driller's Report**

Date printed **2019/08/29**

Drilled by	Work Type	Drill Method	Work Completed
Well Use <b>Drinking Water, Domestic</b>	<b>New Well</b>		<b>08/15/2007</b>

Casing Information		Casing above ground			Drive Shoe Used?
Well Log	Casing Type	Diameter	From	End	Slotted?
<b>16287</b>	<b>Steel</b>	<b>15.24cm</b>	<b>0m</b>	<b>12.19m</b>	

Aquifer Test/Yield							
Method	Initial Water Level (BTC)	Pumping Rate	Duration	Final Water Level (BTC)	Estimated Safe Yield	Flowing Well?	Rate
<b>Air</b>	<b>9.14m</b>	<b>6.82 lpm</b>	<b>0hr 30min</b>	<b>21.34m</b>	<b>6.82 lpm</b>	<b>No</b>	<b>0 lpm</b>
<i>(BTC - Below top of casing)</i>							

Well Grouting	Drilling Fluids Used	Disinfectant	Pump Installed
<b>There is no Grout information.</b>	None	<b>Bleach (Javex)</b>	<b>N/A</b>
		Qty <b>0L</b>	Intake Setting (BTC) <b>0m</b>

Driller's Log				
Well Log	From	End	Colour	Rock Type
<b>16287</b>	<b>0m</b>	<b>1.52m</b>	<b>Grey</b>	<b>Rock</b>
<b>16287</b>	<b>1.52m</b>	<b>4.57m</b>	<b>Red</b>	<b>Clay</b>
<b>16287</b>	<b>4.57m</b>	<b>10.36m</b>	<b>Brown</b>	<b>Sand and Mud</b>
<b>16287</b>	<b>10.36m</b>	<b>10.97m</b>	<b>Grey</b>	<b>Other</b>
<b>16287</b>	<b>10.97m</b>	<b>12.19m</b>	<b>Grey</b>	<b>Limestone</b>
<b>16287</b>	<b>12.19m</b>	<b>36.58m</b>	<b>Grey and black</b>	<b>Limestone</b>
<b>16287</b>	<b>36.58m</b>	<b>60.96m</b>	<b>Grey and white</b>	<b>Limestone</b>
<b>16287</b>	<b>60.96m</b>	<b>64.01m</b>	<b>Grey</b>	<b>Limestone</b>
<b>16287</b>	<b>64.01m</b>	<b>79.25m</b>	<b>Grey and white</b>	<b>Limestone</b>

Overall Well Depth  
**79.25m**

Bedrock Level  
**10.36m**

Water Bearing Fracture Zone		
Well Log	Depth	Rate
<b>16287</b>	<b>64.01m</b>	<b>2.28 lpm</b>
<b>16287</b>	<b>74.68m</b>	<b>4.55 lpm</b>

Setbacks		
Well Log	Distance	Setback From
<b>16287</b>	<b>30.48m</b>	<b>Right of any Public Way Road</b>
<b>16287</b>	<b>304.80m</b>	<b>Right of any Public Way Road</b>

**Well Driller's Report**

Date printed **2019/08/29**

Drilled by	Work Type	Drill Method	Work Completed
Well Use <b>Drinking Water, Domestic</b>	<b>New Well</b>	<b>Rotary</b>	<b>04/10/2012</b>

Casing Information		Casing above ground			Drive Shoe Used?
Well Log	Casing Type	Diameter	From	End	Slotted?
<b>29122</b>	<b>Steel</b>	<b>15.24cm</b>	<b>0m</b>	<b>6.40m</b>	

Aquifer Test/Yield							
Method	Initial Water Level (BTC)	Pumping Rate	Duration	Final Water Level (BTC)	Estimated Safe Yield	Flowing Well?	Rate
<b>Air</b>	<b>137.16m</b>	<b>6.82 lpm</b>	<b>0hr 30min</b>	<b>18.29m</b>	<b>6.82 lpm</b>	<b>No</b>	<b>0 lpm</b>
<i>(BTC - Below top of casing)</i>							

Well Grouting	Drilling Fluids Used	Disinfectant	Pump Installed
<b>There is no Grout information.</b>	None	<b>Bleach (Javex)</b>	<b>Submersible</b>
		Qty <b>0L</b>	Intake Setting (BTC) <b>121.92m</b>

Driller's Log					Overall Well Depth <b>137.16m</b>
Well Log	From	End	Colour	Rock Type	
<b>29122</b>	<b>0m</b>	<b>2.44m</b>	<b>Brown</b>	<b>Clay</b>	Bedrock Level <b>2.44m</b>
<b>29122</b>	<b>2.44m</b>	<b>137.16m</b>	<b>Grey</b>	<b>Limestone</b>	

Water Bearing Fracture Zone		
Well Log	Depth	Rate
<b>29122</b>	<b>124.97m</b>	<b>2.28 lpm</b>
<b>29122</b>	<b>128.02m</b>	<b>4.55 lpm</b>

Setbacks		
Well Log	Distance	Setback From
<b>29122</b>	<b>22.86m</b>	<b>Septic Tank</b>
<b>29122</b>	<b>25.91m</b>	<b>Leach Field</b>
<b>29122</b>	<b>64.01m</b>	<b>Right of any Public Way Road</b>



**Well Driller's Report**

Date printed **2019/08/29**

Drilled by	Work Type	Drill Method	Work Completed
Well Use <b>Drinking Water, Municipal</b>	<b>New Well</b>	<b>Rotary</b>	<b>09/30/2015</b>

Casing Information		Casing above ground			Drive Shoe Used?
Well Log	Casing Type	Diameter	From	End	Slotted?
<b>30895</b>	<b>Steel</b>	<b>15.24cm</b>	<b>0m</b>	<b>6.10m</b>	

Aquifer Test/Yield							
Method	Initial Water Level (BTC)	Pumping Rate	Duration	Final Water Level (BTC)	Estimated Safe Yield	Flowing Well?	Rate
<b>Air</b>	<b>146.91m</b>	<b>0 lpm</b>	<b>1hr 30min</b>	<b>17.07m</b>	<b>54.6 lpm</b>	<b>No</b>	<b>0 lpm</b>
<i>(BTC - Below top of casing)</i>							

Well Grouting	Drilling Fluids Used	Disinfectant	Pump Installed
<b>There is no Grout information.</b>	None	<b>Chlorine Pucks</b>	<b>N/A</b>
		Qty <b>0L</b>	Intake Setting (BTC) <b>0m</b>

Driller's Log					Overall Well Depth
Well Log	From	End	Colour	Rock Type	<b>146.91m</b>
<b>30895</b>	<b>0m</b>	<b>9.14m</b>	<b>Grey</b>	<b>Limestone</b>	<b>Bedrock Level 0m</b>
<b>30895</b>	<b>9.14m</b>	<b>10.67m</b>	<b>Black</b>	<b>Shale and Rock</b>	
<b>30895</b>	<b>10.67m</b>	<b>81.69m</b>	<b>Grey and blue</b>	<b>Limestone</b>	
<b>30895</b>	<b>81.69m</b>	<b>146.91m</b>	<b>Brown and grey</b>	<b>Rock</b>	

Water Bearing Fracture Zone		
Well Log	Depth	Rate
<b>30895</b>	<b>108.20m</b>	<b>15.92 lpm</b>
<b>30895</b>	<b>133.81m</b>	<b>36.4 lpm</b>

Setbacks		
Well Log	Distance	Setback From
<b>30895</b>	<b>93.27m</b>	<b>Right of any Public Way Road</b>

**Well Driller's Report**

Date printed **2019/08/29**

Drilled by	Work Type	Drill Method	Work Completed
Well Use <b>Drinking Water, Municipal</b>	<b>New Well</b>	<b>Rotary</b>	<b>10/06/2015</b>

Casing Information		Casing above ground			Drive Shoe Used?
Well Log	Casing Type	Diameter	From	End	Slotted?
<b>30896</b>	<b>Steel</b>	<b>15.24cm</b>	<b>0m</b>	<b>6.10m</b>	

Aquifer Test/Yield							
Method	Initial Water Level (BTC)	Pumping Rate	Duration	Final Water Level (BTC)	Estimated Safe Yield	Flowing Well?	Rate
<b>Air</b>	<b>140.82m</b>	<b>72.8 lpm</b>	<b>1hr 30min</b>	<b>33.53m</b>	<b>72.8 lpm</b>	<b>No</b>	<b>0 lpm</b>
<i>(BTC - Below top of casing)</i>							

Well Grouting	Drilling Fluids Used	Disinfectant	Pump Installed
<b>There is no Grout information.</b>	None	<b>Chlorine Pucks</b>	<b>N/A</b>
		Qty <b>0L</b>	Intake Setting (BTC) <b>0m</b>

Driller's Log				
Well Log	From	End	Colour	Rock Type
<b>30896</b>	<b>0m</b>	<b>12.80m</b>	<b>Grey</b>	<b>Limestone</b>
<b>30896</b>	<b>12.80m</b>	<b>41.15m</b>	<b>Purple</b>	<b>Rock</b>
<b>30896</b>	<b>41.15m</b>	<b>46.63m</b>	<b>Grey and black</b>	<b>Rock</b>
<b>30896</b>	<b>46.63m</b>	<b>84.73m</b>	<b>Brown and grey</b>	<b>Rock</b>
<b>30896</b>	<b>84.73m</b>	<b>124.97m</b>	<b>Brown</b>	<b>Rock</b>
<b>30896</b>	<b>124.97m</b>	<b>138.07m</b>	<b>Green</b>	<b>Rock</b>

Overall Well Depth  
**138.07m**

Bedrock Level  
**0m**

Water Bearing Fracture Zone		
Well Log	Depth	Rate
<b>30896</b>	<b>84.73m</b>	<b>2.28 lpm</b>
<b>30896</b>	<b>90.53m</b>	<b>2.28 lpm</b>
<b>30896</b>	<b>116.74m</b>	<b>72.8 lpm</b>

Setbacks		
Well Log	Distance	Setback From
<b>30896</b>	<b>93.27m</b>	<b>Right of any Public Way Road</b>

**Well Driller's Report**

Date printed **2019/08/29**

Drilled by	Work Type	Drill Method	Work Completed
Well Use <b>Drinking Water, Domestic</b>	<b>New Well</b>	<b>Rotary</b>	<b>07/31/2018</b>

Casing Information		Casing above ground			Drive Shoe Used?
Well Log	Casing Type	Diameter	From	End	Slotted?
<b>36920</b>	<b>Steel</b>	<b>15.24cm</b>	<b>0m</b>	<b>18.29m</b>	

Aquifer Test/Yield							
Method	Initial Water Level (BTC)	Pumping Rate	Duration	Final Water Level (BTC)	Estimated Safe Yield	Flowing Well?	Rate
<b>Air</b>	<b>18.29m</b>	<b>20.48 lpm</b>	<b>2hrs 01min</b>	<b>2.44m</b>	<b>20.48 lpm</b>	<b>No</b>	<b>0 lpm</b>
<i>(BTC - Below top of casing)</i>							

Well Grouting	Drilling Fluids Used	Disinfectant	Pump Installed
<b>There is no Grout information.</b>	None	<b>Bleach (Javex)</b>	<b>Submersible</b>
		Qty <b>0L</b>	Intake Setting (BTC) <b>17.37m</b>

Driller's Log				
Well Log	From	End	Colour	Rock Type
<b>36920</b>	<b>0m</b>	<b>2.44m</b>	<b>Brown</b>	<b>Clay</b>
<b>36920</b>	<b>2.44m</b>	<b>5.18m</b>	<b>Brown</b>	<b>Clay and Mud</b>
<b>36920</b>	<b>5.18m</b>	<b>18.29m</b>	<b>Grey</b>	<b>Gravel</b>

Overall Well Depth  
**18.29m**

Bedrock Level  
**0m**

Water Bearing Fracture Zone		
Well Log	Depth	Rate
<b>36920</b>	<b>18.29m</b>	<b>21.61 lpm</b>

Setbacks		
Well Log	Distance	Setback From
<b>36920</b>	<b>24.38m</b>	<b>Septic Tank</b>
<b>36920</b>	<b>30.48m</b>	<b>Leach Field</b>
<b>36920</b>	<b>182.88m</b>	<b>Right of any Public Way Road</b>
<b>36920</b>	<b>192.94m</b>	<b>Center of road</b>

Drilled by	Work Type	Drill Method	Work Completed
Well Use <b>Drinking Water, Domestic</b>	<b>New Well</b>	<b>Rotary</b>	<b>07/31/2018</b>

Casing Information		Casing above ground			Drive Shoe Used?
Well Log	Casing Type	Diameter	From	End	Slotted?
36920	Steel	15.24cm	0m	18.29m	

Aquifer Test/Yield						
Method	Initial Water Level (BTC)	Pumping Rate	Duration	Final Water Level (BTC)	Estimated Safe Yield	Flowing Well? Rate
Air	18.29m	20.48 lpm	2hrs 01min	2.44m	20.48 lpm	No 0 lpm
<i>(BTC - Below top of casing)</i>						

Well Grouting
There is no Grout information.

Drilling Fluids Used	Disinfectant	Pump Installed
None	Bleach (Javex)	Submersible
	Qty 0L	Intake Setting (BTC) 17.37m

Driller's Log				
Well Log	From	End	Colour	Rock Type
36920	0m	2.44m	Brown	Clay
36920	2.44m	5.18m	Brown	Clay and Mud
36920	5.18m	18.29m	Grey	Gravel

Overall Well Depth  
**18.29m**

Bedrock Level  
**0m**

Water Bearing Fracture Zone		
Well Log	Depth	Rate
36920	18.29m	21.61 lpm

Setbacks		
Well Log	Distance	Setback From
36920	24.38m	Septic Tank
36920	30.48m	Leach Field
36920	182.88m	Right of any Public Way Road
36920	192.94m	Center of road

**Well Driller's Report**

Date printed **2019/08/29**

Drilled by	Work Type	Drill Method	Work Completed
Well Use <b>Drinking Water, Domestic</b>	<b>New Well</b>	<b>Rotary</b>	<b>05/04/2016</b>

Casing Information		Casing above ground			Drive Shoe Used?
Well Log	Casing Type	Diameter	From	End	Slotted?
<b>38901</b>	<b>Steel</b>	<b>15.24cm</b>	<b>0m</b>	<b>18.29m</b>	

Aquifer Test/Yield							
Method	Initial Water Level (BTC)	Pumping Rate	Duration	Final Water Level (BTC)	Estimated Safe Yield	Flowing Well?	Rate
<b>Air</b>	<b>205.74m</b>	<b>22.75 lpm</b>	<b>3hrs 50min</b>	<b>4.88m</b>	<b>22.75 lpm</b>	<b>No</b>	<b>0 lpm</b>
<i>(BTC - Below top of casing)</i>							

Well Grouting	Drilling Fluids Used	Disinfectant	Pump Installed
<b>There is no Grout information.</b>	None	<b>Bleach (Javex)</b>	<b>Submersible</b>
		Qty <b>0L</b>	Intake Setting (BTC) <b>91.44m</b>

Driller's Log					Overall Well Depth
Well Log	From	End	Colour	Rock Type	<b>205.74m</b>
<b>38901</b>	<b>0m</b>	<b>4.27m</b>	<b>Brown</b>	<b>Mud and Gravel</b>	<b>Bedrock Level 4.27m</b>
<b>38901</b>	<b>4.27m</b>	<b>64.01m</b>	<b>Grey</b>	<b>Slate</b>	
<b>38901</b>	<b>64.01m</b>	<b>205.74m</b>	<b>Grey</b>	<b>Granite</b>	

Water Bearing Fracture Zone		
Well Log	Depth	Rate
<b>38901</b>	<b>42.67m</b>	<b>4.55 lpm</b>
<b>38901</b>	<b>51.82m</b>	<b>9.1 lpm</b>
<b>38901</b>	<b>67.36m</b>	<b>9.1 lpm</b>

Setbacks		
Well Log	Distance	Setback From
<b>38901</b>	<b>804.67m</b>	<b>Right of any Public Way Road</b>
<b>38901</b>	<b>804.67m</b>	<b>Center of road</b>

**Well Driller's Report**

Date printed **2019/08/29**

Drilled by	Work Type	Drill Method	Work Completed
Well Use <b>Drinking Water, Domestic</b>	<b>New Well (NEW WELL)</b>	<b>Rotary (ROTARY)</b>	<b>04/24/1995</b>

Casing Information		Casing above ground			Drive Shoe Used?
Well Log	Casing Type	Diameter	From	End	Slotted?
<b>90015000</b>	<b>Steel</b>	<b>15.24cm</b>	<b>0m</b>	<b>33.83m</b>	

Aquifer Test/Yield							
Method	Initial Water Level (BTC)	Pumping Rate	Duration	Final Water Level (BTC)	Estimated Safe Yield	Flowing Well?	Rate
<b>Air</b>	<b>1.52m</b>	<b>341.25 lpm</b>	<b>2hrs</b>	<b>0m</b>	<b>341.25 lpm</b>	<b>No</b>	<b>0 lpm</b>
<i>(BTC - Below top of casina)</i>							

Well Grouting	Drilling Fluids Used	Disinfectant	Pump Installed
<b>There is no Grout information.</b>	None	<b>N/A</b>	<b>N/A</b>
		Qty <b>0L</b>	Intake Setting (BTC) <b>60.96m</b>

Driller's Log					Overall Well Depth
Well Log	From	End	Colour	Rock Type	<b>92.96m</b>
<b>90015000</b>	<b>2.44m</b>	<b>18.90m</b>	<b>Grey</b>	<b>Mud</b>	Bedrock Level <b>0m</b>
<b>90015000</b>	<b>18.90m</b>	<b>23.16m</b>	<b>Grey</b>	<b>Gravel</b>	
<b>90015000</b>	<b>23.16m</b>	<b>33.83m</b>	<b>Grey</b>	<b>Clay and Gravel</b>	
<b>90015000</b>	<b>33.83m</b>	<b>92.96m</b>	<b>Grey</b>	<b>Limestone</b>	
<b>90015000</b>	<b>0m</b>	<b>2.44m</b>	<b>Brown</b>	<b>Sand</b>	

Water Bearing Fracture Zone		
Well Log	Depth	Rate
<b>90015000</b>	<b>63.70m</b>	<b>113.75 lpm</b>
<b>90015000</b>	<b>84.73m</b>	<b>227.5 lpm</b>

Setbacks
<b>There is no Setback information.</b>

**Well Driller's Report**

Date printed **2019/08/29**

Drilled by	Work Type	Drill Method	Work Completed
Well Use <b>Drinking Water, Domestic</b>	<b>New Well</b>		<b>01/01/2000</b>

Casing Information	Casing above ground	Drive Shoe Used?
<b>There is no casing information.</b>		

Aquifer Test/Yield							
Method	Initial Water Level (BTC)	Pumping Rate	Duration	Final Water Level (BTC)	Estimated Safe Yield	Flowing Well?	Rate
	<b>0m</b>	<b>0 lpm</b>	<b>0hr</b>	<b>0m</b>	<b>0 lpm</b>	<b>No</b>	<b>0 lpm</b>
<i>(BTC - Below top of casing)</i>							

Well Grouting	Drilling Fluids Used	Disinfectant	Pump Installed
<b>There is no Grout information.</b>	None	<b>N/A</b>	<b>N/A</b>
		Qty <b>0L</b>	Intake Setting (BTC) <b>0m</b>

Driller's Log	Overall Well Depth
<b>There is no rock layer information.</b>	<b>0m</b>
	Bedrock Level
	<b>0m</b>

Water Bearing Fracture Zone
<b>There is no water bearing fracture zone information.</b>

Setbacks
<b>There is no Setback information.</b>

**Well Driller's Report**

Date printed **2019/08/29**

Drilled by	Work Type	Drill Method	Work Completed
Well Use <b>Drinking Water, Domestic</b>	<b>New Well (NEW WELL)</b>	<b>Cable Tool (CABLE TOOL)</b>	<b>09/27/1997</b>

Casing Information		Casing above ground			Drive Shoe Used?
Well Log	Casing Type	Diameter	From	End	Slotted?
90965500	Steel	15.24cm	0m	13.41m	

Aquifer Test/Yield							
Method	Initial Water Level (BTC)	Pumping Rate	Duration	Final Water Level (BTC)	Estimated Safe Yield	Flowing Well?	Rate
<b>Bailer</b>	<b>6.10m</b>	<b>54.6 lpm</b>	<b>1hr 30min</b>	<b>12.19m</b>	<b>31.85 lpm</b>	<b>No</b>	<b>0 lpm</b>
<i>(BTC - Below top of casina)</i>							

Well Grouting	Drilling Fluids Used	Disinfectant	Pump Installed
<b>There is no Grout information.</b>	None	<b>Chlorine Pucks</b>	<b>N/A</b>
		Qty <b>0L</b>	Intake Setting (BTC) <b>19.81m</b>

Driller's Log					Overall Well Depth
Well Log	From	End	Colour	Rock Type	<b>6.40m</b>
90965500	0m	1.83m	Brown	Till	Bedrock Level <b>6.10m</b>
90965500	1.83m	6.10m	Brown	Mud and Stone and Shale	
90965500	6.10m	6.40m	Brown	Rock	

Water Bearing Fracture Zone		
Well Log	Depth	Rate
90965500	16.76m	9.1 lpm

Setbacks
<b>There is no Setback information.</b>



**Well Driller's Report**

Date printed **2019/08/29**

Drilled by	Work Type	Drill Method	Work Completed
Well Use <b>Drinking Water, Domestic</b>	<b>New Well</b>	<b>Rotary</b>	<b>06/04/2002</b>

Casing Information		Casing above ground			Drive Shoe Used?
Well Log	Casing Type	Diameter	From	End	Slotted?
<b>92304200</b>	<b>Steel</b>	<b>15.24cm</b>	<b>0m</b>	<b>18.29m</b>	

Aquifer Test/Yield							
Method	Initial Water Level (BTC)	Pumping Rate	Duration	Final Water Level (BTC)	Estimated Safe Yield	Flowing Well?	Rate
<b>Air</b>	<b>0m</b>	<b>0 lpm</b>	<b>0hr</b>	<b>0m</b>	<b>6.82 lpm</b>	<b>No</b>	<b>0 lpm</b>
<i>(BTC - Below top of casing)</i>							

Well Grouting	Drilling Fluids Used	Disinfectant	Pump Installed
<b>There is no Grout information.</b>	None	<b>N/A</b>	<b>N/A</b>
		Qty <b>0L</b>	Intake Setting (BTC) <b>0m</b>

Driller's Log					Overall Well Depth
Well Log	From	End	Colour	Rock Type	<b>60.96m</b>
<b>92304200</b>	<b>0m</b>	<b>17.07m</b>	<b>Brown and grey</b>	<b>Mud and Stone and Shale</b>	Bedrock Level <b>17.07m</b>
<b>92304200</b>	<b>17.07m</b>	<b>60.96m</b>	<b>Grey</b>	<b>Granite</b>	

Water Bearing Fracture Zone		
Well Log	Depth	Rate
<b>92304200</b>	<b>60.96m</b>	<b>6.82 lpm</b>

Setbacks
<b>There is no Setback information.</b>

