WATER SUPPLY SOURCE ASSESSMENT

Strang's Shore Seasonal Camping Inc. 1639 Route 955 Little Shemogue, (Murray Corner), NB PID No. 00837088



Our File No.: 278-17 January, 2018 Prepared for:

Jerry and Linda Strang 89 Moore Road Ext. Otter Creek, NB E4M 3V5

Prepared by:





T. : 506 472-9838 = F. : 506 472-9255

364, rue York Street, Suite 201 Fredericton (NB) E3B 3P7 www.royconsultants.ca

January 19, 2018

Jerry and Linda Strang Strang's Shore Seasonal Camping Inc. 89 Moore Road Ext. Otter Creek, NB E4M 3V5

Our File No.: 278-17-C¹

Mr. and Mrs. Strang:

Subject: Water Supply Source Assessment Strang's Shore Seasonal Camping Inc. 1639 Route 955 Little Shemogue (Murray Corner), NB PID No. 00837088

We are pleased to present you with the water supply source assessment for Strang's Shore Seasonal Camping Inc. in Little Shemogue (Murray Corner), New Brunswick.

The assessment has determined that there is an adequate supply of water to support the existing campground facility and the proposed future expansion. It is recommended that production well PW1 be operated at a rate not to exceed 20 Igpm (131 m^3/day) for a maximum of 14 hours per day and a flow meter be installed on the well to monitor actual water consumption. Water quality samples should be collected on a monthly basis (at a minimum) and analyzed for conductivity to monitor for possible saltwater intrusion.

Should you have any questions regarding this report, please do not hesitate to contact the undersigned.

Yours truly,

Gina Butt

Gina Burtt, M.Sc., P.Eng. P.Geo. ENVIRONMENTAL Engineer

GB/jb/sl Enc.

¹ 278-17 Pump Test Report Jan 2018.doc

Bathurst • Dieppe • Edmundston • Fredericton • Tracadie

TABLE OF CONTENTS

i) Letter of Introduction

ii)	Table o	f Contents
-----	---------	------------

1.0	INTRODUCTION	1
1.	Project Description	1
2.0	EXISTING SITE CONDITIONS	2
2	~r	2
2. 2.		
3.0	HYDROGEOLOGICAL CONDITIONS	4
3	- · · · · · · · · · · · · · · · · · · ·	
3.		
4.0	HYDRAULIC TESTING	
4.	~···F	
4.	/2 noti i unping i com	
	4.2.1 Pumping Test Analysis 1 4.2.2 Recommended Sustainable Yield (PW1) 1	
	4.2.5 Groundwater Quality	
5.0	DISCUSSION1	5
5.	Neighbouring Water Users1	5
5.		
5.	Groundwater under the Direct Influence of Surface Water (GUDI)1	7
6.0	CONCLUSIONS AND RECOMMENDATIONS1	9
7.0	CLOSURE2	0
8.0	REFERENCES2	1

APPENDICES

APPENDIX A: Figures
APPENDIX B: SNB Documentation
APPENDIX C: Well Driller's Reports
APPENDIX D: Pumping Test Data for Pumping Well and Observation Well
APPENDIX E: Laboratory Certificates
APPENDIX F: Environment Canada Daily Data Report and Tide Tables
APPENDIX G: NBDELG Documentation

1.0 INTRODUCTION

Jerry and Linda Strang, on behalf of Strang's Shore Seasonal Camping Inc., retained the services of Roy Consultants to complete a water supply source assessment for the existing campground in Little Shemogue (Murray Corner), New Brunswick (PID Nos. 00837088, 70188826 and 70563457), herein referred to as the "subject property". Refer to Figure 1 in Appendix A for the site location plan.

This report has been prepared in accordance with the New Brunswick Department of Environment and Local Government's (NBDELG) Environmental Impact Assessment *Water Supply Source Assessment Guidelines* (April 2017). These guidelines are used to assist proponents engaging in projects that require a Water Supply Source Assessment (WSSA) through the Environmental Impact Assessment (EIA) process. A WSSA includes, but is not limited to, an evaluation of the sustainability of the water supply, an assessment of water quality, an evaluation of potential impacts to existing water users and an assessment of the potential for saltwater intrusion. The WSSA guidelines are enclosed in Appendix G.

1.1 **Project Description**

Strang's Shore Seasonal Camping Inc. (hereinafter "the proponent") currently operates a campground with 115 serviced lots at 1639 Route 955, Little Shemogue (Murray Corner), New Brunswick (Westmorland County). The campground began operating in 2012 and includes three parcels of land identified by Service New Brunswick as PID Nos. 00837088, 70188826 and 70563457. For a campground with water and sewer hook-ups, the NBDELG recommends 450 L per space per day for water usage. The estimated current water demand is $52 \text{ m}^3/\text{day}$. The campground will expand in the future for a total of 150 serviced lots with an approximate water demand of $68 \text{ m}^3/\text{day}$. Currently, the actual water usage is unknown. As limited information is available on current water usage, the objective of the water supply source assessment is to complete a pump test on the existing production well to determine its recommended safe yield.

2.0 EXISTING SITE CONDITIONS

2.1 Site Description

The campground is located in a rural area surrounded by cottage/residential buildings. The subject property, identified by the Service New Brunswick (SNB) parcel identification (PID) number 00837088, is zoned "rural zone" according to the Tantramar Rural Zoning Map Schedule A. Development in the area includes residences and/or cottages to the east, south and west and the Northumberland Strait borders the northern property line. Refer to Figure 1 in Appendix A.

The pumping well (PW1) is located on PID No. 00837088, which covers an area of 3.43 hectares. The observation well (OW1) is located on PID No. 70188826, which has an area of 1.13 hectares. No wells are located on the third parcel of land comprising the campground, PID No. 70563457, which has an area of 3.27 ha. SNB documentation is enclosed in Appendix B. The nearest neighbouring domestic well is located approximately 130 metres east and cross gradient of PW1, along Highway 955 (PID No. 70063144).



Photos 1 and 2: Photo at left shows the well house (looking northeast). Photo at right shows production well PW1 located inside the well house (July 5, 2017).



Photo 3: View of observation well OW1 looking south towards Highway 955 (October 16, 2017)

2.2 Current Groundwater Use

There are two (2) existing on-site potable wells (PW1 and OW1); however, only PW1 services the campground. The wells are located approximately 216 m from each other. PW1 is equipped with a Pentek® 2 horsepower submersible pump with a capacity of 25 USgpm (21 Igpm). OW1 is not hooked up to the water supply system. This well is a remnant from a mobile home that previously occupied PID No. 70188826 prior to that land parcel's purchase by Strang's Shore Seasonal Camping Inc.

2.3 Well Construction

PW1 was constructed on August 2, 2010 (Well ID 24773). The well is 150 mm (6 inches) in diameter and completed to a depth of 32 metres (105 feet). Based on the well driller's report, the predominant bedrock is comprised of alternating layers of grey sandstone and red shale. Depth to the bedrock level is 6.4 metres below ground surface (bgs). OW1 was constructed on August 13, 2014 (Well ID 30194). The well is 150 mm (6 inches) in diameter and completed to a depth of 19.8 metres (65 feet). OW1 was deepened to a depth of 32 metres (105 feet) on October 16, 2017 by Charlie Herman Chappell Well Drilling, out of Colpitts Settlement, NB. All well locations are shown on Figure 1 in Appendix A. The well driller reports for PW1 and OW1 are enclosed in Appendix C.

Well ID	GPS Coordinates		Date Drilled	Well Depth	Casing Depth	Driller's Estimated	Static Water
	Northing	Easting		(btoc) (m)	(btoc) (m)	Safe Yield (Igpm)	Level (btoc) (m)
PW1	7467524.674	2695018.638	August 2010	32	10.97	20	4.13*
OW1	7467310.055	2694998.413	August 2014	32	12.19	35	3.465*

Table 1: Summary of On-site Potable Well Information

(*) as measured on November 19, 2017

3.0 HYDROGEOLOGICAL CONDITIONS

3.1 Topography and Drainage

The subject property is located within the New Brunswick Lowlands physiographic unit. Based on the well elevation survey completed by Roy Consultants in November 2017, the ground surface elevations noted at PW1 and OW1 were 6.74 m and 7.7 m above mean sea level, respectively. The property was noted to gently slope north towards the Northumberland Strait. Surface water drainage across the subject property is northerly via overland flow. No drainage ditches were noted on the subject site. Drainage is good, evidenced by no mapped wetlands on the subject site. Standing water and wet areas were not observed during field work completed in November 2017. The area to the south, which could potentially contribute groundwater to the study area, is a mix of developed residential and vacant/wooded lots.

3.2 Geology

The surficial geology for the area consists of Late Wisconsinan morainal sediments blanket deposits consisting of loamy lodgment till, minor ablation till, silt, sand, gravel and rubble generally 0.5 m to 3 m thick (Rampton, 1984). According to the well driller's log for PW1, the underlying site stratigraphy (from top to bottom) consists of clay and sand at depths from 0 to 6.4 metres bgs and sand present from 6.4 m to 9.1 metres bgs.

The bedrock underlying the subject property is comprised of Late Carboniferous-aged sedimentary rocks comprised of the Pictou Group, Richibucto Formation consisting of grey and brownish red, commonly micaceous lithic and arkosic sandstone, pebbly sandstone and intraformational mudstone-clast conglomerate, brownish red to brick-red and lesser grey siltstone and mudstone, minor intraformational limestone-cobble conglomerate and thin laterally extensive limestone beds and minor thin coal seams (Smith, 2007). According to the well driller's log for PW1, grey sandstone was encountered at a depth of 12.5 metres bgs. Refer to Appendix C for the well driller's report.

3.3 Hydrogeology

Based on a review of seven (7) water well logs within 500 metres of the subject property (PID 00837088), the local aquifer is comprised of a fractured sandstone bedrock aquifer. According to well drillers' reports, several major water-bearing fractures are noted at depths of approximately 17 m, 25 m and 29 m. Well depths range between 19.8 m and 73.5 m and well yields range from 3 Igpm to 25 Igpm (19.6 m³/day to 163.6 m³/day). Most well logs indicate a confined aquifer scenario of sandstone bedrock interbedded with layers of shale. Refer to well driller's reports in Appendix C for further details.

The subject property is located immediately adjacent to the Northumberland Strait, which is under tidal influence. Water levels in the area are expected to be influenced to some degree by high and low tides. Potential recharge sources to the wells on the subject site include direct infiltration from precipitation and groundwater flow from upland areas.

4

4.0 HYDRAULIC TESTING

Hydraulic testing was completed at PW1 from November 19 to November 22, 2017. A 72-hour constant rate pumping test was completed in accordance with NBDELG's WSSA guidelines. During the test, groundwater from PW1 was contained and discharged through approximately 75 m of 4-inch diameter PVC pipe into the Northumberland Strait. Refer to Photos 4 and 5. The site topography slopes northward, away from the pumping well, towards the Northumberland Strait. The discharge location of the pumped water did not allow artificial recharge to PW1 and OW1.



Photo 4: View of water discharge line directing pumped water towards the Northumberland Strait (November 19, 2017).



Photo 5: View of water discharge (November 19, 2017)

4.1 Step Test

Prior to commencement of the 72-hour continuous pumping test, a step test was conducted to determine the optimal pumping rates for the long-term test at PW1. The existing pump in PW1 was pulled prior to the test and a 5-horsepower pump was installed by Charlie Herman Chappell Well Drilling. Installation of a larger pump allowed for higher pump rate at which to step test the well. The pump was installed at a depth of 27.4 m (90 feet). Step test intervals were 30 minutes in length, each having a higher pumping rate than the previous interval. Three steps were completed at 10 Igpm, 20 Igpm and 30 Igpm, respectively. Pumping rates were verified by the driller using a 20-gallon bucket and stopwatch. Water levels were allowed to recover following completion of each step. Leveloggers were installed in both the pumping and observation wells to recover water levels in addition to collecting manual water measurements. Drawdown and recovery data for PW1 throughout the step test are shown in Figure 1.




Figure 1: Step Test Data PW1 – Drawdown vs Time

At the beginning of the step test, the static water level in PW1 was 3.56 m bgs. During the first step, at a pumping rate of 10 Igpm, drawdown stabilized at approximately 4.52 m bgs. During the second step, at a pumping rate of 20 Igpm, the pumping water level stabilized at approximately 5.61 m. At the end of the third step, at a pumping rate of 30 Igpm, the pumping water level was 7.08 m bgs and did not appear to have stabilized. The maximum drawdown observed in OW1 during the pumping portion of the step test was 0.029 m (water level of 2.924 m bgs). The water level recovery in PW1 was 94 % recovery after 30 minutes of the end of the last step. Based on the results of the step test, a pumping rate of 20 Igpm (131 m³/day) was selected for PW1 for the constant rate test. All step test data and plots are enclosed in Appendix D.

4.2 72-hour Pumping Test

The 72-hour constant rate test was started at 2:30 p.m. on November 19, 2017, and the pump was shut off at 2:30 p.m. on November 22, 2017. The average flow rate measured over the duration of the test was 20 Igpm (131 m³/day) from PW1. The flow rate was monitored regularly throughout the duration of the pump test by the driller using a 20-gallon bucket and stopwatch.


Results from the pumping well and observation well during the 72-hour pumping test are presented in Table 2. Water level data are shown in Figure 2 and drawdown data is presented in Figure 3. Refer to the pumping test data and graphs in Appendix D for further details.

Well ID	Well Type	Distance from Pumped Well (m)	Ground Surface Elevation (m)	Static Water Elevation (m)	Maximum Observed Drawdown (m)	Time of Maximum Observed Drawdown (Hour into Pumping Test)
PW1	Pumping	N/A	6.74	3.563 (bgs) 3.177 (amsl)	4.69	67
OW1	Observation	216	7.70	2.895 (bgs) 4.805 (amsl)	0.29	66

Table 2. Summary of 72-hour Constant Rate Test Data

bgs = below ground surface

amsl = above mean sea level





WATER SUPPLY SOURCE ASSESSMENT Little Shemogue, NB

The water level in PW1 appeared to stabilize over the duration of the pumping test. However, fluctuations in drawdown were noted which are attributed to pumping rate adjustments made by the driller and tidal effect. The pumping rate had to be adjusted after 37 hours of pumping (2220 minutes), 44 hours (2640 minutes), 50 hours (3000 minutes), 52 hours (3120 minutes) and 63 hours (3780 minutes).




Figure 3: 72-hour Constant Rate Test Drawdown Data

The maximum drawdown in PW1 was 4.69 m, which corresponds to a pumping water level of approximately 1.51 m below sea level (bsl). The maximum drawdown observed in OW1 was 0.29 m, which corresponds to a water level of 4.515 m above sea level (asl). Water levels in OW1 remained above sea level throughout the duration of the pumping test.

Some minor fluctuations in water levels are noted in the drawdown data for both wells and are attributed to tidal effects. Fluctuations correlate with the tide schedules for Cape Tormentine. Based on the drawdown data, drawdowns of approximately 0.17 m in PW1 and 0.02 m in OW1 are attributed to tidal influence during the pumping test. Refer to Appendix F for tide tables.

Following completion of the pumping test, recovery in both wells was very good. In PW1, water levels recovered 71 %, 92 % and 100 % within 1 hour, 10 hours and 26 hours, respectively, of shutting off the pump. In OW1, 100 % water level recovery was noted within 23 hours of shutting off the pump (at 4320 minutes). Refer to Figure 4 for drawdown and recovery data for both wells.




Figure 4: Drawdown and Recovery Data – All Wells

Water levels recovered 100 % in PW1 within 26 hours of the end of the pump test. In OW1, 100 % water level recovery was achieved within 23 hours of shutting off the pump. It was noted during the recovery period that water levels in PW1 and OW1 fluctuated due to tidal effects. Fluctuations were more pronounced in PW1 and water levels fluctuated between 0.09 m and 0.45 m due to tidal effects. Refer to Figures 5 and 6 for recovery data. From Figure 5, it appears that residual drawdown reaches '0' near t/t'=2, indicating complete recovery, although interpretation is made difficult due to fluctuations in residual drawdowns, which are attributed to tidal effects.





Figure 5: Residual Drawdown Recovery Data – All Wells





4.2.1 Pumping Test Analysis

After completion of the 72-hour pumping test, transmissivity was calculated from the drawdown and recovery data from pumping well PW1 using the Cooper-Jacob straight line method. The log time versus drawdown plots are shown in Appendix D. The calculated transmissivities for PW1 are shown in Table 3.

Well No.	Draw	down	Recovery		
	TransmissivityTransmissivity(minimum)(maximum)m²/daym²/day		Transmissivity (minimum) m²/day	Transmissivity (maximum) m²/day	
PW1	23.2	30.9	19.96	34.22	

 Table 3: Transmissivity Values

Transmissivities calculated based on the recovery data are considered more representative of the aquifer than data collected under pumping conditions. Based on the distance-drawdown plot, the maximum radius of influence extends approximately 230 metres from PW1. Refer to Figures 6 and 7 in Section 5.1 for the distance-drawdown data.

The specific capacity calculated for PW1 during the pumping test was 24.23 m³/day/m. A storativity value of 0.0014 was calculated using time drawdown data obtained from OW1. According to Driscoll (1986), the coefficient of storage for confined aquifers ranges from 10^{-5} to 10^{-3} , and from 0.01 to 0.3 for unconfined aquifers. The calculated storativity value is reflective of a confined aquifer.

4.2.2 Recommended Sustainable Yield (PW1)


PW1's specific capacity after 100 days of pumping was calculated using the pumping rate of 20 Igpm (131 m³/day) and extrapolating the drawdown at 100 days from the Time vs. Drawdown graph. The drawdown at 100 days is 5.4 m and the pumping well's specific capacity is 24.23 m³/d/m. The total available drawdown in the well is calculated using the depth from the static water level (3.56 m bgs) to mean sea level (6.74 m bgs). Based on available site information, the total available drawdown in the well is 3.2 m (to mean sea level). The long-term sustainable yield (Q) is calculated based on the following formula:

 $Q=Specific Capacity at 100 days x available drawdown in the well <math display="inline">Q=24.23\ m^3/day/m$ x 3.2 m $Q=78\ m^3/day$ or 12 Igpm

PW1, operating at a continuous rate of 78 m³/day (12 Igpm) over a 24-hour period, corresponds to the same water withdrawal as operating at a pumping rate of 20 Igpm for a maximum of 14 hours per day. Based on the pump test, pumping PW1 at a rate of 131 m³/day (20 Igpm) resulted in a drawdown of 3.78 m after 14 hours of continuous pumping which corresponds to a pumping water level below sea level (refer to Figure 7). However, it should be noted that the casing in PW1 extends below sea level and the drawdown is likely more pronounced due to the casing length. It is likely that the well construction of PW1 has more influence on the pumping water level than does the actual pumping rate. The potential for saltwater intrusion into PW1 is considered unlikely at a pumping rate of 20 Igpm based on the assessment outlined in Section 5.2.

WATER SUPPLY SOURCE ASSESSMENT Little Shemogue, NB

It should be noted that PW1 would be operated on a cycle basis and would not pump continuously throughout the day while the campground is operating. It should also be noted that the campground operates from May to October and water withdrawal would be restricted to this time period. Based on the above, it is recommended that PW1 be pumped at a rate not to exceed 20 Igpm (131 m³/day) for a maximum of 14 hours per day, which equates to a daily maximum water withdrawal of 76.4 m³/day.



4.2.5 Groundwater Quality

Groundwater samples were collected from the pumping well (PW1) towards the beginning (24 hours), middle (48 hours) and near the end (69 hours) of the pump test. All samples were submitted to AGAT Laboratories in Dartmouth, Nova Scotia, for general chemistry, trace metals and microbiological analyses. Laboratory certificates are enclosed in Appendix E.

General chemistry and trace metals results for the samples collected at the beginning and end of the pump test are all within the *Canadian Drinking Water Quality Guidelines* (CDWQ) and *New Brunswick Drinking Water Guidelines* (NB) potable guideline values with the exception of turbidity and manganese. The turbidity value of 1.3 NTU (48 hours) slightly exceeds the CDWQ guideline range of 0.1 to 1.0 NTU and the NB guideline of 1.0 NTU. It should be noted that turbidity values in PW1 were below guidelines at 24 hours and 69 hours into the pump test. The levels of turbidity in the well may be related to sediment dislodged during removal of the pump and installation of the driller's pump for completion of the pump test. Furthermore, an iron build-up was noted on the casing and discoloured the water level tape used to collect manual readings throughout the test. The friction of the tape against the casing may also have contributed to

sediments in the well water. The reported turbidity levels are not considered a concern for human health and turbidity levels should decrease over time with continued well use.

Manganese in PW1 exceeded the CDWQ guideline of less than or equal to $50 \ \mu g/L$ towards the beginning of the test (24 hours) and decreased to below the CDWQ guideline for the remainder of the pump test (48 hours and 69 hours). It is likely that elevated manganese was associated with sediment content present in the well at the start of the test. With further pumping, manganese concentrations decreased to within the acceptable guideline.

Microbiological results for the samples collected towards the beginning, middle and end of the pump test indicate no counts for total coliforms or *E.coli*. All results meet the CDWQ and NB guideline values of 0 MPN/100 ml for both total coliforms and *E.coli*. Following completion of the pumping test, the water quality in the pumping well meets potable guidelines. Water quality results for PW1 are shown in Table 4.

Parameter	Units	CDWQ	NB	24 h	48 h	69 h	
General Chemistry							
Ammonia (as N)	mg/L			0.03	0.05	< 0.03	
pH	units	7.0-10.5		8.01	7.96	8.09	
Alkalinity (as CaCO3)	mg/L			117	118	118	
Chloride	mg/L	≤ 250	250	24	24	25	
Colour	TCU	15		6	5	14	
Fluoride	mg/L		1.5	< 0.12	< 0.12	< 0.12	
Sulfate	mg/L	\leq 500	500	7	7	7	
Nitrate (as N)	mg/L	45	45	1.88	2.03	1.91	
Nitrite (as N)	mg/L	3		< 0.05	< 0.05	< 0.05	
o-Phosphate (as P)	mg/L			< 0.01	< 0.01	< 0.01	
Phosphorus	mg/L			< 0.02	< 0.02	< 0.02	
r-Silica (as SiO2)	mg/L			10.8	9.0	11.7	
Total Organic Carbon	mg/L			< 0.5	< 0.5	< 0.5	
Turbidity	NTU	0.1-1.0	1.0	0.5	1.3	0.8	
Conductivity	μS/cm			332	322	332	
Total Dissolved Solids	mg/L	\leq 500		177	174	178	
Trace Metals	8						
Aluminum	μg/L	<100		<5	11	<5	
Antimony	μg/L	6	6	<2	<2	<2	
Arsenic	μg/L	10	10	<2	<2	<2	
Barium	μg/L	1000	1000	431	421	413	
Beryllium	μg/L			<2	<2	<2	
Bismuth	μg/L			<2	<2	<2	
Boron	μg/L	5000	5000	34	32	28	
Cadmium	μg/L	5	5	< 0.017	< 0.017	< 0.017	
Calcium	μg/L			44700	42800	43700	
Chromium	μg/L	50	50	3	3	<1	
Cobalt	μg/L			<1	<1	<1	
Copper	μg/L	≤1000	1000	<2	<2	<2	
Iron	μg/L	≤ 300	300	<50	<50	<50	
Lead	μg/L	10	10	< 0.5	< 0.5	< 0.5	
Magnesium	μg/L			3900	3600	4100	
Manganese	μg/L	\leq 50		72	22	21	
Molybdenum	μg/L			<2	<2	<2	
Nickel	μg/L			<2	<2	<2	
Potassium	μg/L			1600	1500	1700	
Selenium	μg/L	50	10	<1	<1	<1	
Silver	μg/L			< 0.1	< 0.1	< 0.1	
Sodium	μg/L	\leq 200,000	200,000	17300	15600	17700	
Strontium	μg/L	,	,	633	583	521	
Thallium	μg/L			< 0.1	< 0.1	< 0.1	
Tin	μg/L			<2	<2	<2	
Titanium	μg/L			<2	<2	<2	
Uranium	μg/L	20	20	2.3	2.2	2.1	
Vanadium	μg/L			4	4	4	
Zinc	μg/L	≤5000		8	9	<5	
Microbiology							
	/IPN/100 mL	Absent	Absent	Absent	<1	<1	
	/IPN/100 mL	Absent	Absent	Absent	<1	<1	
"Bold" exceeds applical				•	•	·]	

Table 4: PW1 Groundwater Quality

5.0 DISCUSSION

5.1 Neighbouring Water Users

Based on the results of the hydraulic testing, the radius of influence for PW1 extends approximately 230 metres when the production well is operating at a rate of 131 m³/day (20 Igpm) (refer to Figure 8). OW1 is located at a distance of 216 m from PW1. Approximately 0.29 m of drawdown was observed in OW1 during the pumping test. The closest neighbouring residential well (PID 70063144) is located approximately 130 metres east of PW1 and eight (8) private wells are located on neighbouring properties within 230 metres of PW1. Based on the Distance-Drawdown plot (see Figure 8), 2 m of drawdown is estimated at a distance of 130 metres from the pumping well. Note that the drawdown also includes interferences from tidal effects. Throughout the pumping test and recovery period, no residents in the area contacted the proponent or Roy Consultants' personnel with complaints regarding water quality or quantity. Surrounding land use within 500 m of the campground is residential (primarily seasonal cottages). No potentially adverse impacts on the groundwater supply are anticipated due to current or historical land uses.




Figure 8: Distance-drawdown Data from the 72-hour Constant Rate Pump Test

At the recommended pumping rate of 20 Igpm for a maximum of 14 hours per day, the maximum drawdown at PW1 is approximately 3.78 m based on the pump test data. Operating at 20 Igpm for a continuous 14-hour period will slightly reduce the radius of influence to 220 metres (refer to Figure 9). The corresponding drawdown in the nearest neighbouring well (130 m away) is approximately 2 m. However, upon further review of the pump test data, water level drawdown (0.10 metre) in OW1 did not occur until after 10 hours of continuous pumping at 20 Igpm. It should be noted that PW1 would be operated on a cycle basis and would not pump continuously throughout the day while the campground is operating. As a result, the radius of influence is expected to be less than 220 metres and the corresponding drawdown of 2 metres in the nearest neighbouring well is also expected to be less. The operation of the production well is expected to have minimal interference with neighbouring water users. Based on the above, it is

recommended that PW1 be pumped at a rate not to exceed 20 Igpm (131 m^3/day) for a maximum of 14 hours per day.




Figure 9: Distance-drawdown Data after 14 Hours of Continuous Pumping at 20 Igpm

5.2 Potential for Saltwater Intrusion

The production well is located approximately 75 metres from the Northumberland Strait. A review of water quality data during the pump test was completed to assess any observable trends in certain parameters that may indicate saltwater intrusion. According to Drever (1988), the parameters listed in Table 5 are some of the major elements that comprise sea water. Parameters listed in Table 5 are listed in order from most concentrated to least concentrated in seawater. For example, chloride is the parameter with the highest concentration in seawater and strontium has a lower concentration. Concentrations for major solutes (chloride and sodium) remained relatively constant throughout the pump test. The water quality observed during the pumping test does not suggest that saltwater intrusion into the aquifer is occurring. It should be also be noted that PW1 has been supplying the campground since 2012 with no reported water quality issues.

Table 5. 1 W1 Water Quarty Results – Farameter's Associated with Saitwater							
Parameter	PW1 (24 h)	PW1 (48 h)	PW1 (69 h)				
Chloride (mg/L)	24	24	25				
Sodium (mg/L)	17.3	15.6	17.7				
Sulfate (mg/L)	7	7	7				
Magnesium (mg/L)	3.9	3.6	4.1				
Calcium (mg/L)	44.7	42.8	43.7				
Potassium (mg/L)	1.6	1.5	1.7				
Bicarbonate (mg/L)	117	118	118				
Strontium (µg/L)	633	583	521				
Boron (µg/L)	34	32	28				
r-Silica (mg/L)	10.8	9.0	11.7				

 Table 5: PW1 Water Quality Results – Parameters Associated with Saltwater

WATER SUPPLY SOURCE ASSESSMENT Little Shemogue, NB

As pumping well PW1 is located within 500 m of a saltwater source (Northumberland Strait), an evaluation of the potential for saltwater intrusion was undertaken. A review of available literature was completed. Rivard et al. (2008) completed a regional hydrogeological characterization of the south-central part of the Maritimes Basin which included a geophysical survey along Cap Brûlé Road near Shediac, NB, which is located approximately 40 km west of the campground. This area is underlain by the same geological formation (Richibucto Formation) as the campground. The survey did not detect any zones of very low resistivity, suggesting that saline water does not occur within 40 m of the surface. From the 72-hour pump test, it was determined that PW1 is situated in a confined aquifer and the maximum drawdown observed during the pump test was 4.69 m. If we use 40 m as the distance from surface to the top of the fresh water/salt water interface (to be conservative), operating the well at 20 Igpm will result in a maximum drawdown of 4.69 m, correlating to a distance of 31.75 m above the fresh water/salt water interface. Therefore, operating the well at a pumping rate of 20 Igpm will not result in a drawdown that will induce saltwater intrusion.

5.3 Groundwater under the Direct Influence off Surface Water (GUDI)

An evaluation was completed for the potential influence of surface water on the groundwater source. Groundwater is considered under the direct influence of surface water if there is:

- a direct hydraulic connection to the surface or surface water by way of local geology or well construction; and/or
- Significant and relative rapid shifts in water characteristics such as temperature, turbidity, conductivity and pH which closely correlate with climatological events; and/or
- Significant occurrence of micro-organisms.

The closest surface water body to the production well is the Northumberland Strait located approximately 75 m north of the well. The nearest freshwater surface water bodies are watercourses: Trout Brook (1.05 km west of the campground) and Scott Brook (1.2 km east). The area surrounding the well head consists of developed RV lots with gravel pads and grass cover and gravel access roads. No standing water is present near the well house. The construction of PW1 includes 10.97 m (36 feet) of steel casing and the well is drilled to a depth of 32 m. The local geology consists of interbedded layers of shale and sandstone bedrock. The well draws its water from a confined sandstone bedrock aquifer with major water-bearing fractures noted at depths of 18.3 m (15 Igpm), 24.38 m (10 Igpm) and 27.7 m (10 Igpm).

According to Environment Canada's daily climate data from the Moncton International Airport, there were 38.4 mm of precipitation during the 14 days preceding the pump test. An estimated 46.6 mm of precipitation were noted during the pump test from November 19 to 22, 2017. An estimated 5.8 mm of precipitation were noted during the recovery period on November 23, 2017. Water level data in PW1 and OW1 do not show a spike in water levels associated with the rainfall events. Water level fluctuations are attributed to tidal effects. Considering both wells have over 10 m (30 feet) of casing each, any surface recharge to the wells during the pump test is considered minimal. Further, temperature readings measured throughout the test by the dataloggers do not show any fluctuations. Refer to Appendix F for the Environment Canada Daily Data Report for November 2017 and Appendix D for temperature readings.

A review of raw groundwater quality data collected from PW1 at 24 hours, 48 hours and 69 hours into the pump test does not indicate any significant changes in turbidity, conductivity and pH. Reported levels for all parameters were consistent for all three sampling events. Refer to Section 4.2.5 for further discussion. No detection of microbiological parameters (total coliforms and E. coli) was reported for all three sampling events. Further, water quality sampling was previously

completed in May 2017 for PW1 and no detection of total coliforms or E. coli were reported. Refer to Appendix E for laboratory certificates.

PW1 is a deep well drawing groundwater from a confined aquifer. The well is located more than 60 m from the nearest freshwater surface water body. The well casing extends more than 6 m and has an appropriate sized drive shoe. Water quality data collected throughout the duration of the pump test indicates no detection of total coliforms or E. coli bacteria and other indicator parameters (pH, turbidity, conductivity and temperature) do not show any obvious signs of surface water influence. Based on the above, groundwater supplying PW1 is not considered under the influence of surface water.

6.0 CONCLUSIONS AND RECOMMENDATIONS

Roy Consultants supervised the 72-hour constant rate test for PW1 completed in November 2017. The objective of the pump test was to determine the maximum sustainable yield of the water supply for the Strang's Shore Campground. To accommodate the existing and future lots (a total of 150 lots), the estimated water demand is approximately 10 Igpm (68 m³/day).

PW1 was pumped at a rate of 20 Igpm (131 m³/day) and a maximum observed drawdown of 4.69 m was noted. The calculated transmissivities of the aquifer from the recovery portion of the pump test range from 19.96 m²/d to 34.22 m²/d. Following the end of the pumping test, water levels in PW1 recovered 100 % within 26 hours after the pump was shut off.

Groundwater results for general chemistry, trace metals and microbiological analyses from the pumping well indicate turbidity and manganese exceedances of CDWQ and NB Drinking Water guidelines. The turbidity level was slightly above the CDWQ and NB guidelines in the middle of the test, but was below guidelines towards the beginning and end of the pump test. Turbidity levels typically decrease over time with continued well use. The manganese concentration exceeded the CDWQ guideline towards the beginning of the test, but decreased to below the guideline for the remainder of the test. Both parameters are attributed to sediment content in the well and should decrease over time with continued well use. Based on the water quality results observed throughout the pump test, there is no indication that saltwater intrusion is occurring.

Based on the results of the pump test, a pumping rate of 20 Igpm (131 m^3 /day) operating for a maximum of 14 hours per day is recommended for PW1. Pumping at 20 Igpm for 14 hours per day equates to a maximum daily withdrawal of 76.4 m^3 /day which meets the future estimated water demand of 68 m^3 /day. It is also recommended that a flow meter be installed and water usage recorded over an operating season (May to October) to determine actual water consumption. Water quality samples should also be collected on a monthly basis (at a minimum) and analyzed for conductivity to monitor for possible saltwater intrusion.

7.0 CLOSURE

This report was prepared by Roy Consultants for the exclusive use of Strang's Shore Seasonal Camping Inc. The data contained herein may not be used by any other person or entity without the express written consent of Roy Consultants and Strang's Shore Seasonal Camping Inc. While this report provides an overview of environmental conditions, the assessment is limited by the availability of information at the time of the study. Field work was carried out by Mr. Abram Lee, EIT, and Ms. Gina Burtt, P.Eng., P.Geo. Reporting was carried out by Ms. Gina Burtt, P.Eng., P.Geo.

8.0 **REFERENCES**

British Columbia Ministry of Environment, Lands and Parks. 1999. Evaluating long-term well capacity for a certificate of public convenience and necessity: a guidance document. Water Management Branch, Groundwater Section. ISBN 0-7726-4019-X.

Drever, J.I. 1988. The Geochemistry of Natural Waters. Second Edition Prentice Hall, Englewood Cliffs, New Jersey 07632, USA, pp.1-437.

Driscoll, F.G. 1986. Groundwater and Wells. Second Edition Johnson Division, St. Paul Minnesota 55112, USA, pp. 1-1089.

Freeze, R.A. and Cherry, J.A. 1979. Groundwater. Prentice-Hall, Inc., Englewood Cliffs, N.J. 07632, USA, pp. 1-604.

Government of Canada. 2017. The Atlas of Canada. Toporama, version 2.3. <u>http://atlas.gc.ca/toporama/en/index.html</u>.

Health Canada. 2017. Guidelines for Canadian Drinking Water Quality Summary Table. Federal-Provincial-Territorial Committee on Drinking Water of the Federal-Provincial-Territorial Committee on Health and the Environment.

New Brunswick Department of Environment and Local Government. 2017. Environmental Impact Assessment Water Supply Source Assessment Guidelines.

Rampton, V. N. 1984. Generalized surficial geology map of New Brunswick Department of Natural Resources and Energy. Mineral, Policy and Planning Division. NR-8 (scale 1: 500 000).

Rivard, C., Michaud, Y., Deblonde, C., Boisvert, V., Carrier, C., Morin, R.H., Calvert, T., Vigneault, H., Conohan, D., Castonguay, S., Lefebvre, R., Rivera, A., and Parent, M. 2008. Canadian Groundwater Inventory: Regional hydrogeological characterization of the south central part of the Maritimes Basin; Geological Survey of Canada. Bulletin 589, 96 p.

Service New Brunswick. NBGIC Parcel Data, 2017. Real Property Information PID numbers 00837088, 70188826 and 70563457. New Brunswick. Canada.

Smith, E.A. (compiler). 2007. Bedrock geology of the Cape Tormentine area (NTS 11L/04), Westmorland County, New Brunswick. New Brunswick Department of Natural Resources, Minerals, Policy and Planning Division, Plate 2007-46. Scale 1:50,000.

APPENDICES

APPENDIX A: Figures

APPENDIX B: SNB Documentation

APPENDIX C: Well Driller's Reports

APPENDIX D: Pumping Test Data for Pumping Wells and Observation Well

APPENDIX E: Laboratory Certificates

APPENDIX F: Environment Canada Daily Data Report and Tide Tables

APPENDIX G: NBDELG Documentation

APPENDIX A

Figures

APPENDIX B

SNB Documentation

APPENDIX C

Well Driller's Reports

APPENDIX D

Pumping Test Data for Pumping Wells and Observation Well

APPENDIX E

Laboratory Certificates

APPENDIX F

Environment Canada Daily Data Report and Tide Tables

APPENDIX G

NBDELG Documentation

WATER SUPPLY SOURCE ASSESSMENT Strang's Shore Seasonal Camping Inc. 1639 Route 955 Little Shemogue, (Murray Corner), NB PID No. 00837088

> Our File No.: 278-17 January, 2018

Prepared for:

Jerry and Linda Strang 89 Moore Road Ext. Otter Creek, NB E4M 3V5

Prepared by:





T. : 506 472-9838 = F. : 506 472-9255

364, rue York Street, Suite 201 Fredericton (NB) E3B 3P7 www.royconsultants.ca

January 19, 2018

Jerry and Linda Strang Strang's Shore Seasonal Camping Inc. 89 Moore Road Ext. Otter Creek, NB E4M 3V5

Our File No.: 278-17-C¹

Mr. and Mrs. Strang:

Subject: Water Supply Source Assessment Strang's Shore Seasonal Camping Inc. 1639 Route 955 Little Shemogue (Murray Corner), NB PID No. 00837088

We are pleased to present you with the water supply source assessment for Strang's Shore Seasonal Camping Inc. in Little Shemogue (Murray Corner), New Brunswick.

The assessment has determined that there is an adequate supply of water to support the existing campground facility and the proposed future expansion. It is recommended that production well PW1 be operated at a rate not to exceed 20 Igpm (131 m^3 /day) for a maximum of 14 hours per day and a flow meter be installed on the well to monitor actual water consumption. Water quality samples should be collected on a monthly basis (at a minimum) and analyzed for conductivity to monitor for possible saltwater intrusion.

Should you have any questions regarding this report, please do not hesitate to contact the undersigned.

Yours truly,

Gina Butt

Gina Burtt, M.Sc., P.Eng. P.Geo. ENVIRONMENTAL Engineer

GB/jb/sl Enc.

¹ 278-17 Pump Test Report Jan 2018.doc

TABLE OF CONTENTS

i) Letter of Introduction

ii)	Table o	f Contents
-----	---------	------------

1.0	INTRODUCTION	1
1.	Project Description	1
2.0	EXISTING SITE CONDITIONS	2
2	~r	2
2. 2.		
3.0	HYDROGEOLOGICAL CONDITIONS	4
3	- · · · · · · · · · · · · · · · · · · ·	
3.		
4.0	HYDRAULIC TESTING	
4.	~···F	
4.	/2 noti i unping i com	
	4.2.1 Pumping Test Analysis 1 4.2.2 Recommended Sustainable Yield (PW1) 1	
	4.2.5 Groundwater Quality	
5.0	DISCUSSION1	5
5.	Neighbouring Water Users1	5
5.		
5.	Groundwater under the Direct Influence of Surface Water (GUDI)1	7
6.0	CONCLUSIONS AND RECOMMENDATIONS1	9
7.0	CLOSURE2	0
8.0	REFERENCES2	1

APPENDICES

APPENDIX A: Figures
APPENDIX B: SNB Documentation
APPENDIX C: Well Driller's Reports
APPENDIX D: Pumping Test Data for Pumping Well and Observation Well
APPENDIX E: Laboratory Certificates
APPENDIX F: Environment Canada Daily Data Report and Tide Tables
APPENDIX G: NBDELG Documentation

1.0 INTRODUCTION

Jerry and Linda Strang, on behalf of Strang's Shore Seasonal Camping Inc., retained the services of Roy Consultants to complete a water supply source assessment for the existing campground in Little Shemogue (Murray Corner), New Brunswick (PID Nos. 00837088, 70188826 and 70563457), herein referred to as the "subject property". Refer to Figure 1 in Appendix A for the site location plan.

This report has been prepared in accordance with the New Brunswick Department of Environment and Local Government's (NBDELG) Environmental Impact Assessment *Water Supply Source Assessment Guidelines* (April 2017). These guidelines are used to assist proponents engaging in projects that require a Water Supply Source Assessment (WSSA) through the Environmental Impact Assessment (EIA) process. A WSSA includes, but is not limited to, an evaluation of the sustainability of the water supply, an assessment of water quality, an evaluation of potential impacts to existing water users and an assessment of the potential for saltwater intrusion. The WSSA guidelines are enclosed in Appendix G.

1.1 **Project Description**

Strang's Shore Seasonal Camping Inc. (hereinafter "the proponent") currently operates a campground with 115 serviced lots at 1639 Route 955, Little Shemogue (Murray Corner), New Brunswick (Westmorland County). The campground began operating in 2012 and includes three parcels of land identified by Service New Brunswick as PID Nos. 00837088, 70188826 and 70563457. For a campground with water and sewer hook-ups, the NBDELG recommends 450 L per space per day for water usage. The estimated current water demand is $52 \text{ m}^3/\text{day}$. The campground will expand in the future for a total of 150 serviced lots with an approximate water demand of $68 \text{ m}^3/\text{day}$. Currently, the actual water usage is unknown. As limited information is available on current water usage, the objective of the water supply source assessment is to complete a pump test on the existing production well to determine its recommended safe yield.

2.0 EXISTING SITE CONDITIONS

2.1 Site Description

The campground is located in a rural area surrounded by cottage/residential buildings. The subject property, identified by the Service New Brunswick (SNB) parcel identification (PID) number 00837088, is zoned "rural zone" according to the Tantramar Rural Zoning Map Schedule A. Development in the area includes residences and/or cottages to the east, south and west and the Northumberland Strait borders the northern property line. Refer to Figure 1 in Appendix A.

The pumping well (PW1) is located on PID No. 00837088, which covers an area of 3.43 hectares. The observation well (OW1) is located on PID No. 70188826, which has an area of 1.13 hectares. No wells are located on the third parcel of land comprising the campground, PID No. 70563457, which has an area of 3.27 ha. SNB documentation is enclosed in Appendix B. The nearest neighbouring domestic well is located approximately 130 metres east and cross gradient of PW1, along Highway 955 (PID No. 70063144).



Photos 1 and 2: Photo at left shows the well house (looking northeast). Photo at right shows production well PW1 located inside the well house (July 5, 2017).



Photo 3: View of observation well OW1 looking south towards Highway 955 (October 16, 2017)

2.2 Current Groundwater Use

There are two (2) existing on-site potable wells (PW1 and OW1); however, only PW1 services the campground. The wells are located approximately 216 m from each other. PW1 is equipped with a Pentek® 2 horsepower submersible pump with a capacity of 25 USgpm (21 Igpm). OW1 is not hooked up to the water supply system. This well is a remnant from a mobile home that previously occupied PID No. 70188826 prior to that land parcel's purchase by Strang's Shore Seasonal Camping Inc.

2.3 Well Construction

PW1 was constructed on August 2, 2010 (Well ID 24773). The well is 150 mm (6 inches) in diameter and completed to a depth of 32 metres (105 feet). Based on the well driller's report, the predominant bedrock is comprised of alternating layers of grey sandstone and red shale. Depth to the bedrock level is 6.4 metres below ground surface (bgs). OW1 was constructed on August 13, 2014 (Well ID 30194). The well is 150 mm (6 inches) in diameter and completed to a depth of 19.8 metres (65 feet). OW1 was deepened to a depth of 32 metres (105 feet) on October 16, 2017 by Charlie Herman Chappell Well Drilling, out of Colpitts Settlement, NB. All well locations are shown on Figure 1 in Appendix A. The well driller reports for PW1 and OW1 are enclosed in Appendix C.

Well ID	GPS Coordinates		Date Drilled	Well Depth	Casing Depth	Driller's Estimated	Static Water
	Northing	Easting		(btoc) (m)	(btoc) (m)	Safe Yield (Igpm)	Level (btoc) (m)
PW1	7467524.674	2695018.638	August 2010	32	10.97	20	4.13*
OW1	7467310.055	2694998.413	August 2014	32	12.19	35	3.465*

Table 1: Summary of On-site Potable Well Information

(*) as measured on November 19, 2017

3.0 HYDROGEOLOGICAL CONDITIONS

3.1 Topography and Drainage

The subject property is located within the New Brunswick Lowlands physiographic unit. Based on the well elevation survey completed by Roy Consultants in November 2017, the ground surface elevations noted at PW1 and OW1 were 6.74 m and 7.7 m above mean sea level, respectively. The property was noted to gently slope north towards the Northumberland Strait. Surface water drainage across the subject property is northerly via overland flow. No drainage ditches were noted on the subject site. Drainage is good, evidenced by no mapped wetlands on the subject site. Standing water and wet areas were not observed during field work completed in November 2017. The area to the south, which could potentially contribute groundwater to the study area, is a mix of developed residential and vacant/wooded lots.

3.2 Geology

The surficial geology for the area consists of Late Wisconsinan morainal sediments blanket deposits consisting of loamy lodgment till, minor ablation till, silt, sand, gravel and rubble generally 0.5 m to 3 m thick (Rampton, 1984). According to the well driller's log for PW1, the underlying site stratigraphy (from top to bottom) consists of clay and sand at depths from 0 to 6.4 metres bgs and sand present from 6.4 m to 9.1 metres bgs.

The bedrock underlying the subject property is comprised of Late Carboniferous-aged sedimentary rocks comprised of the Pictou Group, Richibucto Formation consisting of grey and brownish red, commonly micaceous lithic and arkosic sandstone, pebbly sandstone and intraformational mudstone-clast conglomerate, brownish red to brick-red and lesser grey siltstone and mudstone, minor intraformational limestone-cobble conglomerate and thin laterally extensive limestone beds and minor thin coal seams (Smith, 2007). According to the well driller's log for PW1, grey sandstone was encountered at a depth of 12.5 metres bgs. Refer to Appendix C for the well driller's report.

3.3 Hydrogeology

Based on a review of seven (7) water well logs within 500 metres of the subject property (PID 00837088), the local aquifer is comprised of a fractured sandstone bedrock aquifer. According to well drillers' reports, several major water-bearing fractures are noted at depths of approximately 17 m, 25 m and 29 m. Well depths range between 19.8 m and 73.5 m and well yields range from 3 Igpm to 25 Igpm (19.6 m³/day to 163.6 m³/day). Most well logs indicate a confined aquifer scenario of sandstone bedrock interbedded with layers of shale. Refer to well driller's reports in Appendix C for further details.

The subject property is located immediately adjacent to the Northumberland Strait, which is under tidal influence. Water levels in the area are expected to be influenced to some degree by high and low tides. Potential recharge sources to the wells on the subject site include direct infiltration from precipitation and groundwater flow from upland areas.

4

4.0 HYDRAULIC TESTING

Hydraulic testing was completed at PW1 from November 19 to November 22, 2017. A 72-hour constant rate pumping test was completed in accordance with NBDELG's WSSA guidelines. During the test, groundwater from PW1 was contained and discharged through approximately 75 m of 4-inch diameter PVC pipe into the Northumberland Strait. Refer to Photos 4 and 5. The site topography slopes northward, away from the pumping well, towards the Northumberland Strait. The discharge location of the pumped water did not allow artificial recharge to PW1 and OW1.



Photo 4: View of water discharge line directing pumped water towards the Northumberland Strait (November 19, 2017).



Photo 5: View of water discharge (November 19, 2017)

4.1 Step Test

Prior to commencement of the 72-hour continuous pumping test, a step test was conducted to determine the optimal pumping rates for the long-term test at PW1. The existing pump in PW1 was pulled prior to the test and a 5-horsepower pump was installed by Charlie Herman Chappell Well Drilling. Installation of a larger pump allowed for higher pump rate at which to step test the well. The pump was installed at a depth of 27.4 m (90 feet). Step test intervals were 30 minutes in length, each having a higher pumping rate than the previous interval. Three steps were completed at 10 Igpm, 20 Igpm and 30 Igpm, respectively. Pumping rates were verified by the driller using a 20-gallon bucket and stopwatch. Water levels were allowed to recover following completion of each step. Leveloggers were installed in both the pumping and observation wells to recover water levels in addition to collecting manual water measurements. Drawdown and recovery data for PW1 throughout the step test are shown in Figure 1.




Figure 1: Step Test Data PW1 – Drawdown vs Time

At the beginning of the step test, the static water level in PW1 was 3.56 m bgs. During the first step, at a pumping rate of 10 Igpm, drawdown stabilized at approximately 4.52 m bgs. During the second step, at a pumping rate of 20 Igpm, the pumping water level stabilized at approximately 5.61 m. At the end of the third step, at a pumping rate of 30 Igpm, the pumping water level was 7.08 m bgs and did not appear to have stabilized. The maximum drawdown observed in OW1 during the pumping portion of the step test was 0.029 m (water level of 2.924 m bgs). The water level recovery in PW1 was 94 % recovery after 30 minutes of the end of the last step. Based on the results of the step test, a pumping rate of 20 Igpm (131 m³/day) was selected for PW1 for the constant rate test. All step test data and plots are enclosed in Appendix D.

4.2 72-hour Pumping Test

The 72-hour constant rate test was started at 2:30 p.m. on November 19, 2017, and the pump was shut off at 2:30 p.m. on November 22, 2017. The average flow rate measured over the duration of the test was 20 Igpm (131 m³/day) from PW1. The flow rate was monitored regularly throughout the duration of the pump test by the driller using a 20-gallon bucket and stopwatch.


Results from the pumping well and observation well during the 72-hour pumping test are presented in Table 2. Water level data are shown in Figure 2 and drawdown data is presented in Figure 3. Refer to the pumping test data and graphs in Appendix D for further details.

Well ID	Well Type	Distance from Pumped Well (m)	Ground Surface Elevation (m)	Static Water Elevation (m)	Maximum Observed Drawdown (m)	Time of Maximum Observed Drawdown (Hour into Pumping Test)
PW1	Pumping	N/A	6.74	3.563 (bgs) 3.177 (amsl)	4.69	67
OW1	Observation	216	7.70	2.895 (bgs) 4.805 (amsl)	0.29	66

Table 2. Summary of 72-hour Constant Rate Test Data

bgs = below ground surface

amsl = above mean sea level





WATER SUPPLY SOURCE ASSESSMENT Little Shemogue, NB

The water level in PW1 appeared to stabilize over the duration of the pumping test. However, fluctuations in drawdown were noted which are attributed to pumping rate adjustments made by the driller and tidal effect. The pumping rate had to be adjusted after 37 hours of pumping (2220 minutes), 44 hours (2640 minutes), 50 hours (3000 minutes), 52 hours (3120 minutes) and 63 hours (3780 minutes).




Figure 3: 72-hour Constant Rate Test Drawdown Data

The maximum drawdown in PW1 was 4.69 m, which corresponds to a pumping water level of approximately 1.51 m below sea level (bsl). The maximum drawdown observed in OW1 was 0.29 m, which corresponds to a water level of 4.515 m above sea level (asl). Water levels in OW1 remained above sea level throughout the duration of the pumping test.

Some minor fluctuations in water levels are noted in the drawdown data for both wells and are attributed to tidal effects. Fluctuations correlate with the tide schedules for Cape Tormentine. Based on the drawdown data, drawdowns of approximately 0.17 m in PW1 and 0.02 m in OW1 are attributed to tidal influence during the pumping test. Refer to Appendix F for tide tables.

Following completion of the pumping test, recovery in both wells was very good. In PW1, water levels recovered 71 %, 92 % and 100 % within 1 hour, 10 hours and 26 hours, respectively, of shutting off the pump. In OW1, 100 % water level recovery was noted within 23 hours of shutting off the pump (at 4320 minutes). Refer to Figure 4 for drawdown and recovery data for both wells.




Figure 4: Drawdown and Recovery Data – All Wells

Water levels recovered 100 % in PW1 within 26 hours of the end of the pump test. In OW1, 100 % water level recovery was achieved within 23 hours of shutting off the pump. It was noted during the recovery period that water levels in PW1 and OW1 fluctuated due to tidal effects. Fluctuations were more pronounced in PW1 and water levels fluctuated between 0.09 m and 0.45 m due to tidal effects. Refer to Figures 5 and 6 for recovery data. From Figure 5, it appears that residual drawdown reaches '0' near t/t'=2, indicating complete recovery, although interpretation is made difficult due to fluctuations in residual drawdowns, which are attributed to tidal effects.





Figure 5: Residual Drawdown Recovery Data – All Wells





4.2.1 Pumping Test Analysis

After completion of the 72-hour pumping test, transmissivity was calculated from the drawdown and recovery data from pumping well PW1 using the Cooper-Jacob straight line method. The log time versus drawdown plots are shown in Appendix D. The calculated transmissivities for PW1 are shown in Table 3.

Well No.	Draw	down	Recovery		
	Transmissivity (minimum) m²/dayTransmissivity (maximum) m²/day		Transmissivity (minimum) m²/day	Transmissivity (maximum) m²/day	
PW1	23.2	30.9	19.96	34.22	

 Table 3: Transmissivity Values

Transmissivities calculated based on the recovery data are considered more representative of the aquifer than data collected under pumping conditions. Based on the distance-drawdown plot, the maximum radius of influence extends approximately 230 metres from PW1. Refer to Figures 6 and 7 in Section 5.1 for the distance-drawdown data.

The specific capacity calculated for PW1 during the pumping test was 24.23 m³/day/m. A storativity value of 0.0014 was calculated using time drawdown data obtained from OW1. According to Driscoll (1986), the coefficient of storage for confined aquifers ranges from 10^{-5} to 10^{-3} , and from 0.01 to 0.3 for unconfined aquifers. The calculated storativity value is reflective of a confined aquifer.

4.2.2 Recommended Sustainable Yield (PW1)


PW1's specific capacity after 100 days of pumping was calculated using the pumping rate of 20 Igpm (131 m³/day) and extrapolating the drawdown at 100 days from the Time vs. Drawdown graph. The drawdown at 100 days is 5.4 m and the pumping well's specific capacity is 24.23 m³/d/m. The total available drawdown in the well is calculated using the depth from the static water level (3.56 m bgs) to mean sea level (6.74 m bgs). Based on available site information, the total available drawdown in the well is 3.2 m (to mean sea level). The long-term sustainable yield (Q) is calculated based on the following formula:

 $Q=Specific Capacity at 100 days x available drawdown in the well <math display="inline">Q=24.23\ m^3/day/m$ x 3.2 m $Q=78\ m^3/day$ or 12 Igpm

PW1, operating at a continuous rate of 78 m³/day (12 Igpm) over a 24-hour period, corresponds to the same water withdrawal as operating at a pumping rate of 20 Igpm for a maximum of 14 hours per day. Based on the pump test, pumping PW1 at a rate of 131 m³/day (20 Igpm) resulted in a drawdown of 3.78 m after 14 hours of continuous pumping which corresponds to a pumping water level below sea level (refer to Figure 7). However, it should be noted that the casing in PW1 extends below sea level and the drawdown is likely more pronounced due to the casing length. It is likely that the well construction of PW1 has more influence on the pumping water level than does the actual pumping rate. The potential for saltwater intrusion into PW1 is considered unlikely at a pumping rate of 20 Igpm based on the assessment outlined in Section 5.2.

WATER SUPPLY SOURCE ASSESSMENT Little Shemogue, NB

It should be noted that PW1 would be operated on a cycle basis and would not pump continuously throughout the day while the campground is operating. It should also be noted that the campground operates from May to October and water withdrawal would be restricted to this time period. Based on the above, it is recommended that PW1 be pumped at a rate not to exceed 20 Igpm (131 m³/day) for a maximum of 14 hours per day, which equates to a daily maximum water withdrawal of 76.4 m³/day.



4.2.5 Groundwater Quality

Groundwater samples were collected from the pumping well (PW1) towards the beginning (24 hours), middle (48 hours) and near the end (69 hours) of the pump test. All samples were submitted to AGAT Laboratories in Dartmouth, Nova Scotia, for general chemistry, trace metals and microbiological analyses. Laboratory certificates are enclosed in Appendix E.

General chemistry and trace metals results for the samples collected at the beginning and end of the pump test are all within the *Canadian Drinking Water Quality Guidelines* (CDWQ) and *New Brunswick Drinking Water Guidelines* (NB) potable guideline values with the exception of turbidity and manganese. The turbidity value of 1.3 NTU (48 hours) slightly exceeds the CDWQ guideline range of 0.1 to 1.0 NTU and the NB guideline of 1.0 NTU. It should be noted that turbidity values in PW1 were below guidelines at 24 hours and 69 hours into the pump test. The levels of turbidity in the well may be related to sediment dislodged during removal of the pump and installation of the driller's pump for completion of the pump test. Furthermore, an iron build-up was noted on the casing and discoloured the water level tape used to collect manual readings throughout the test. The friction of the tape against the casing may also have contributed to

sediments in the well water. The reported turbidity levels are not considered a concern for human health and turbidity levels should decrease over time with continued well use.

Manganese in PW1 exceeded the CDWQ guideline of less than or equal to $50 \ \mu g/L$ towards the beginning of the test (24 hours) and decreased to below the CDWQ guideline for the remainder of the pump test (48 hours and 69 hours). It is likely that elevated manganese was associated with sediment content present in the well at the start of the test. With further pumping, manganese concentrations decreased to within the acceptable guideline.

Microbiological results for the samples collected towards the beginning, middle and end of the pump test indicate no counts for total coliforms or *E.coli*. All results meet the CDWQ and NB guideline values of 0 MPN/100 ml for both total coliforms and *E.coli*. Following completion of the pumping test, the water quality in the pumping well meets potable guidelines. Water quality results for PW1 are shown in Table 4.

Parameter	Units	CDWQ	NB	24 h	48 h	69 h
General Chemistry						
Ammonia (as N)	mg/L			0.03	0.05	< 0.03
pH	units	7.0-10.5		8.01	7.96	8.09
Alkalinity (as CaCO3)	mg/L			117	118	118
Chloride	mg/L	≤ 250	250	24	24	25
Colour	TCU	15		6	5	14
Fluoride	mg/L		1.5	< 0.12	< 0.12	< 0.12
Sulfate	mg/L	\leq 500	500	7	7	7
Nitrate (as N)	mg/L	45	45	1.88	2.03	1.91
Nitrite (as N)	mg/L	3		< 0.05	< 0.05	< 0.05
o-Phosphate (as P)	mg/L			< 0.01	< 0.01	< 0.01
Phosphorus	mg/L			< 0.02	< 0.02	< 0.02
r-Silica (as SiO2)	mg/L			10.8	9.0	11.7
Total Organic Carbon	mg/L			< 0.5	< 0.5	< 0.5
Turbidity	NTU	0.1-1.0	1.0	0.5	1.3	0.8
Conductivity	μS/cm			332	322	332
Total Dissolved Solids	mg/L	\leq 500		177	174	178
Trace Metals	8					
Aluminum	μg/L	<100		<5	11	<5
Antimony	μg/L	6	6	<2	<2	<2
Arsenic	μg/L	10	10	<2	<2	<2
Barium	μg/L	1000	1000	431	421	413
Beryllium	μg/L			<2	<2	<2
Bismuth	μg/L			<2	<2	<2
Boron	μg/L	5000	5000	34	32	28
Cadmium	μg/L	5	5	< 0.017	< 0.017	< 0.017
Calcium	μg/L			44700	42800	43700
Chromium	μg/L	50	50	3	3	<1
Cobalt	μg/L			<1	<1	<1
Copper	μg/L	≤1000	1000	<2	<2	<2
Iron	μg/L	≤ 300	300	<50	<50	<50
Lead	μg/L	10	10	< 0.5	< 0.5	< 0.5
Magnesium	μg/L			3900	3600	4100
Manganese	μg/L	\leq 50		72	22	21
Molybdenum	μg/L			<2	<2	<2
Nickel	μg/L			<2	<2	<2
Potassium	μg/L			1600	1500	1700
Selenium	μg/L	50	10	<1	<1	<1
Silver	μg/L			< 0.1	< 0.1	< 0.1
Sodium	μg/L	\leq 200,000	200,000	17300	15600	17700
Strontium	μg/L	,	,	633	583	521
Thallium	μg/L			< 0.1	< 0.1	< 0.1
Tin	μg/L			<2	<2	<2
Titanium	μg/L			<2	<2	<2
Uranium	μg/L	20	20	2.3	2.2	2.1
Vanadium	μg/L			4	4	4
Zinc	μg/L	≤5000		8	9	<5
Microbiology				•	•	
	/IPN/100 mL	Absent	Absent	Absent	<1	<1
	/IPN/100 mL	Absent	Absent	Absent	<1	<1
"Bold" exceeds applical				•	•	·]

Table 4: PW1 Groundwater Quality

5.0 DISCUSSION

5.1 Neighbouring Water Users

Based on the results of the hydraulic testing, the radius of influence for PW1 extends approximately 230 metres when the production well is operating at a rate of 131 m³/day (20 Igpm) (refer to Figure 8). OW1 is located at a distance of 216 m from PW1. Approximately 0.29 m of drawdown was observed in OW1 during the pumping test. The closest neighbouring residential well (PID 70063144) is located approximately 130 metres east of PW1 and eight (8) private wells are located on neighbouring properties within 230 metres of PW1. Based on the Distance-Drawdown plot (see Figure 8), 2 m of drawdown is estimated at a distance of 130 metres from the pumping well. Note that the drawdown also includes interferences from tidal effects. Throughout the pumping test and recovery period, no residents in the area contacted the proponent or Roy Consultants' personnel with complaints regarding water quality or quantity. Surrounding land use within 500 m of the campground is residential (primarily seasonal cottages). No potentially adverse impacts on the groundwater supply are anticipated due to current or historical land uses.




Figure 8: Distance-drawdown Data from the 72-hour Constant Rate Pump Test

At the recommended pumping rate of 20 Igpm for a maximum of 14 hours per day, the maximum drawdown at PW1 is approximately 3.78 m based on the pump test data. Operating at 20 Igpm for a continuous 14-hour period will slightly reduce the radius of influence to 220 metres (refer to Figure 9). The corresponding drawdown in the nearest neighbouring well (130 m away) is approximately 2 m. However, upon further review of the pump test data, water level drawdown (0.10 metre) in OW1 did not occur until after 10 hours of continuous pumping at 20 Igpm. It should be noted that PW1 would be operated on a cycle basis and would not pump continuously throughout the day while the campground is operating. As a result, the radius of influence is expected to be less than 220 metres and the corresponding drawdown of 2 metres in the nearest neighbouring well is also expected to be less. The operation of the production well is expected to have minimal interference with neighbouring water users. Based on the above, it is

recommended that PW1 be pumped at a rate not to exceed 20 Igpm (131 m^3/day) for a maximum of 14 hours per day.




Figure 9: Distance-drawdown Data after 14 Hours of Continuous Pumping at 20 Igpm

5.2 Potential for Saltwater Intrusion

The production well is located approximately 75 metres from the Northumberland Strait. A review of water quality data during the pump test was completed to assess any observable trends in certain parameters that may indicate saltwater intrusion. According to Drever (1988), the parameters listed in Table 5 are some of the major elements that comprise sea water. Parameters listed in Table 5 are listed in order from most concentrated to least concentrated in seawater. For example, chloride is the parameter with the highest concentration in seawater and strontium has a lower concentration. Concentrations for major solutes (chloride and sodium) remained relatively constant throughout the pump test. The water quality observed during the pumping test does not suggest that saltwater intrusion into the aquifer is occurring. It should be also be noted that PW1 has been supplying the campground since 2012 with no reported water quality issues.

Table 5. 1 W1 Water Quarty Results – 1 arameter's Associated with Saitwater							
Parameter	PW1 (24 h)	PW1 (48 h)	PW1 (69 h)				
Chloride (mg/L)	24	24	25				
Sodium (mg/L)	17.3	15.6	17.7				
Sulfate (mg/L)	7	7	7				
Magnesium (mg/L)	3.9	3.6	4.1				
Calcium (mg/L)	44.7	42.8	43.7				
Potassium (mg/L)	1.6	1.5	1.7				
Bicarbonate (mg/L)	117	118	118				
Strontium (µg/L)	633	583	521				
Boron (µg/L)	34	32	28				
r-Silica (mg/L)	10.8	9.0	11.7				

 Table 5: PW1 Water Quality Results – Parameters Associated with Saltwater

WATER SUPPLY SOURCE ASSESSMENT Little Shemogue, NB

As pumping well PW1 is located within 500 m of a saltwater source (Northumberland Strait), an evaluation of the potential for saltwater intrusion was undertaken. A review of available literature was completed. Rivard et al. (2008) completed a regional hydrogeological characterization of the south-central part of the Maritimes Basin which included a geophysical survey along Cap Brûlé Road near Shediac, NB, which is located approximately 40 km west of the campground. This area is underlain by the same geological formation (Richibucto Formation) as the campground. The survey did not detect any zones of very low resistivity, suggesting that saline water does not occur within 40 m of the surface. From the 72-hour pump test, it was determined that PW1 is situated in a confined aquifer and the maximum drawdown observed during the pump test was 4.69 m. If we use 40 m as the distance from surface to the top of the fresh water/salt water interface (to be conservative), operating the well at 20 Igpm will result in a maximum drawdown of 4.69 m, correlating to a distance of 31.75 m above the fresh water/salt water interface. Therefore, operating the well at a pumping rate of 20 Igpm will not result in a drawdown that will induce saltwater intrusion.

5.3 Groundwater under the Direct Influence off Surface Water (GUDI)

An evaluation was completed for the potential influence of surface water on the groundwater source. Groundwater is considered under the direct influence of surface water if there is:

- a direct hydraulic connection to the surface or surface water by way of local geology or well construction; and/or
- Significant and relative rapid shifts in water characteristics such as temperature, turbidity, conductivity and pH which closely correlate with climatological events; and/or
- Significant occurrence of micro-organisms.

The closest surface water body to the production well is the Northumberland Strait located approximately 75 m north of the well. The nearest freshwater surface water bodies are watercourses: Trout Brook (1.05 km west of the campground) and Scott Brook (1.2 km east). The area surrounding the well head consists of developed RV lots with gravel pads and grass cover and gravel access roads. No standing water is present near the well house. The construction of PW1 includes 10.97 m (36 feet) of steel casing and the well is drilled to a depth of 32 m. The local geology consists of interbedded layers of shale and sandstone bedrock. The well draws its water from a confined sandstone bedrock aquifer with major water-bearing fractures noted at depths of 18.3 m (15 Igpm), 24.38 m (10 Igpm) and 27.7 m (10 Igpm).

According to Environment Canada's daily climate data from the Moncton International Airport, there were 38.4 mm of precipitation during the 14 days preceding the pump test. An estimated 46.6 mm of precipitation were noted during the pump test from November 19 to 22, 2017. An estimated 5.8 mm of precipitation were noted during the recovery period on November 23, 2017. Water level data in PW1 and OW1 do not show a spike in water levels associated with the rainfall events. Water level fluctuations are attributed to tidal effects. Considering both wells have over 10 m (30 feet) of casing each, any surface recharge to the wells during the pump test is considered minimal. Further, temperature readings measured throughout the test by the dataloggers do not show any fluctuations. Refer to Appendix F for the Environment Canada Daily Data Report for November 2017 and Appendix D for temperature readings.

A review of raw groundwater quality data collected from PW1 at 24 hours, 48 hours and 69 hours into the pump test does not indicate any significant changes in turbidity, conductivity and pH. Reported levels for all parameters were consistent for all three sampling events. Refer to Section 4.2.5 for further discussion. No detection of microbiological parameters (total coliforms and E. coli) was reported for all three sampling events. Further, water quality sampling was previously

completed in May 2017 for PW1 and no detection of total coliforms or E. coli were reported. Refer to Appendix E for laboratory certificates.

PW1 is a deep well drawing groundwater from a confined aquifer. The well is located more than 60 m from the nearest freshwater surface water body. The well casing extends more than 6 m and has an appropriate sized drive shoe. Water quality data collected throughout the duration of the pump test indicates no detection of total coliforms or E. coli bacteria and other indicator parameters (pH, turbidity, conductivity and temperature) do not show any obvious signs of surface water influence. Based on the above, groundwater supplying PW1 is not considered under the influence of surface water.

6.0 CONCLUSIONS AND RECOMMENDATIONS

Roy Consultants supervised the 72-hour constant rate test for PW1 completed in November 2017. The objective of the pump test was to determine the maximum sustainable yield of the water supply for the Strang's Shore Campground. To accommodate the existing and future lots (a total of 150 lots), the estimated water demand is approximately 10 Igpm (68 m³/day).

PW1 was pumped at a rate of 20 Igpm (131 m³/day) and a maximum observed drawdown of 4.69 m was noted. The calculated transmissivities of the aquifer from the recovery portion of the pump test range from 19.96 m²/d to 34.22 m²/d. Following the end of the pumping test, water levels in PW1 recovered 100 % within 26 hours after the pump was shut off.

Groundwater results for general chemistry, trace metals and microbiological analyses from the pumping well indicate turbidity and manganese exceedances of CDWQ and NB Drinking Water guidelines. The turbidity level was slightly above the CDWQ and NB guidelines in the middle of the test, but was below guidelines towards the beginning and end of the pump test. Turbidity levels typically decrease over time with continued well use. The manganese concentration exceeded the CDWQ guideline towards the beginning of the test, but decreased to below the guideline for the remainder of the test. Both parameters are attributed to sediment content in the well and should decrease over time with continued well use. Based on the water quality results observed throughout the pump test, there is no indication that saltwater intrusion is occurring.

Based on the results of the pump test, a pumping rate of 20 Igpm (131 m^3 /day) operating for a maximum of 14 hours per day is recommended for PW1. Pumping at 20 Igpm for 14 hours per day equates to a maximum daily withdrawal of 76.4 m^3 /day which meets the future estimated water demand of 68 m^3 /day. It is also recommended that a flow meter be installed and water usage recorded over an operating season (May to October) to determine actual water consumption. Water quality samples should also be collected on a monthly basis (at a minimum) and analyzed for conductivity to monitor for possible saltwater intrusion.

7.0 CLOSURE

This report was prepared by Roy Consultants for the exclusive use of Strang's Shore Seasonal Camping Inc. The data contained herein may not be used by any other person or entity without the express written consent of Roy Consultants and Strang's Shore Seasonal Camping Inc. While this report provides an overview of environmental conditions, the assessment is limited by the availability of information at the time of the study. Field work was carried out by Mr. Abram Lee, EIT, and Ms. Gina Burtt, P.Eng., P.Geo. Reporting was carried out by Ms. Gina Burtt, P.Eng., P.Geo.

8.0 **REFERENCES**

British Columbia Ministry of Environment, Lands and Parks. 1999. Evaluating long-term well capacity for a certificate of public convenience and necessity: a guidance document. Water Management Branch, Groundwater Section. ISBN 0-7726-4019-X.

Drever, J.I. 1988. The Geochemistry of Natural Waters. Second Edition Prentice Hall, Englewood Cliffs, New Jersey 07632, USA, pp.1-437.

Driscoll, F.G. 1986. Groundwater and Wells. Second Edition Johnson Division, St. Paul Minnesota 55112, USA, pp. 1-1089.

Freeze, R.A. and Cherry, J.A. 1979. Groundwater. Prentice-Hall, Inc., Englewood Cliffs, N.J. 07632, USA, pp. 1-604.

Government of Canada. 2017. The Atlas of Canada. Toporama, version 2.3. <u>http://atlas.gc.ca/toporama/en/index.html</u>.

Health Canada. 2017. Guidelines for Canadian Drinking Water Quality Summary Table. Federal-Provincial-Territorial Committee on Drinking Water of the Federal-Provincial-Territorial Committee on Health and the Environment.

New Brunswick Department of Environment and Local Government. 2017. Environmental Impact Assessment Water Supply Source Assessment Guidelines.

Rampton, V. N. 1984. Generalized surficial geology map of New Brunswick Department of Natural Resources and Energy. Mineral, Policy and Planning Division. NR-8 (scale 1: 500 000).

Rivard, C., Michaud, Y., Deblonde, C., Boisvert, V., Carrier, C., Morin, R.H., Calvert, T., Vigneault, H., Conohan, D., Castonguay, S., Lefebvre, R., Rivera, A., and Parent, M. 2008. Canadian Groundwater Inventory: Regional hydrogeological characterization of the south central part of the Maritimes Basin; Geological Survey of Canada. Bulletin 589, 96 p.

Service New Brunswick. NBGIC Parcel Data, 2017. Real Property Information PID numbers 00837088, 70188826 and 70563457. New Brunswick. Canada.

Smith, E.A. (compiler). 2007. Bedrock geology of the Cape Tormentine area (NTS 11L/04), Westmorland County, New Brunswick. New Brunswick Department of Natural Resources, Minerals, Policy and Planning Division, Plate 2007-46. Scale 1:50,000.

APPENDICES

APPENDIX A: Figures

APPENDIX B: SNB Documentation

APPENDIX C: Well Driller's Reports

APPENDIX D: Pumping Test Data for Pumping Wells and Observation Well

APPENDIX E: Laboratory Certificates

APPENDIX F: Environment Canada Daily Data Report and Tide Tables

APPENDIX G: NBDELG Documentation

APPENDIX A

Figures

APPENDIX B

SNB Documentation

APPENDIX C

Well Driller's Reports

APPENDIX D

Pumping Test Data for Pumping Wells and Observation Well

APPENDIX E

Laboratory Certificates

APPENDIX F

Environment Canada Daily Data Report and Tide Tables

APPENDIX G

NBDELG Documentation

WATER SUPPLY SOURCE ASSESSMENT Strang's Shore Seasonal Camping Inc. 1639 Route 955 Little Shemogue, (Murray Corner), NB PID No. 00837088

> Our File No.: 278-17 January, 2018

Prepared for:

Jerry and Linda Strang 89 Moore Road Ext. Otter Creek, NB E4M 3V5

Prepared by:





T. : 506 472-9838 = F. : 506 472-9255

364, rue York Street, Suite 201 Fredericton (NB) E3B 3P7 www.royconsultants.ca

January 19, 2018

Jerry and Linda Strang Strang's Shore Seasonal Camping Inc. 89 Moore Road Ext. Otter Creek, NB E4M 3V5

Our File No.: 278-17-C¹

Mr. and Mrs. Strang:

Subject: Water Supply Source Assessment Strang's Shore Seasonal Camping Inc. 1639 Route 955 Little Shemogue (Murray Corner), NB PID No. 00837088

We are pleased to present you with the water supply source assessment for Strang's Shore Seasonal Camping Inc. in Little Shemogue (Murray Corner), New Brunswick.

The assessment has determined that there is an adequate supply of water to support the existing campground facility and the proposed future expansion. It is recommended that production well PW1 be operated at a rate not to exceed 20 Igpm (131 m^3/day) for a maximum of 14 hours per day and a flow meter be installed on the well to monitor actual water consumption. Water quality samples should be collected on a monthly basis (at a minimum) and analyzed for conductivity to monitor for possible saltwater intrusion.

Should you have any questions regarding this report, please do not hesitate to contact the undersigned.

Yours truly,

Gina Butt

Gina Burtt, M.Sc., P.Eng. P.Geo. ENVIRONMENTAL Engineer

GB/jb/sl Enc.

¹ 278-17 Pump Test Report Jan 2018.doc

TABLE OF CONTENTS

i) Letter of Introduction

ii)	Table o	f Contents
-----	---------	------------

1.0	INTRODUCTION	1
1.	Project Description	1
2.0	EXISTING SITE CONDITIONS	2
2	~r	2
2. 2.		
3.0	HYDROGEOLOGICAL CONDITIONS	4
3	- · · · · · · · · · · · · · · · · · · ·	
3.		
4.0	HYDRAULIC TESTING	
4.	~···F	
4.	/2 noti i unping i com	
	4.2.1 Pumping Test Analysis 1 4.2.2 Recommended Sustainable Yield (PW1) 1	
	4.2.5 Groundwater Quality	
5.0	DISCUSSION1	5
5.	Neighbouring Water Users1	5
5.		
5.	Groundwater under the Direct Influence of Surface Water (GUDI)1	7
6.0	CONCLUSIONS AND RECOMMENDATIONS1	9
7.0	CLOSURE2	0
8.0	REFERENCES2	1

APPENDICES

APPENDIX A: Figures
APPENDIX B: SNB Documentation
APPENDIX C: Well Driller's Reports
APPENDIX D: Pumping Test Data for Pumping Well and Observation Well
APPENDIX E: Laboratory Certificates
APPENDIX F: Environment Canada Daily Data Report and Tide Tables
APPENDIX G: NBDELG Documentation

1.0 INTRODUCTION

Jerry and Linda Strang, on behalf of Strang's Shore Seasonal Camping Inc., retained the services of Roy Consultants to complete a water supply source assessment for the existing campground in Little Shemogue (Murray Corner), New Brunswick (PID Nos. 00837088, 70188826 and 70563457), herein referred to as the "subject property". Refer to Figure 1 in Appendix A for the site location plan.

This report has been prepared in accordance with the New Brunswick Department of Environment and Local Government's (NBDELG) Environmental Impact Assessment *Water Supply Source Assessment Guidelines* (April 2017). These guidelines are used to assist proponents engaging in projects that require a Water Supply Source Assessment (WSSA) through the Environmental Impact Assessment (EIA) process. A WSSA includes, but is not limited to, an evaluation of the sustainability of the water supply, an assessment of water quality, an evaluation of potential impacts to existing water users and an assessment of the potential for saltwater intrusion. The WSSA guidelines are enclosed in Appendix G.

1.1 **Project Description**

Strang's Shore Seasonal Camping Inc. (hereinafter "the proponent") currently operates a campground with 115 serviced lots at 1639 Route 955, Little Shemogue (Murray Corner), New Brunswick (Westmorland County). The campground began operating in 2012 and includes three parcels of land identified by Service New Brunswick as PID Nos. 00837088, 70188826 and 70563457. For a campground with water and sewer hook-ups, the NBDELG recommends 450 L per space per day for water usage. The estimated current water demand is $52 \text{ m}^3/\text{day}$. The campground will expand in the future for a total of 150 serviced lots with an approximate water demand of $68 \text{ m}^3/\text{day}$. Currently, the actual water usage is unknown. As limited information is available on current water usage, the objective of the water supply source assessment is to complete a pump test on the existing production well to determine its recommended safe yield.

2.0 EXISTING SITE CONDITIONS

2.1 Site Description

The campground is located in a rural area surrounded by cottage/residential buildings. The subject property, identified by the Service New Brunswick (SNB) parcel identification (PID) number 00837088, is zoned "rural zone" according to the Tantramar Rural Zoning Map Schedule A. Development in the area includes residences and/or cottages to the east, south and west and the Northumberland Strait borders the northern property line. Refer to Figure 1 in Appendix A.

The pumping well (PW1) is located on PID No. 00837088, which covers an area of 3.43 hectares. The observation well (OW1) is located on PID No. 70188826, which has an area of 1.13 hectares. No wells are located on the third parcel of land comprising the campground, PID No. 70563457, which has an area of 3.27 ha. SNB documentation is enclosed in Appendix B. The nearest neighbouring domestic well is located approximately 130 metres east and cross gradient of PW1, along Highway 955 (PID No. 70063144).



Photos 1 and 2: Photo at left shows the well house (looking northeast). Photo at right shows production well PW1 located inside the well house (July 5, 2017).



Photo 3: View of observation well OW1 looking south towards Highway 955 (October 16, 2017)

2.2 Current Groundwater Use

There are two (2) existing on-site potable wells (PW1 and OW1); however, only PW1 services the campground. The wells are located approximately 216 m from each other. PW1 is equipped with a Pentek® 2 horsepower submersible pump with a capacity of 25 USgpm (21 Igpm). OW1 is not hooked up to the water supply system. This well is a remnant from a mobile home that previously occupied PID No. 70188826 prior to that land parcel's purchase by Strang's Shore Seasonal Camping Inc.

2.3 Well Construction

PW1 was constructed on August 2, 2010 (Well ID 24773). The well is 150 mm (6 inches) in diameter and completed to a depth of 32 metres (105 feet). Based on the well driller's report, the predominant bedrock is comprised of alternating layers of grey sandstone and red shale. Depth to the bedrock level is 6.4 metres below ground surface (bgs). OW1 was constructed on August 13, 2014 (Well ID 30194). The well is 150 mm (6 inches) in diameter and completed to a depth of 19.8 metres (65 feet). OW1 was deepened to a depth of 32 metres (105 feet) on October 16, 2017 by Charlie Herman Chappell Well Drilling, out of Colpitts Settlement, NB. All well locations are shown on Figure 1 in Appendix A. The well driller reports for PW1 and OW1 are enclosed in Appendix C.

Well ID	GPS Coordinates		Date Drilled	Well Depth	Casing Depth	Driller's Estimated	Static Water
	Northing	Easting		(btoc) (m)	(btoc) (m)	Safe Yield (Igpm)	Level (btoc) (m)
PW1	7467524.674	2695018.638	August 2010	32	10.97	20	4.13*
OW1	7467310.055	2694998.413	August 2014	32	12.19	35	3.465*

Table 1: Summary of On-site Potable Well Information

(*) as measured on November 19, 2017

3.0 HYDROGEOLOGICAL CONDITIONS

3.1 Topography and Drainage

The subject property is located within the New Brunswick Lowlands physiographic unit. Based on the well elevation survey completed by Roy Consultants in November 2017, the ground surface elevations noted at PW1 and OW1 were 6.74 m and 7.7 m above mean sea level, respectively. The property was noted to gently slope north towards the Northumberland Strait. Surface water drainage across the subject property is northerly via overland flow. No drainage ditches were noted on the subject site. Drainage is good, evidenced by no mapped wetlands on the subject site. Standing water and wet areas were not observed during field work completed in November 2017. The area to the south, which could potentially contribute groundwater to the study area, is a mix of developed residential and vacant/wooded lots.

3.2 Geology

The surficial geology for the area consists of Late Wisconsinan morainal sediments blanket deposits consisting of loamy lodgment till, minor ablation till, silt, sand, gravel and rubble generally 0.5 m to 3 m thick (Rampton, 1984). According to the well driller's log for PW1, the underlying site stratigraphy (from top to bottom) consists of clay and sand at depths from 0 to 6.4 metres bgs and sand present from 6.4 m to 9.1 metres bgs.

The bedrock underlying the subject property is comprised of Late Carboniferous-aged sedimentary rocks comprised of the Pictou Group, Richibucto Formation consisting of grey and brownish red, commonly micaceous lithic and arkosic sandstone, pebbly sandstone and intraformational mudstone-clast conglomerate, brownish red to brick-red and lesser grey siltstone and mudstone, minor intraformational limestone-cobble conglomerate and thin laterally extensive limestone beds and minor thin coal seams (Smith, 2007). According to the well driller's log for PW1, grey sandstone was encountered at a depth of 12.5 metres bgs. Refer to Appendix C for the well driller's report.

3.3 Hydrogeology

Based on a review of seven (7) water well logs within 500 metres of the subject property (PID 00837088), the local aquifer is comprised of a fractured sandstone bedrock aquifer. According to well drillers' reports, several major water-bearing fractures are noted at depths of approximately 17 m, 25 m and 29 m. Well depths range between 19.8 m and 73.5 m and well yields range from 3 Igpm to 25 Igpm (19.6 m³/day to 163.6 m³/day). Most well logs indicate a confined aquifer scenario of sandstone bedrock interbedded with layers of shale. Refer to well driller's reports in Appendix C for further details.

The subject property is located immediately adjacent to the Northumberland Strait, which is under tidal influence. Water levels in the area are expected to be influenced to some degree by high and low tides. Potential recharge sources to the wells on the subject site include direct infiltration from precipitation and groundwater flow from upland areas.

4

4.0 HYDRAULIC TESTING

Hydraulic testing was completed at PW1 from November 19 to November 22, 2017. A 72-hour constant rate pumping test was completed in accordance with NBDELG's WSSA guidelines. During the test, groundwater from PW1 was contained and discharged through approximately 75 m of 4-inch diameter PVC pipe into the Northumberland Strait. Refer to Photos 4 and 5. The site topography slopes northward, away from the pumping well, towards the Northumberland Strait. The discharge location of the pumped water did not allow artificial recharge to PW1 and OW1.



Photo 4: View of water discharge line directing pumped water towards the Northumberland Strait (November 19, 2017).



Photo 5: View of water discharge (November 19, 2017)

4.1 Step Test

Prior to commencement of the 72-hour continuous pumping test, a step test was conducted to determine the optimal pumping rates for the long-term test at PW1. The existing pump in PW1 was pulled prior to the test and a 5-horsepower pump was installed by Charlie Herman Chappell Well Drilling. Installation of a larger pump allowed for higher pump rate at which to step test the well. The pump was installed at a depth of 27.4 m (90 feet). Step test intervals were 30 minutes in length, each having a higher pumping rate than the previous interval. Three steps were completed at 10 Igpm, 20 Igpm and 30 Igpm, respectively. Pumping rates were verified by the driller using a 20-gallon bucket and stopwatch. Water levels were allowed to recover following completion of each step. Leveloggers were installed in both the pumping and observation wells to recover water levels in addition to collecting manual water measurements. Drawdown and recovery data for PW1 throughout the step test are shown in Figure 1.




Figure 1: Step Test Data PW1 – Drawdown vs Time

At the beginning of the step test, the static water level in PW1 was 3.56 m bgs. During the first step, at a pumping rate of 10 Igpm, drawdown stabilized at approximately 4.52 m bgs. During the second step, at a pumping rate of 20 Igpm, the pumping water level stabilized at approximately 5.61 m. At the end of the third step, at a pumping rate of 30 Igpm, the pumping water level was 7.08 m bgs and did not appear to have stabilized. The maximum drawdown observed in OW1 during the pumping portion of the step test was 0.029 m (water level of 2.924 m bgs). The water level recovery in PW1 was 94 % recovery after 30 minutes of the end of the last step. Based on the results of the step test, a pumping rate of 20 Igpm (131 m³/day) was selected for PW1 for the constant rate test. All step test data and plots are enclosed in Appendix D.

4.2 72-hour Pumping Test

The 72-hour constant rate test was started at 2:30 p.m. on November 19, 2017, and the pump was shut off at 2:30 p.m. on November 22, 2017. The average flow rate measured over the duration of the test was 20 Igpm (131 m³/day) from PW1. The flow rate was monitored regularly throughout the duration of the pump test by the driller using a 20-gallon bucket and stopwatch.


Results from the pumping well and observation well during the 72-hour pumping test are presented in Table 2. Water level data are shown in Figure 2 and drawdown data is presented in Figure 3. Refer to the pumping test data and graphs in Appendix D for further details.

Well ID	Well Type	Distance from Pumped Well (m)	Ground Surface Elevation (m)	Static Water Elevation (m)	Maximum Observed Drawdown (m)	Time of Maximum Observed Drawdown (Hour into Pumping Test)
PW1	Pumping	N/A	6.74	3.563 (bgs) 3.177 (amsl)	4.69	67
OW1	Observation	216	7.70	2.895 (bgs) 4.805 (amsl)	0.29	66

Table 2. Summary of 72-hour Constant Rate Test Data

bgs = below ground surface

amsl = above mean sea level





WATER SUPPLY SOURCE ASSESSMENT Little Shemogue, NB

The water level in PW1 appeared to stabilize over the duration of the pumping test. However, fluctuations in drawdown were noted which are attributed to pumping rate adjustments made by the driller and tidal effect. The pumping rate had to be adjusted after 37 hours of pumping (2220 minutes), 44 hours (2640 minutes), 50 hours (3000 minutes), 52 hours (3120 minutes) and 63 hours (3780 minutes).




Figure 3: 72-hour Constant Rate Test Drawdown Data

The maximum drawdown in PW1 was 4.69 m, which corresponds to a pumping water level of approximately 1.51 m below sea level (bsl). The maximum drawdown observed in OW1 was 0.29 m, which corresponds to a water level of 4.515 m above sea level (asl). Water levels in OW1 remained above sea level throughout the duration of the pumping test.

Some minor fluctuations in water levels are noted in the drawdown data for both wells and are attributed to tidal effects. Fluctuations correlate with the tide schedules for Cape Tormentine. Based on the drawdown data, drawdowns of approximately 0.17 m in PW1 and 0.02 m in OW1 are attributed to tidal influence during the pumping test. Refer to Appendix F for tide tables.

Following completion of the pumping test, recovery in both wells was very good. In PW1, water levels recovered 71 %, 92 % and 100 % within 1 hour, 10 hours and 26 hours, respectively, of shutting off the pump. In OW1, 100 % water level recovery was noted within 23 hours of shutting off the pump (at 4320 minutes). Refer to Figure 4 for drawdown and recovery data for both wells.




Figure 4: Drawdown and Recovery Data – All Wells

Water levels recovered 100 % in PW1 within 26 hours of the end of the pump test. In OW1, 100 % water level recovery was achieved within 23 hours of shutting off the pump. It was noted during the recovery period that water levels in PW1 and OW1 fluctuated due to tidal effects. Fluctuations were more pronounced in PW1 and water levels fluctuated between 0.09 m and 0.45 m due to tidal effects. Refer to Figures 5 and 6 for recovery data. From Figure 5, it appears that residual drawdown reaches '0' near t/t'=2, indicating complete recovery, although interpretation is made difficult due to fluctuations in residual drawdowns, which are attributed to tidal effects.





Figure 5: Residual Drawdown Recovery Data – All Wells





4.2.1 Pumping Test Analysis

After completion of the 72-hour pumping test, transmissivity was calculated from the drawdown and recovery data from pumping well PW1 using the Cooper-Jacob straight line method. The log time versus drawdown plots are shown in Appendix D. The calculated transmissivities for PW1 are shown in Table 3.

Well No.	Draw	down	Recovery		
	Transmissivity (minimum) m²/day	Transmissivity (maximum) m²/day	Transmissivity (minimum) m²/day	Transmissivity (maximum) m²/day	
PW1	23.2	30.9	19.96	34.22	

 Table 3: Transmissivity Values

Transmissivities calculated based on the recovery data are considered more representative of the aquifer than data collected under pumping conditions. Based on the distance-drawdown plot, the maximum radius of influence extends approximately 230 metres from PW1. Refer to Figures 6 and 7 in Section 5.1 for the distance-drawdown data.

The specific capacity calculated for PW1 during the pumping test was 24.23 m³/day/m. A storativity value of 0.0014 was calculated using time drawdown data obtained from OW1. According to Driscoll (1986), the coefficient of storage for confined aquifers ranges from 10^{-5} to 10^{-3} , and from 0.01 to 0.3 for unconfined aquifers. The calculated storativity value is reflective of a confined aquifer.

4.2.2 Recommended Sustainable Yield (PW1)


PW1's specific capacity after 100 days of pumping was calculated using the pumping rate of 20 Igpm (131 m³/day) and extrapolating the drawdown at 100 days from the Time vs. Drawdown graph. The drawdown at 100 days is 5.4 m and the pumping well's specific capacity is 24.23 m³/d/m. The total available drawdown in the well is calculated using the depth from the static water level (3.56 m bgs) to mean sea level (6.74 m bgs). Based on available site information, the total available drawdown in the well is 3.2 m (to mean sea level). The long-term sustainable yield (Q) is calculated based on the following formula:

 $Q=Specific Capacity at 100 days x available drawdown in the well <math display="inline">Q=24.23\ m^3/day/m$ x 3.2 m $Q=78\ m^3/day$ or 12 Igpm

PW1, operating at a continuous rate of 78 m³/day (12 Igpm) over a 24-hour period, corresponds to the same water withdrawal as operating at a pumping rate of 20 Igpm for a maximum of 14 hours per day. Based on the pump test, pumping PW1 at a rate of 131 m³/day (20 Igpm) resulted in a drawdown of 3.78 m after 14 hours of continuous pumping which corresponds to a pumping water level below sea level (refer to Figure 7). However, it should be noted that the casing in PW1 extends below sea level and the drawdown is likely more pronounced due to the casing length. It is likely that the well construction of PW1 has more influence on the pumping water level than does the actual pumping rate. The potential for saltwater intrusion into PW1 is considered unlikely at a pumping rate of 20 Igpm based on the assessment outlined in Section 5.2.

WATER SUPPLY SOURCE ASSESSMENT Little Shemogue, NB

It should be noted that PW1 would be operated on a cycle basis and would not pump continuously throughout the day while the campground is operating. It should also be noted that the campground operates from May to October and water withdrawal would be restricted to this time period. Based on the above, it is recommended that PW1 be pumped at a rate not to exceed 20 Igpm (131 m³/day) for a maximum of 14 hours per day, which equates to a daily maximum water withdrawal of 76.4 m³/day.



4.2.5 Groundwater Quality

Groundwater samples were collected from the pumping well (PW1) towards the beginning (24 hours), middle (48 hours) and near the end (69 hours) of the pump test. All samples were submitted to AGAT Laboratories in Dartmouth, Nova Scotia, for general chemistry, trace metals and microbiological analyses. Laboratory certificates are enclosed in Appendix E.

General chemistry and trace metals results for the samples collected at the beginning and end of the pump test are all within the *Canadian Drinking Water Quality Guidelines* (CDWQ) and *New Brunswick Drinking Water Guidelines* (NB) potable guideline values with the exception of turbidity and manganese. The turbidity value of 1.3 NTU (48 hours) slightly exceeds the CDWQ guideline range of 0.1 to 1.0 NTU and the NB guideline of 1.0 NTU. It should be noted that turbidity values in PW1 were below guidelines at 24 hours and 69 hours into the pump test. The levels of turbidity in the well may be related to sediment dislodged during removal of the pump and installation of the driller's pump for completion of the pump test. Furthermore, an iron build-up was noted on the casing and discoloured the water level tape used to collect manual readings throughout the test. The friction of the tape against the casing may also have contributed to

sediments in the well water. The reported turbidity levels are not considered a concern for human health and turbidity levels should decrease over time with continued well use.

Manganese in PW1 exceeded the CDWQ guideline of less than or equal to $50 \ \mu g/L$ towards the beginning of the test (24 hours) and decreased to below the CDWQ guideline for the remainder of the pump test (48 hours and 69 hours). It is likely that elevated manganese was associated with sediment content present in the well at the start of the test. With further pumping, manganese concentrations decreased to within the acceptable guideline.

Microbiological results for the samples collected towards the beginning, middle and end of the pump test indicate no counts for total coliforms or *E.coli*. All results meet the CDWQ and NB guideline values of 0 MPN/100 ml for both total coliforms and *E.coli*. Following completion of the pumping test, the water quality in the pumping well meets potable guidelines. Water quality results for PW1 are shown in Table 4.

Parameter	Units	CDWQ	NB	24 h	48 h	69 h
General Chemistry						
Ammonia (as N)	mg/L			0.03	0.05	< 0.03
pH	units	7.0-10.5		8.01	7.96	8.09
Alkalinity (as CaCO3)	mg/L			117	118	118
Chloride	mg/L	≤ 250	250	24	24	25
Colour	TCU	15		6	5	14
Fluoride	mg/L		1.5	< 0.12	< 0.12	< 0.12
Sulfate	mg/L	\leq 500	500	7	7	7
Nitrate (as N)	mg/L	45	45	1.88	2.03	1.91
Nitrite (as N)	mg/L	3		< 0.05	< 0.05	< 0.05
o-Phosphate (as P)	mg/L			< 0.01	< 0.01	< 0.01
Phosphorus	mg/L			< 0.02	< 0.02	< 0.02
r-Silica (as SiO2)	mg/L			10.8	9.0	11.7
Total Organic Carbon	mg/L			< 0.5	< 0.5	< 0.5
Turbidity	NTU	0.1-1.0	1.0	0.5	1.3	0.8
Conductivity	μS/cm			332	322	332
Total Dissolved Solids	mg/L	\leq 500		177	174	178
Trace Metals	8					
Aluminum	μg/L	<100		<5	11	<5
Antimony	μg/L	6	6	<2	<2	<2
Arsenic	μg/L	10	10	<2	<2	<2
Barium	μg/L	1000	1000	431	421	413
Beryllium	μg/L			<2	<2	<2
Bismuth	μg/L			<2	<2	<2
Boron	μg/L	5000	5000	34	32	28
Cadmium	μg/L	5	5	< 0.017	< 0.017	< 0.017
Calcium	μg/L			44700	42800	43700
Chromium	μg/L	50	50	3	3	<1
Cobalt	μg/L			<1	<1	<1
Copper	μg/L	≤1000	1000	<2	<2	<2
Iron	μg/L	≤ 300	300	<50	<50	<50
Lead	μg/L	10	10	< 0.5	< 0.5	< 0.5
Magnesium	μg/L			3900	3600	4100
Manganese	μg/L	\leq 50		72	22	21
Molybdenum	μg/L			<2	<2	<2
Nickel	μg/L			<2	<2	<2
Potassium	μg/L			1600	1500	1700
Selenium	μg/L	50	10	<1	<1	<1
Silver	μg/L			< 0.1	< 0.1	< 0.1
Sodium	μg/L	\leq 200,000	200,000	17300	15600	17700
Strontium	μg/L	,	,	633	583	521
Thallium	μg/L			< 0.1	< 0.1	< 0.1
Tin	μg/L			<2	<2	<2
Titanium	μg/L			<2	<2	<2
Uranium	μg/L	20	20	2.3	2.2	2.1
Vanadium	μg/L			4	4	4
Zinc	μg/L	≤5000		8	9	<5
Microbiology						·
	/IPN/100 mL	Absent	Absent	Absent	<1	<1
	/IPN/100 mL	Absent	Absent	Absent	<1	<1
"Bold" exceeds applical				•	•	·]

Table 4: PW1 Groundwater Quality

5.0 DISCUSSION

5.1 Neighbouring Water Users

Based on the results of the hydraulic testing, the radius of influence for PW1 extends approximately 230 metres when the production well is operating at a rate of 131 m³/day (20 Igpm) (refer to Figure 8). OW1 is located at a distance of 216 m from PW1. Approximately 0.29 m of drawdown was observed in OW1 during the pumping test. The closest neighbouring residential well (PID 70063144) is located approximately 130 metres east of PW1 and eight (8) private wells are located on neighbouring properties within 230 metres of PW1. Based on the Distance-Drawdown plot (see Figure 8), 2 m of drawdown is estimated at a distance of 130 metres from the pumping well. Note that the drawdown also includes interferences from tidal effects. Throughout the pumping test and recovery period, no residents in the area contacted the proponent or Roy Consultants' personnel with complaints regarding water quality or quantity. Surrounding land use within 500 m of the campground is residential (primarily seasonal cottages). No potentially adverse impacts on the groundwater supply are anticipated due to current or historical land uses.




Figure 8: Distance-drawdown Data from the 72-hour Constant Rate Pump Test

At the recommended pumping rate of 20 Igpm for a maximum of 14 hours per day, the maximum drawdown at PW1 is approximately 3.78 m based on the pump test data. Operating at 20 Igpm for a continuous 14-hour period will slightly reduce the radius of influence to 220 metres (refer to Figure 9). The corresponding drawdown in the nearest neighbouring well (130 m away) is approximately 2 m. However, upon further review of the pump test data, water level drawdown (0.10 metre) in OW1 did not occur until after 10 hours of continuous pumping at 20 Igpm. It should be noted that PW1 would be operated on a cycle basis and would not pump continuously throughout the day while the campground is operating. As a result, the radius of influence is expected to be less than 220 metres and the corresponding drawdown of 2 metres in the nearest neighbouring well is also expected to be less. The operation of the production well is expected to have minimal interference with neighbouring water users. Based on the above, it is

recommended that PW1 be pumped at a rate not to exceed 20 Igpm (131 m^3/day) for a maximum of 14 hours per day.




Figure 9: Distance-drawdown Data after 14 Hours of Continuous Pumping at 20 Igpm

5.2 Potential for Saltwater Intrusion

The production well is located approximately 75 metres from the Northumberland Strait. A review of water quality data during the pump test was completed to assess any observable trends in certain parameters that may indicate saltwater intrusion. According to Drever (1988), the parameters listed in Table 5 are some of the major elements that comprise sea water. Parameters listed in Table 5 are listed in order from most concentrated to least concentrated in seawater. For example, chloride is the parameter with the highest concentration in seawater and strontium has a lower concentration. Concentrations for major solutes (chloride and sodium) remained relatively constant throughout the pump test. The water quality observed during the pumping test does not suggest that saltwater intrusion into the aquifer is occurring. It should be also be noted that PW1 has been supplying the campground since 2012 with no reported water quality issues.

Table 5. 1 W1 Water Quanty Results – 1 arameters Associated with Saitwater									
Parameter	PW1 (24 h)	PW1 (48 h)	PW1 (69 h)						
Chloride (mg/L)	24	24	25						
Sodium (mg/L)	17.3	15.6	17.7						
Sulfate (mg/L)	7	7	7						
Magnesium (mg/L)	3.9	3.6	4.1						
Calcium (mg/L)	44.7	42.8	43.7						
Potassium (mg/L)	1.6	1.5	1.7						
Bicarbonate (mg/L)	117	118	118						
Strontium (µg/L)	633	583	521						
Boron (µg/L)	34	32	28						
r-Silica (mg/L)	10.8	9.0	11.7						

 Table 5: PW1 Water Quality Results – Parameters Associated with Saltwater

WATER SUPPLY SOURCE ASSESSMENT Little Shemogue, NB

As pumping well PW1 is located within 500 m of a saltwater source (Northumberland Strait), an evaluation of the potential for saltwater intrusion was undertaken. A review of available literature was completed. Rivard et al. (2008) completed a regional hydrogeological characterization of the south-central part of the Maritimes Basin which included a geophysical survey along Cap Brûlé Road near Shediac, NB, which is located approximately 40 km west of the campground. This area is underlain by the same geological formation (Richibucto Formation) as the campground. The survey did not detect any zones of very low resistivity, suggesting that saline water does not occur within 40 m of the surface. From the 72-hour pump test, it was determined that PW1 is situated in a confined aquifer and the maximum drawdown observed during the pump test was 4.69 m. If we use 40 m as the distance from surface to the top of the fresh water/salt water interface (to be conservative), operating the well at 20 Igpm will result in a maximum drawdown of 4.69 m, correlating to a distance of 31.75 m above the fresh water/salt water interface. Therefore, operating the well at a pumping rate of 20 Igpm will not result in a drawdown that will induce saltwater intrusion.

5.3 Groundwater under the Direct Influence off Surface Water (GUDI)

An evaluation was completed for the potential influence of surface water on the groundwater source. Groundwater is considered under the direct influence of surface water if there is:

- a direct hydraulic connection to the surface or surface water by way of local geology or well construction; and/or
- Significant and relative rapid shifts in water characteristics such as temperature, turbidity, conductivity and pH which closely correlate with climatological events; and/or
- Significant occurrence of micro-organisms.

The closest surface water body to the production well is the Northumberland Strait located approximately 75 m north of the well. The nearest freshwater surface water bodies are watercourses: Trout Brook (1.05 km west of the campground) and Scott Brook (1.2 km east). The area surrounding the well head consists of developed RV lots with gravel pads and grass cover and gravel access roads. No standing water is present near the well house. The construction of PW1 includes 10.97 m (36 feet) of steel casing and the well is drilled to a depth of 32 m. The local geology consists of interbedded layers of shale and sandstone bedrock. The well draws its water from a confined sandstone bedrock aquifer with major water-bearing fractures noted at depths of 18.3 m (15 Igpm), 24.38 m (10 Igpm) and 27.7 m (10 Igpm).

According to Environment Canada's daily climate data from the Moncton International Airport, there were 38.4 mm of precipitation during the 14 days preceding the pump test. An estimated 46.6 mm of precipitation were noted during the pump test from November 19 to 22, 2017. An estimated 5.8 mm of precipitation were noted during the recovery period on November 23, 2017. Water level data in PW1 and OW1 do not show a spike in water levels associated with the rainfall events. Water level fluctuations are attributed to tidal effects. Considering both wells have over 10 m (30 feet) of casing each, any surface recharge to the wells during the pump test is considered minimal. Further, temperature readings measured throughout the test by the dataloggers do not show any fluctuations. Refer to Appendix F for the Environment Canada Daily Data Report for November 2017 and Appendix D for temperature readings.

A review of raw groundwater quality data collected from PW1 at 24 hours, 48 hours and 69 hours into the pump test does not indicate any significant changes in turbidity, conductivity and pH. Reported levels for all parameters were consistent for all three sampling events. Refer to Section 4.2.5 for further discussion. No detection of microbiological parameters (total coliforms and E. coli) was reported for all three sampling events. Further, water quality sampling was previously

completed in May 2017 for PW1 and no detection of total coliforms or E. coli were reported. Refer to Appendix E for laboratory certificates.

PW1 is a deep well drawing groundwater from a confined aquifer. The well is located more than 60 m from the nearest freshwater surface water body. The well casing extends more than 6 m and has an appropriate sized drive shoe. Water quality data collected throughout the duration of the pump test indicates no detection of total coliforms or E. coli bacteria and other indicator parameters (pH, turbidity, conductivity and temperature) do not show any obvious signs of surface water influence. Based on the above, groundwater supplying PW1 is not considered under the influence of surface water.

6.0 CONCLUSIONS AND RECOMMENDATIONS

Roy Consultants supervised the 72-hour constant rate test for PW1 completed in November 2017. The objective of the pump test was to determine the maximum sustainable yield of the water supply for the Strang's Shore Campground. To accommodate the existing and future lots (a total of 150 lots), the estimated water demand is approximately 10 Igpm (68 m³/day).

PW1 was pumped at a rate of 20 Igpm (131 m³/day) and a maximum observed drawdown of 4.69 m was noted. The calculated transmissivities of the aquifer from the recovery portion of the pump test range from 19.96 m²/d to 34.22 m²/d. Following the end of the pumping test, water levels in PW1 recovered 100 % within 26 hours after the pump was shut off.

Groundwater results for general chemistry, trace metals and microbiological analyses from the pumping well indicate turbidity and manganese exceedances of CDWQ and NB Drinking Water guidelines. The turbidity level was slightly above the CDWQ and NB guidelines in the middle of the test, but was below guidelines towards the beginning and end of the pump test. Turbidity levels typically decrease over time with continued well use. The manganese concentration exceeded the CDWQ guideline towards the beginning of the test, but decreased to below the guideline for the remainder of the test. Both parameters are attributed to sediment content in the well and should decrease over time with continued well use. Based on the water quality results observed throughout the pump test, there is no indication that saltwater intrusion is occurring.

Based on the results of the pump test, a pumping rate of 20 Igpm (131 m^3 /day) operating for a maximum of 14 hours per day is recommended for PW1. Pumping at 20 Igpm for 14 hours per day equates to a maximum daily withdrawal of 76.4 m^3 /day which meets the future estimated water demand of 68 m^3 /day. It is also recommended that a flow meter be installed and water usage recorded over an operating season (May to October) to determine actual water consumption. Water quality samples should also be collected on a monthly basis (at a minimum) and analyzed for conductivity to monitor for possible saltwater intrusion.

7.0 CLOSURE

This report was prepared by Roy Consultants for the exclusive use of Strang's Shore Seasonal Camping Inc. The data contained herein may not be used by any other person or entity without the express written consent of Roy Consultants and Strang's Shore Seasonal Camping Inc. While this report provides an overview of environmental conditions, the assessment is limited by the availability of information at the time of the study. Field work was carried out by Mr. Abram Lee, EIT, and Ms. Gina Burtt, P.Eng., P.Geo. Reporting was carried out by Ms. Gina Burtt, P.Eng., P.Geo.

8.0 **REFERENCES**

British Columbia Ministry of Environment, Lands and Parks. 1999. Evaluating long-term well capacity for a certificate of public convenience and necessity: a guidance document. Water Management Branch, Groundwater Section. ISBN 0-7726-4019-X.

Drever, J.I. 1988. The Geochemistry of Natural Waters. Second Edition Prentice Hall, Englewood Cliffs, New Jersey 07632, USA, pp.1-437.

Driscoll, F.G. 1986. Groundwater and Wells. Second Edition Johnson Division, St. Paul Minnesota 55112, USA, pp. 1-1089.

Freeze, R.A. and Cherry, J.A. 1979. Groundwater. Prentice-Hall, Inc., Englewood Cliffs, N.J. 07632, USA, pp. 1-604.

Government of Canada. 2017. The Atlas of Canada. Toporama, version 2.3. <u>http://atlas.gc.ca/toporama/en/index.html</u>.

Health Canada. 2017. Guidelines for Canadian Drinking Water Quality Summary Table. Federal-Provincial-Territorial Committee on Drinking Water of the Federal-Provincial-Territorial Committee on Health and the Environment.

New Brunswick Department of Environment and Local Government. 2017. Environmental Impact Assessment Water Supply Source Assessment Guidelines.

Rampton, V. N. 1984. Generalized surficial geology map of New Brunswick Department of Natural Resources and Energy. Mineral, Policy and Planning Division. NR-8 (scale 1: 500 000).

Rivard, C., Michaud, Y., Deblonde, C., Boisvert, V., Carrier, C., Morin, R.H., Calvert, T., Vigneault, H., Conohan, D., Castonguay, S., Lefebvre, R., Rivera, A., and Parent, M. 2008. Canadian Groundwater Inventory: Regional hydrogeological characterization of the south central part of the Maritimes Basin; Geological Survey of Canada. Bulletin 589, 96 p.

Service New Brunswick. NBGIC Parcel Data, 2017. Real Property Information PID numbers 00837088, 70188826 and 70563457. New Brunswick. Canada.

Smith, E.A. (compiler). 2007. Bedrock geology of the Cape Tormentine area (NTS 11L/04), Westmorland County, New Brunswick. New Brunswick Department of Natural Resources, Minerals, Policy and Planning Division, Plate 2007-46. Scale 1:50,000.

APPENDICES

APPENDIX A: Figures

APPENDIX B: SNB Documentation

APPENDIX C: Well Driller's Reports

APPENDIX D: Pumping Test Data for Pumping Well and Observation Well


APPENDIX E: Laboratory Certificates

APPENDIX F: Environment Canada Daily Data Report and Tide Tables

APPENDIX G: NBDELG Documentation

APPENDIX A

Figures



APPENDIX B

SNB Documentation

Parcel Information

Service Nouveau-Brunswick

PID:	837088	County:	Westmorland
Status:	Active	Active Date/Time:	1970-01-01 01:01:01
Land Related Description:	Land	Management Unit:	NB1423
Area:	3.43	Area Unit:	Hectares
Date Last Updated:	2016-08-24 11:16:44	Harmonization Status:	Harmonized
Land Titles Status:	Land Titles	Land Titles Date/Time:	2004-05-21 13:10:30
Date of Last CRO:	2014-12-19 15:44:41	Manner of Tenure:	Not Applicable
Land Gazette	NO		

Description of Tenure:

Public Comments:

Information:

MAP/CARTE 11L04X1

Parcel Interest Holders

Owner						Qualifier	Interest Type
Strang's Shor	re Seasonal Camping In	IC.					Owner
			Asse	ssment R	eference)	
PAN	PAN Type		Та	axing Authori	ty Code	Taxing Author	ity
6509191			64	40		L.S.D. of/D.	S.L. de Murray Corner
			Ра	rcel Locat	tions		
Civic Number	Street Name		Stree	et Type		Street Direction	Place Name
1641	955		Hig	nway			Little Shemogue
			Co	ounty Pari	sh		
County					Parish		
Westmorland	1				Botsfo	rd	
				Documen	ts		
Number	Registration Date	Book	Page	Code	Descr	iption	
34494873	2014-12-19			1100	Deed	I/Transfer	
28639269	2010-04-28			6110	Disch	narge of Mortgag	e
28133925	2009-12-08			1100	Deed	I/Transfer	
18738790	2004-07-16			5100	Mortg	gage	
18380478	2004-05-21			3800	Land	Titles First Notic)e
18380460	2004-05-21			3720	Land	Titles First Orde	r

Parcel Information

Service New Brunswick

					Documents	(cont.)		
Number	Re	gistration Date	Book	Page	Code	Description	I	
18378068	20	04-05-21			3900	Land Title	s First Application	
615127	19	95-12-01	2409	523	101	Deed		
433742	19	83-01-01	891	406	101	Deed		
414253	19	81-01-01	792	34	101	Deed		
170020	19	46-01-01	X13	334	105	Will		
					Plans			
Number	Suffix	Registation Date	Code		Description		Lot Information	Orientation
28082114		2009-11-26	9050		Subdivision & Amalgamatic		Lot	Provincial Grid
14086		1983-05-20	9040		Retracement Return of Su		Parcel A	Provincial Grid
				P	arcel Relatio	ons		
Related PID			Туре С	f Relati	on	Lot	Information	
963215			Infant			Pai	rcel B	
70188826			Infant			Lot	: 87-1	
70517206			Infant			Lot	09-1	

Non-Registered Instruments

No Records Returned

PAN:	6509191	Status:	Open
Assessed Owner(s):	STRANG'S SHORE SEASONAL CAMPING INC.	Mailing Address:	89 MOORE RD EXT OTTERCREEK NB
Assessment Year:	2017	Postal Code:	E4M 3V5
Current Assessment:	\$ 611,300	Current Levy:	\$ 10,619.76
Location:	1639 RTE 955	County:	Westmo rl and
Property Description: Property Type Code:	RV PARK & CAMPGROUND 532	Tax Class: Property Type Name:	Fully Taxable
Taxing Authority Code	: 640	Neighbourhood Code	: 01
Taxing Authority Code Taxing Authority Description:	[:] 640 L.S.D. of/D.S.L. de Murray Corner	Neighbourhood Code Neighbourhood Description:	01 MURRAY CORNER LSD
Taxing Authority		Neighbourhood	
Taxing Authority Description:	L.S.D. of/D.S.L. de Murray Corner	Neighbourhood Description:	MURRAY CORNER LSD
Taxing Authority Description: Sequence Number:	L.S.D. of/D.S.L. de Murray Corner A105C COMPLETED (PAN consists of Assessment amalgamated parcels except those for building stradding	Neighbourhood Description: Sub Unit: Farm Land Identifiation	MURRAY CORNER LSD

Sale Price Information

No Records Returned



Map Scale / Échelle cartographique 1 : 4239

While this map may not be free from error or omission, care has been taken to ensure the best possible quality. This map is a graphical representation of property boundaries which approximates the size, configuration and location of properties. It is not a survey and is not intended to be used for legal descriptions or to calculate exact dimensions or area.

Même si cette carte n'est peut-être pas libre de toute erreur ou omission, toutes les précautions ont été prises pour en assurer la meilleure qualité possible. Cette carte est une représentation graphique approximative des terrains (limites, dimensions, configuration et emplacement). Elle n'a aucun caractère officiel et ne doit donc pas servir à la rédaction de la description officielle d'un terrain ni au calcul de ses dimensions exactes ou de sa superficie.

Service New Brunswick

Parcel Information

Service Nouveau-Brunswick

PID:	70188826	County:	Westmorland
Status:	Active	Active Date/Time:	1987-08-25 00:00:00
Land Related Description:	Land	Management Unit:	NB1423
Area:	1.13	Area Unit:	Hectares
Date Last Updated:	2016-05-31 13:28:27	Harmonization Status:	Harmonized
Land Titles Status:	Land Titles	Land Titles Date/Time:	2003-06-16 16:39:36
Date of Last CRO:	2016-05-31 13:28:34	Manner of Tenure:	Not Applicable
Land Gazette	NO		

Information:

Description of Tenure:

Public Comments:

16443179

MAP/CARTE 11L04X1

Owner					Qualifier	Interest Type
STRANG'S SI	HORE SEASONAL CA		Owner			
			Asses	ssment Refe	erence	
PAN	PAN Type		Та	xing Authority C	ode Taxing Autho	rity
3876426			64	40	L.S.D. of/D.	S.L. de Murray Corner
			Ра	rcel Locatio	ns	
Civic Number	Street Name		Stree	et Type	Street Direction	Place Name
1645	955		High	nway		Murray Corner
			Co	ounty Parish		
County				I	Parish	
Westmorland					Botsford	
				Documents		
Number	Registration Date	Book	Page	Code	Description	
35975771	2016-05-31			1100	Deed/Transfer	
31683940	2012-07-09			1100	Deed/Transfer	
16451982	2003-06-18			1100	Deed/Transfer	

Parcel Interest Holders

2003-06-16	3800	Land Titles First Notice
------------	------	--------------------------

16443161	2003-06-16	3720	Land Titles First Order

16442379 2003-06-16	3900	Land Titles First Application
---------------------	------	-------------------------------

					Documents	(cont.)		
Number	Re	gistration Date	Book	Page	Code	Description		
494041	19	87-08-08	1279	3	101	Deed		
					Plans			
Number	Suffix	Registation Date	Code		Description		Lot Information	Orientation
16171		1987-08-12	9050		Subdivision 8 Amalgamatio		Lot 87-1	Provincial Grid
				Р	arcel Relatio	ns		
Related PID			Туре С	of Relation	on	Lot	nformation	
837088			Parer	nt		Parc	cel A	

Non-Registered Instruments

No Records Returned

PAN:	3876426	Status:	Open
Assessed Owner(s):	Strang's Shore Seasonal Camping Inc.	Mailing Address:	89 MOORE EXT. ROAD OTTERCREEK NB
Assessment Year:	2017	Postal Code:	E4M 3V5
Current Assessment:	\$ 17,400	Current Levy:	\$ 301.96
Location:	1645 RTE 955	County:	Westmorland
Property Description:	VACANT LOT	Tax Class:	Fully Taxable
Property Type Code:	105	Property Type Name:	Mobile/Mini Homes and Land
Taxing Authority Code	: 640	Neighbourhood Code	: 01
Taxing Authority Description:	L.S.D. of/D.S.L. de Murray Corner	Neighbourhood Description:	MURRAY CORNER LSD
Sequence Number:	A105B	Sub Unit:	0
Harmonization:	COMPLETED (One to one match of parcels)	Farm Land Identifiation Program:	No
PID:	70188826	PID (2nd):	-
More PID(s):	No		

Sale Price Information

Price:	\$90,000	Date:	2016-05-31
Price:	\$1	Date:	2012-07-09
Price:	\$28,000	Date:	2011-05-16

Service New Brunswick

Service Nouveau-Brunswick

Ň



Map Scale / Échelle cartographique 1 : 2137

While this map may not be free from error or omission, care has been taken to ensure the best possible quality. This map is a graphical representation of property boundaries which approximates the size, configuration and location of properties. It is not a survey and is not intended to be used for legal descriptions or to calculate exact dimensions or area.

Même si cette carte n'est peut-être pas libre de toute erreur ou omission, toutes les précautions ont été prises pour en assurer la meilleure qualité possible. Cette carte est une représentation graphique approximative des terrains (limites, dimensions, configuration et emplacement). Elle n'a aucun caractère officiel et ne doit donc pas servir à la rédaction de la description officielle d'un terrain ni au calcul de ses dimensions exactes ou de sa superficie.

Service New Brunswick

Parcel Information

Service Nouveau-Brunswick

PID:	70563457	County:	Westmorland
Status:	Active	Active Date/Time:	2012-08-27 12:20:51
Land Related Description:	Land	Management Unit:	NB1423
Area:	3.27	Area Unit:	Hectares
Date Last Updated:	2016-08-24 11:16:18	Harmonization Status:	Harmonized
Land Titles Status:	Land Titles	Land Titles Date/Time:	2012-09-18 10:34:47
Date of Last CRO:	2015-09-11 09:51:52	Manner of Tenure:	Not Applicable
Land Gazette	NO		

Description of Tenure:

Public Comments:

Information:

MAP/CARTE	11L04U3	11L04X1
-----------	---------	---------

Owner						Qualifier	Interest Type
STRANG'S S	HORE SEASONAL CA	MPING IN	NC.				Owner
			Asse	ssment Re	eference		
PAN	PAN Type		Та	axing Authorit	ty Code Taxi	ng Author	ity
6509191			64	40	L.S	.D. of/D.\$	S.L. de Murray Corner
			Pa	rcel Locat	tions		
Civic Number	Street Name		Stree	et Type	Street D	Direction	Place Name
	Stright Beach		Roa	d			Murray Corner
			Co	ounty Pari	sh		
County					Parish		
Westmorland	t				Botsford		
				Documen	its		
Number	Registration Date	Book	Page	Code	Description		
35230599	2015-09-10			2200	Easement		
35213298	2015-09-03			2200	Easement		
31967715	2012-09-20			1100	Deed/Transfe	er	
31956734	2012-09-18			3800	Land Titles F	irst Notic	e
31956726	2012-09-18			3720	Land Titles F	irst Orde	r
31955876	2012-09-18			3900	Land Titles F	irst Appli	cation

Parcel Interest Holders

				Documents	(cont.)	
Number	Re	gistration Date	Book Pag	ge Code	Description	
22394374	20	06-07-10		1900	Deed of a Partial Interest	
				Plans		
Number	Suffix	Registation Date	Code	Description	Lot Information	Orientation
31877427		2012-08-27	9050	Subdivision & Amalgamation		Provincial Grid
				Parcel Relatio	ns	
Related PID			Type Of Rel	ation	Lot Information	
70061395			Parent		Lot	

Non-Registered Instruments


No Records Returned

PAN:	6509191	Status:	Open
Assessed Owner(s):	STRANG'S SHORE SEASONAL CAMPING INC.	Mailing Address:	89 MOORE RD EXT OTTERCREEK NB
Assessment Year:	2017	Postal Code:	E4M 3V5
Current Assessment:	\$ 611,300	Current Levy:	\$ 10,619.76
Location:	1639 RTE 955	County:	Westmo rl and
Property Description: Property Type Code:	RV PARK & CAMPGROUND 532	Tax Class: Property Type Name:	Fully Taxable
Taxing Authority Code	: 640	Neighbourhood Code	: 01
Taxing Authority Code Taxing Authority Description:	: 640 L.S.D. of/D.S.L. de Murray Corner	Neighbourhood Code Neighbourhood Description:	01 MURRAY CORNER LSD
Taxing Authority		Neighbourhood	
Taxing Authority Description:	L.S.D. of/D.S.L. de Murray Corner	Neighbourhood Description:	MURRAY CORNER LSD
Taxing Authority Description: Sequence Number:	L.S.D. of/D.S.L. de Murray Corner A105C COMPLETED (PAN consists of Assessment amalgamated parcels except those for building stradding	Neighbourhood Description: Sub Unit: Farm Land Identifiation	MURRAY CORNER LSD

Sale Price Information

No Records Returned

Ň



Map Scale / Échelle cartographique 1 : 3664

While this map may not be free from error or omission, care has been taken to ensure the best possible quality. This map is a graphical representation of property boundaries which approximates the size, configuration and location of properties. It is not a survey and is not intended to be used for legal descriptions or to calculate exact dimensions or area.

Même si cette carte n'est peut-être pas libre de toute erreur ou omission, toutes les précautions ont été prises pour en assurer la meilleure qualité possible. Cette carte est une représentation graphique approximative des terrains (limites, dimensions, configuration et emplacement). Elle n'a aucun caractère officiel et ne doit donc pas servir à la rédaction de la description officielle d'un terrain ni au calcul de ses dimensions exactes ou de sa superficie.

APPENDIX C

Well Driller's Reports



Report Number 6807

Well Driller's Report

Date printed 6/8/2017

Well Us Drinkir		, Domest	ic	Work Ty New We		Dri ll Method Rotary				k Comp 7/08/20	
	Casing	Informat	ion		Casing abo	ve ground 2ft		Driv	e Shoe Used?	'Yes	
	Well Log	Casing T	уре	Diam	neter	From	End	Sk	otted?		
	6807	Steel		6 inc	h	Oft	80ft				
	r Test/Yi	Initial W		Pumping Rate	Duration	Final Water Level (BTC)		timated fe Yie l d	Flowing Well?		
Methoo Air	L	Level (E 0f f (BTC - E	t	3 igpm	Duration 1hr	105ft	3	igpm	No		Rate igpm
Well Gr	U			None	ing Fluids U	304	Disinf N/A	ectant	Pump In N/A	stalled	
	There is no	o Grout inf	ormatio	n .					Intake Set	ting (BTC))
							0.1				
							Qty	0 ig	Oft		
Driller's	Log						Qty	0 ig		Jenth	
		End	Color	ur	F	Rock Type	Qty	0 ig	0ft Overall Well [241ft	Depth	
Well Log 6807	From Oft	2ft	Unkno	wn Rock Colour	. c	Rock Type Dverburden	Qty	0 ig	Overall Well [
Well Log 6807 6807	From Oft 2ft	2ft 15ft	Unknov Brown	wn Rock Colour	. (Rock Type Overburden Clay and Shale	Qty	0 ig	Overall Well [241ft		
Well Log 6807 6807 6807	From 0ft 2ft 15ft	2ft 15ft 18ft	Unkno Brown Grey	wn Rock Colour	· () () () ()	Rock Type Dverburden Clay and Shale Gandstone	Qty	0 ig	Overall Well [241ft Bedrock Leve		
Well Log 6807 6807 6807 6807	From Oft 2ft 15ft 18ft	2ft 15ft 18ft 21ft	Unknov Brown Grey Brown	wn Rock Colour	· () () () () () () () () () () () () () (Rock Type Overburden Clay and Shale Sandstone Clay and Shale	Qty	0 ig	Overall Well [241ft Bedrock Leve		
Well Log 6807 6807 6807 6807 6807 6807	From 0ft 2ft 15ft	2ft 15ft 18ft 21ft 30ft	Unkno Brown Grey Brown Grey	wn Rock Colour		Rock Type Overburden Clay and Shale Sandstone Clay and Shale Sandstone	Qty	0 ig	Overall Well [241ft Bedrock Leve		
Well Log 5807 5807 5807 5807 5807 5807 5807	From Oft 2ft 15ft 18ft 21ft	2ft 15ft 18ft 21ft	Unknov Brown Grey Brown	wn Rock Colour	·	Rock Type Overburden Clay and Shale Sandstone Clay and Shale	Qty	0 ig	Overall Well [241ft Bedrock Leve		
Well Log 6807 6807 6807 6807 6807 6807 6807	From Oft 2ft 15ft 18ft 21ft 30ft	2ft 15ft 18ft 21ft 30ft 42ft	Unkno Brown Grey Brown Grey Brown	wn Rock Colour		Rock Type Dverburden Clay and Shale Sandstone Clay and Shale Sandstone Clay and Shale	Qty	0 ig	Overall Well [241ft Bedrock Leve		
Well Log 6807 6807 6807 6807 6807 6807 6807 6807	From 0ft 2ft 15ft 18ft 21ft 30ft 42ft 45ft 56ft	2ft 15ft 18ft 21ft 30ft 42ft 45ft 56ft 67ft	Unknor Brown Grey Brown Grey Brown Grey Brown Grey	wn Rock Colour	·	Rock Type Dverburden Clay and Shale Sandstone Clay and Shale Sandstone Clay and Shale Sandstone Clay and Shale Sandstone	Qty	0 ig	Overall Well [241ft Bedrock Leve		
Well Log 6807 6807 6807 6807 6807 6807 6807 6807	From 0ft 2ft 15ft 18ft 21ft 30ft 42ft 42ft 56ft 67ft	2ft 15ft 18ft 21ft 30ft 42ft 45ft 56ft 67ft 76ft	Unknor Brown Grey Brown Grey Brown Grey Brown Grey Brown	wn Rock Colour		Rock Type Dverburden Clay and Shale Sandstone Clay and Shale Sandstone Clay and Shale Sandstone Clay and Shale Sandstone Clay and Shale	Qty	0 ig	Overall Well [241ft Bedrock Leve		
Well Log 6807 6807 6807 6807 6807 6807 6807 6807	From Oft 2ft 15ft 18ft 21ft 30ft 42ft 42ft 45ft 56ft 67ft 76ft	2ft 15ft 18ft 21ft 30ft 42ft 45ft 56ft 67ft 76ft 110ft	Unknov Brown Grey Brown Grey Brown Grey Brown Grey	wn Rock Colour		Rock Type Dverburden Clay and Shale Sandstone Clay and Shale Sandstone Clay and Shale Sandstone Clay and Shale Sandstone Clay and Shale Sandstone	Qty	0 ig	Overall Well [241ft Bedrock Leve		
Well Log 6807 6807 6807 6807 6807 6807 6807 6807 6807 6807 6807 6807 6807	From Oft 2ft 15ft 18ft 21ft 30ft 42ft 42ft 56ft 67ft 76ft 110ft	2ft 15ft 21ft 30ft 42ft 45ft 56ft 67ft 76ft 110ft 177ft	Unknor Brown Grey Brown Grey Brown Grey Brown Grey Brown	wn Rock Colour		Rock Type Dverburden Clay and Shale Sandstone Clay and Shale Sandstone Clay and Shale Sandstone Clay and Shale Sandstone Clay and Shale Sandstone Clay and Shale Sandstone	Qty	0 ig	Overall Well [241ft Bedrock Leve		
Well Log 6807 6807 6807 6807 6807 6807 6807 6807 6807 6807 6807 6807 6807 6807	From Oft 2ft 15ft 18ft 21ft 30ft 42ft 42ft 56ft 67ft 76ft 110ft 177ft	2ft 15ft 21ft 30ft 42ft 45ft 56ft 67ft 76ft 110ft 177ft 183ft	Unkno Brown Grey Brown Grey Brown Grey Brown Grey Brown Brown Brown	wn Rock Colour		Rock Type Dverburden Clay and Shale Sandstone Clay and Shale Sandstone Clay and Shale Sandstone Clay and Shale Sandstone Clay and Shale Sandstone Clay and Shale Sandstone		0 ig	Overall Well [241ft Bedrock Leve		
Well Log 6807 6807 6807 6807 6807 6807 6807 6807	From Oft 2ft 15ft 18ft 21ft 30ft 42ft 56ft 67ft 76ft 110ft 177ft 183ft	2ft 15ft 21ft 30ft 42ft 45ft 56ft 67ft 76ft 110ft 177ft 183ft 199ft	Unkno Brown Grey Brown Grey Brown Grey Brown Grey Brown Brown Brown	wn Rock Colour		Rock Type Dverburden Clay and Shale Sandstone Clay and Shale		0 ig	Overall Well [241ft Bedrock Leve		
Driller's Well Log 6807 6807 6807 6807 6807 6807 6807 6807 6807 6807 6807 6807 6807 6807	From Oft 2ft 15ft 18ft 21ft 30ft 42ft 42ft 56ft 67ft 76ft 110ft 177ft	2ft 15ft 21ft 30ft 42ft 45ft 56ft 67ft 76ft 110ft 177ft 183ft	Unkno Brown Grey Brown Grey Brown Grey Brown Grey Brown Brown Brown Brown	wn Rock Colour		Rock Type Dverburden Clay and Shale Sandstone Clay and Shale Sandstone Clay and Shale Sandstone Clay and Shale Sandstone Clay and Shale Sandstone Clay and Shale Sandstone		0 ig	Overall Well [241ft Bedrock Leve		

Water Be	earing Frac	ture Zone	Setbacks
Well Log	Depth	Rate	There is no Setback information.
6807	88ft	3 igpm	



Report Number 15242

Well Driller's Report

Date pri	nted	6/8/20 ⁻	17							
Drilled b	ру									
Well Us	e			Work	Tvpe	Drill Me	thod		Work	Completed
	g Water,	Domes	tic	New V		Rotary				/13/2007
						····· ·				
	Casing	Informa	ation		Casing a	above ground a	2ft	Driv	ve Shoe Used?	Yes
	Well Log	Casing -	Туре	Di	ameter	From	End	SI	otted?	
	15242	Steel	31	6 i	nch	Oft	29ft			
	15242	PVC		5 '	l/2 Inch	29ft	70ft			
Aquifor	Teet/Vi	ald								
Aquilei	Test/Yi		N/	Pumping		Final Wa		stimated		
Method		Initial \ Level (Rate	Duratio			afe Yie l d	Well?	Rate
Air) Oft	10 igpm	Ourand 0hr	19ft	,	0 igpm	No	0 igpm
			Below top	•.	VIII	1911		o ighili	NO	o igpri
							D ''		D	
Well Gro	outing				illing Fluid	s Used		nfectant	Pump Ins	stalled
Т	here is no	Grout in	formation		one		Chlo	rine Pucl		
							Qty	0 ig	Intake Setti	ng (втс)
							Giy	Ulg	Oft	
Dri ll er's	Log								Overall Well D	onth
Well Log	From	End	Colou	ır		Rock Type			85ft	ерш
15242										
	Oft 9ft	9ft 25ft	Brown Brown			Overburden Clay			Bedrock Level	
15242	25ft	35ft	Grey			Sandstone			25ft	
15242	35ft	40ft	Brown			Clay and Shal	e			
15242	40ft	83ft	Grey			Sandstone				
15242	83ft	85ft	Brown			Clay and Shal	0			
Water B	Bearing F	racture	Zone		Setbacks					
Well Log	Depth		Rate		Well Log	Distance	Setbac	k From		
15242	32ft		5 igpm		15242	85ft	Septic T	ank		
15242	54ft		5 igpm		15242	90ft	Leach F	ield		



Report Number 24773

PW1 (Campground Production Well)

Well Driller's Report

Date pri	inted	6/8/20	17							
Dri ll ed I	ру									
Well Us	e			Wo	rk Type	Drill Met	hod		Work	Completed
Drinkin	g Water,	Domes	stic	Nev	v Well	Cable T	00		08/	02/2010
	[
	Casing	Informa	ation		Casing	above ground 2	ft 10in	Drive S	Shoe Used? Y	res
	Well Log	Casing	Туре		Diameter	From	End	Slotte	d?	
	24773	Steel			6 inch	Oft	36ft			
Aquife	r Test/Yi	eld					Fs	timated		
		Initial V	Water	Pumpii		Final Wa	iter Sa	fe Yield	Flowing	
Method		Level	(BTC)	Rate	Durau	on Level (B1	FC)		Well?	Rate
Bailer			6ft	20 igp		20ft	20) igpm	No	0 igpm
		(BTC -	- Below top	of casina)						
Well Gr	outing				Drilling Fluid	s Used	Disinf	ectant	Pump Inst	alled
1	There is no	Grout in	nformatior	1_	None		Chlor	ne Pucks	Submersi	
					J		Qty	0 ig	Intake Settin Oft	у (втс)
								• .9	UIL	
Driller's	Log							0	verall Well De	epth
Well Log	From	End	Colou	ır		Rock ⊺ype)5ft	
24773	Oft	10ft	Brown			Clay and Sand		Be	edrock Level	
24773	10ft	21ft	Red			Clay and Sand		21		
24773 24773	21ft	30ft	Brown			Sand				
24773 24773	30ft 41ft	41ft 53ft	Red Grey			Soft Shale Sandstone				
24773	53ft	80ft	Red			Shale				
24773	80ft	105ft	Dark bi	own		Sandstone				
	Bearing F	racture	Zone		Setbacks					
Water E					Well Log	Distance	Setback	From		
	-		Rate				JOUDAUK			
Well Log	Depth 60ft		Rate 15 loom				Right of a	ny Public W	av Road	
Water E Well Log 24773 24773	Depth		Rate 15 lgpm 10 igpm		24773	600ft	Right of a	ny Public Wa	ay Road	



Report Number 27209

Well Driller's Report

Date pr	inted	6/8/201	17								
Drilled Well Us	-			Wor	к Туре	Drill M	ethod				Completed
Drinkir	ng Water,	Domes	tic	New	/ Well	Rotary	,			09/	03/2009
	Casing	Informa	tion		Casing	above ground	1ft 6in	D	rive Sh	be Used? Y	′es
	Well Log	Casing T	Гуре		Diameter	From	E	nd	Slotted?		
	27209	Steel			6 inch	Oft	3	Oft			
	r Test/Yi	Initial V		Pumpir	•	Final V		Estimate Safe Yie	-	Flowing	_
Methoo Air	ł	Level (15	. ,	Rate 60 igpi	Durati n 1hr	on Level (151	,	5 igpm		Well? No	Rate 0 igpm
		(BTC -	Below top	of casina)							
Well Gr	outing There is no	Groutin	formation		Drilling Fluid None	s Used		sinfectani n lorine Pu	-	Pump Inst N/A	
	There is no	Groutin	inormation	•			Q	ty 0ig		Intake Setting Oft	g (B⊤C)
Driller's	Log									rall Well De	nth
Well Log		End	Colou	r		Rock ⊺ype			105f		pui
27209	Oft	3ft	Brown			Topsoil			Bedr	ock Level	
27209	3ft	10ft	Brown			Fill			Oft		
27209 27209	10ft 28ft	28ft 45ft	Red Brown			Clay Fine Sandsto	ne		_		
27209	45ft	70ft	Grey			Medlum San					
27209	70ft	105ft	Brown			Fine Sandsto	ne				
Water E	Bearing F	racture	Zone		Setbacks						
Well Log	Depth		Rate		Well Log	Distance	Setb	ack From			
27209	60ft		3 igpm		27209	65ft		ic Tank			
27209	101ft		57 lgpm		27209	90ft		h Field			
					27209	300ft	Righ	t of any Pub	blic Way I	Road	



Report Number 30194

Environment

00104

OW1 (Observation Well)

Date printed 6/8/2017 Drilled by Well Use Work Type Drill Method Work Completed 08/13/2014 **Drinking Water, Domestic** New Well Rotary Casing above ground 2ft Drive Shoe Used? Yes Casing Information Well Log Casing Type Diameter From End Slotted? 30194 Steel 6 inch 0ft 40ft Aquifer Test/Yield Estimated Final Water Pumping Flowing Initial Water Safe Yield Rate Level (BTC) Well? Method Level (BTC) Duration Rate 5ft 30ft Air 15 igpm 1hr 15 igpm No 0 igpm (BTC - Below top of casina) Well Grouting Disinfectant Pump Installed Drilling Fluids Used None N/A Bleach (Javex) E<u>nd</u> Well Log Grout Type From Intake Setting (BTC) 30194 Bentonite 35ft 40ft Qty 0 ig 0ft Driller's Log Overal Well Depth Well Log From Rock Type End Colour 65ft 30194 Oft 15ft Brown Till Bedrock Level 30194 15ft 20ft Brown Sandstone 0ft 30194 20ft 51ft Grey Sandstone 30194 51ft 57ft Brown Shale 30194 Sandstone 57ft 65ft Brown Water Bearing Fracture Zone Setbacks Well Log Depth Rate Well Log Distance Setback From 30194 50ft 5 lgpm 30194 Septic Tank 65ft 30194 60ft 10 igpm 30194 80ft Leach Fleid 30194 62ft 1 igpm 30194 200ft Center of road

Well Driller's Report

DNew BNouveau	and the second second second				Constant of the second			-	
OFFICE USE ONLY	HEALTH CODE		LOCAL G	CONTRACTOR OF TAXABLE PARTY OF TAXABLE P	Contract of the local division of the local	MARYO,	WATER WE		10036282
FIELD NO.	HEALTH CODE	B ADDELO SOL		SAM	PLE RECEIV DATE	CUCR IN	DRILLER'S RE	PORT	00000006
	HEALTH OFFICE	a second s				SAM	PLE RECEIVED BY:		
A \$56-2204	V Main Stree	enotion Biology, Th		YR	MO	DAY			OW1
TESTING VOUCHER INFOR	MATION	MANDATORY F	OR WATER	TEST	P.I.D. NO).	WELL I.D. I	NO.	
	SE PRINT	1 phones 1 00			701	RXX	26 0056	shalo	SUSSEX
INFORMATION INCLUDED HEREIN S	SHOULD BE THE V	LAST NAME	F SAMPLING		101	000	F	000	<u> </u>
		and the second second second second					FORMATION ED HEREIN SHOULD BE THE	WELL OWNER	T TIME OF DRILLING
ADDRESS (MAIL RESULTS TO))	TO MILESPAN PING.			FIRST NAM		1	LAST NAME	
		TITT			STr	ang	s Shore	Cam	ping . Inc
CITY/TOWN/VILLAGE	le oot meo?	PROV. PO	STAL CODE		ADDRESS	11=	- 1		NOCEDETCOCK
			TIT	in iss	16	145	Histua	295	5.
DAYTIME PHONE	neadel I FA	X NO.			CITY/TOWN	I/VILLAGE	aniway stivel, saite 2	PROVIN	ICE POSTAL CODE
			1 1 1			1 1 1			
TEL. NO. COLSHOLD REFILE		YR MO DAY	HR M	IIN AM		BER STRE	IE AS ABOVE OR ET NAME		NOTSOMMER
		00704050		PM					CONTRACTOR OF THE
DO YOU NEED A SAMPLE I	FORYOURM	ORIGAGE?	SEE BACK	FOR	CITY/TOW	N/VILLAGE	N	WELL PAID FOR	BY PROVINCIAL DEPT.
IF YOU WISH THE RESULT			DETAIL	and the second second	99	OR THE O	an Street Suma 20	OF	TERLITING
MORTGAGE INSTITUTION I FOLLOWING CONTACT INI		UDE THE			WELL ON	RESERVE	? WELL ALREADY TAC	GGED? OLD W	ELL I.D.
£101		byle energie 17	A state of the sta		YES	NO	YES NO		
ATTENTION OF:							DRILLER'S	LOG *	
TEL NO.		NILOH ub (144 -			FROM (FT.)	TO (FT.)	COLOUR		ROCK TYPE
		SP noibius her				1.0.11			
SIGNATURE OF WELL OWNER	C DO TROMINI OR	and the second state	and and a		Ground	Gers			
0882-088		ntrovillo Mail. 342			65	90	Red	5/	a changes
WAS THE COST OF THIS WELL	L FINANCED BY	NB HOUSING?	annes ann an an an ann an an an an an an an a		90	105	ann	50-	astra
YES NO	1 336-3017	185 1" Stree			10	103	guis		Martin C.
WELL / WATER USE:									
	ABANDONED	DOMES			and the second second	78-6032	(6 Dalton Avenue 7	B ^a landa da	THOMAPIN
The second s	MUNICIPAL								
HEAT PUMP	OBSERVATION	OTHER							noraut
GITTE	CTE SILLE	Dimevizi Lestor 65		-	a service serv	A. Same			STRACTION ATTRACT
TYPE OF WORK COMPLET	ED: NEW W		EEPENED						
OTHER:	10 Civic Cour	Lield mass? many	Chin						MARINE C
METHOD:									
		N ET .eost9 onor							NAMAJALA KO
CASING INSTALLED:	<u></u>								
LENGTH OF CASING ABOVE G	ROUND	2 5 0	IN						SACKAILLE
677		FT. TO 5							The second s
and the second se					and the second				
PVC: IN DIAM		ri usi ginunuci is							KEDGMRCK
SLOTTED IN DIAM	. FROM	FT. TO	FT.						
SCREENS: TYPE: SL	OT SIZE	M. Sute 130, 2H	DRIVE SH	OE:	20234	200 Q -	1 2 squal? his and	<u>eet 330</u>	200210
							N. All Market		
IN DIAM. FROM	_ FI. 10	ET.WY UT A		NO			1 IIIII		NOTUMEN
SETBACKS: SEE BACK FOR	DETAILS	SEPTIC TANK (1)	New	FT.	Participa				
SEPTIC TANK (2) FT.			and the second se		and soundaries	in annut	Plan accusto		
*RIGHT OF WAY OF ANY PUBLIC F				17. me	conteet o	a priska	Barrolen		in the second second
CENTER OF ROAD									
SETBACKS MEASURED				10 - 1 V			FICIENT SPACE PLEASE		
APPROXIMATE SETBACKS AS IN		the set of		ONST.)	HER PLA			Contract of the second	
FLOWING WELL? YES	NO	F YES - RATE:	igpm (ar	oprox.)	TOTAL W	ELL DEPTH	1: FT. DEP	TH TO BEDRO	CK:FT.
AQUIFER TEST: METHOD			Desire conception set	and laster	WATER B	EARING 1	igpm AT	_ FT. 2	igpm AT FT.
INITIAL WATER LEVEL:					FRACTU	RE ZONES	3 igpm AT	- FT. 4	igpm AT FT.
PUMPING RATE 30 igr									C. C
FINAL WATER LEVEL:					PUMP IN	ISTALLA	TION: INSTALLED	NOT IN	ISTALLED
ESTIMATED SAFE YIELD					PUMP IN	TAKE SETT	ING: FT.	BELOW TOP	OF CASING
WELL GROUTED? YES	the state when the state of the	ipgin	SCHE CHISC	tool on	(Recomment PUMP T	Nded) YPE: S		T	
FROM FT. TO		GROUT TYPE		1	OTHER	LISWA STA	es allo y sa balantico a	and yough	tor this testing that a
		GHOOT TIPE	* 2	and the	TO AMERICA (MC)		VECT NO T	-	
DRILLING FLUIDS USED: YES					Note in and	INFECTEL	? YES NO		the still and advantaged
TYPE:		· materia	llowing coll	ci odt i	TYPE _	autonoo	ed ventiew or mus	arreade ta	Environment & Los
DRILLER'S COMMENTS	this u	rell cons	DRILLING	COMP	ANY.	HC	mel de	allen	when the same internation
Decepcient From			CHILLING		1.61 -	1	15 meters	0	1 7 9 5 1008
Hit more war			COMPLE	TION DA	ATE: YR.	MO.	DAY	LICENSE NO.	
Feat This			- and the set	T	to stand	at. c	in an il in	n, a well oc	if for whighover Reaso
									entertevele techqui 8
Well FOR ST.	ungi la	imp grain	A. 10	Dee	-ph	e I	n paie.	and the second s	and a first state of the second state of the s
G.P.S. (OPTIONAL)) North	stan wak	auto	ring	f re	L'IS	nonegada partense	- In the weather and the	- Homeowner / Voucher
I CERTIFY THAT THE WELL	HEREIN DES	CRIBED HAS BEE	N CONSTRU	JCTED	IN ACCOR	RDANCE		PINK	HomeownerDrilling Company
WITH THE WATER WELL RE	EGULATION L	INDER THE NEW E	BRUNSWICK	CLEAN	N WATER	ACT.			Drining Company
Signature of Driller	X/		Signatu	re of Hel	lper		a providenti and and	lectorent enti	ar teoremus care model
1 1/11/10 b	Los Dong II	AV 20 BARA TEL	A	17,	1 M	AL	11	and - carries areas	HIS REPORT WITH YOUR
- Mypace	mall	1	-1-10	ee	OCR	della	ulld	IMPORT	ANT DOCUMENTS

ille ille

3S-C7183-Well Drilling Lon V2080813



Report Number 33345

Well Driller's Report

Date pri	nted	6/8/2	017									
Drilled b Well Us Drinkin	•	Dome	estic		< Туре Well	Dri ll Rota	Method I ry					Completec 13/2013
	Casing	Inform	nation		Casing a	above grou	nd 2ft		Driv	e Shc	e Used? Y	/es
	Well Log		ј Туре		Diameter	Fre	m	End	Slo	otted?		
	33345	Steel			6 inch	Oft		31ft				
Aquifer Method	Test/Yi	Initia Leve	l Water I (BTC)	Pumpin Rate	Duratio		Water (BTC)	Saf	imated e Yield	I	-lowing Well?	Rate
Air			10ft C - Below top	20 igpn of casina)	n 1hr 10n	nin 4	Oft	25	igpm		No	0 igpr
Well Gro	outing				Drilling Fluid: None	s Used		Disinfe			Pump Inst N/A	alled
Well Log	Grout Typ	ре	From	End	NOTICE			Bleach	(Javex	,	Intake Settin	g (BTC)
33345	Bentonite		20ft	30ft				Qty	0 ig		Oft	
Driller's	Log									Over	all Well De	enth
Well Log	From	End	Colou	ır		Rock ⊺yp	е			76ft		-pur
33345	Oft	10ft	Red			Sand				Bedr	ock Level	
	23ft	28ft	Grey			Clay and \$				Oft		
33345 33345	28ft 57ft	57ft 76ft	Red Brown			Sandstone Sandstone						
33345	10ft	23ft	Brown			Clay and S						
						•						
Water B	earing F	ractur	re Zone		Setbacks							
Well Log	Depth		Rate		Well Log	Distance	Se	etback l	From			
33345	50ft		15 lgpm		33345	60ft		optic Tar				
33345 33345	60ft 62ft		10 igpm 10 igpm		33345	80ft		ach Fle				
33345 33345	68ft		1 lgpm		33345	100ft	Ce	enter of	road			



Report Number 90386900

Well Driller's Report

Date phi	nted	6/8/201	17							
Drilled b	y									
Well Use	е			Work	Туре	Drill Method	k		Work	Completed
Drinking	g Water,	Domes	tic	New Well (NEW		Rotary (RC	TARY)	08/	31/1995
				WEL	L)					
	Casing	Informa	tion		Casing abo	ove ground 2ft		Driv	e Shoe Used? ۱	/es
	Well Log	Casing T	Гуре	D	iameter	From	End	Sl	otted?	
1	90386900	Steel		6	inch	Oft	42ft			
Aquifer	Test/Yie	eld					Fs	timated		
Method		Initial V Level (Pumping Rate) Duration	Final Water Level (BTC)	Sa	fe Yield	Flowing Well?	Rate
Air		01		5 igpm	1hr	20ft	5	igpm	No	0 igpm
		(BTC -	Below top					•		
Well Gro	outing				rilling Fluids L	lsed	Disinf	ectant	Pump Inst	alled
т	horo ic no	Croutin	formation		one		N/A		N/A	
	nere is no	Grout in	Tormation	•					Intake Settin	g (B⊤C)
							Qty	0 ig	Oft	
Driller's l	Log								Overall Well De	epth
	Log From	End	Colou	r		Rock ⊺ype			Overall Well De 105ft	epth
Well Log	From	End 29ft	Colou Brown	r		Rock Type			105ft	epth
Well Log 90386900 90386900	From 0ft 29ft	29ft 31ft	Brown Brown	r		Sand Broken Sandstone				epth
Well Log 90386900 90386900 90386900	From 0ft 29ft 31ft	29ft 31ft 82ft	Brown Brown Grey	r		Sand Broken Sandstone Sandstone			105ft Bedrock Level	epth
Well Log 90386900 90386900 90386900 90386900	From 0ft 29ft 31ft 82ft	29ft 31ft 82ft 84ft	Brown Brown Grey Grey	r		Sand Broken Sandstone Sandstone Shale			105ft Bedrock Level	epth
Driller's Well Log 90386900 90386900 90386900 90386900 90386900	From 0ft 29ft 31ft 82ft 84ft	29ft 31ft 82ft 84ft 93ft	Brown Brown Grey Grey Brown	r		Sand Broken Sandstone Sandstone Shale Clay and Shale			105ft Bedrock Level	epth
Well Log 90386900 90386900 90386900 90386900	From 0ft 29ft 31ft 82ft 84ft 93ft	29ft 31ft 82ft 84ft	Brown Brown Grey Grey	r		Sand Broken Sandstone Sandstone Shale			105ft Bedrock Level	epth
Well Log 90386900 90386900 90386900 90386900 90386900 90386900	From 0ft 29ft 31ft 82ft 84ft 93ft	29ft 31ft 82ft 84ft 93ft 96ft	Brown Brown Grey Grey Brown Brown	r		Sand Broken Sandstone Sandstone Shale Clay and Shale Sandstone			105ft Bedrock Level	epth
Well Log 90386900 90386900 90386900 90386900 90386900 90386900 90386900	From 0ft 29ft 31ft 82ft 84ft 93ft 96ft	29ft 31ft 82ft 84ft 93ft 96ft 105ft	Brown Brown Grey Grey Brown Brown Brown	r		Sand Broken Sandstone Sandstone Shale Clay and Shale Sandstone			105ft Bedrock Level	epth
Well Log 90386900 90386900 90386900 90386900 90386900 90386900 90386900 Water Be	From Oft 29ft 31ft 82ft 84ft 93ft 96ft earing F	29ft 31ft 82ft 84ft 93ft 96ft 105ft	Brown Grey Grey Brown Brown Brown Zone	r		Sand Broken Sandstone Sandstone Clay and Shale Sandstone Clay and Shale	Softeel		105ft Bedrock Level 0ft	epth
Well Log 90386900 90386900 90386900 90386900 90386900 90386900 90386900	From 0ft 29ft 31ft 82ft 84ft 93ft 96ft	29ft 31ft 82ft 84ft 93ft 96ft 105ft	Brown Brown Grey Grey Brown Brown Brown	r		Sand Broken Sandstone Sandstone Shale Clay and Shale Sandstone	Setback	x informa	105ft Bedrock Level 0ft	epth

APPENDIX D

Pumping Test Data for Pumping Well and Observation Well



PW1

80

85

90

91

92

93

94

95

96

97

98

99

100

105

110

115 120

175

Recovery

Well =

Step Test

wdown

Well = OW1

vvell =	PW1			VV eII = OVV	1			
SWL =	4.13 m bto	c ; 3.563 m	bgs	SWL= 3.46	5 m btoc; 2.8	h btoc; 2.89 m bgs		
Step	Elapsed		P۱	N1	C	W1		
	Time		water level	drawdown	water level	drawdowr		
	(min)		(m)	(m)	(m)	(m)		
Step 1	0		4.13	0	3.46	0		
10 lgpm	1		4.6619	0.5319	3.4687	0.0087		
	2		4.6938	0.5638	3.4695	0.0095		
	3		4.7312	0.6012	3.4693	0.0093		
	4		4.7817	0.6517	3.4675	0.0075		
	5		4.8169	0.6869	3.4681	0.0081		
	6		4.8561	0.7261	3.4675	0.0075		
	7		4.8781	0.7481	3.4672	0.0072		
	8		4.8827	0.7527	3.4681	0.0081		
	9		4.9259	0.7959	3.4676	0.0076		
	10		4.9309	0.8009	3.4676	0.0076		
	15		4.9956	0.8656	3.4675	0.0075		
	20		5.0609	0.9309	3.4654	0.0054		
	25		5.1058	0.9758	3.4677	0.0077		
	30		5.0903	0.9603	3.4666	0.0066		
Step 2	31		4.7843	0.6543	3.469	0.009		
20 lgpm	32		5.1031	0.9731	3.4693	0.0093		
	33		5.3027	1.1727	3.4689	0.0089		
	34		5.4172	1.2872	3.4698	0.0098		
	35		5.4969	1.3669	3.4703	0.0103		
	36		5.5796	1.4496	3.4716	0.0116		
	37		5.6388	1.5088	3.4711	0.0111		
	38		5.6938	1.5638	3.4719	0.0119		
	39		5.7393	1.6093	3.4709	0.0109		
	40		5.7843	1.6543	3.4725	0.0125		
	45		5.9284	1.7984	3.4709	0.0109		
	50		6.0474	1.9174	3.4721	0.0121		
	55		6.131	2.001	3.4729	0.0129		
Otom 0	60		6.1753	2.0453	3.4739	0.0139		
Step 3	61 62		5.4126	1.2826 1.7777	3.4762 3.4774	0.0162		
30 lgpm	63		5.9077 6.1848	2.0548	3.4774 3.4779	0.0174 0.0179		
	64			2.0548				
	65		6.3801 6.5237	2.2301	3.4794 3.4787	0.0194 0.0187		
	66		6.6339	2.5937	3.4787 3.4793	0.0187		
	67		6.7439	2.6139	3.4793 3.4795	0.0193		
	68		6.83	2.0139	3.4795 3.4793	0.0195		
	69		6.9106	2.7806	3.4793	0.0193		
	70		6.9663	2.8363	3.4795	0.0201		
	75		7.2079	2.8383	3.4878	0.0195		
	15		7.2019	5.0119	0.4070	0.0210		

7.3898

7.5333

7.651

7.543

6.3346

5.9392

5.7081

5.5506

5.4331

5.3398

5.2615

5.1956

5.1396

4.9418

4.8185

4.7307

4.6647

4.385

3.2598

3.4033

3.521

3.413

2.2046

1.8092

1.5781

1.4206

1.3031

1.2098

1.1315

1.0656

1.0096

0.8118

0.6885

0.6007

0.5347

0.255

3.4865

3.4868

3.4889

3.488

3.4896

3.4888

3.4893

3.4901

3.4914

3.491

3.4901

3.4912

3.4899

3.4913

3.4935

3.4939

3.4971

3.5111

0.0265

0.0268

0.0289

0.028

0.0296

0.0288

0.0293

0.0301

0.0314

0.031

0.0301

0.0312

0.0299


0.0313

0.0335

0.0339


0.0371

0.0511



Step Test PW1

Step	Q (igpm)	Q (m3/d)	dd (m)	dd/Q	SC	1/SC
1	10	65.44503	0.9603	0.014673	68.15061	0.014673
2	20	130.8901	2.0453	0.015626	63.99553	0.015626
3	30	196.3351	3.521	0.017934	55.76117	0.017934



Pumping Rate of 20 Igpm selected for 72 Hour Constant Rate Test



Pumping Test Data

Static Water Levels: PW1 = 3.563 m bgs OW1 = 2.895 m bgs


location: Murray Corner date: November 19 to 22, 2017


20 Igpm

Q =

		P	N 1	01	W1
		water level	drawdown	water level	drawdown
hours	Time (min)	(m)	(m)	(m)	(m)
	1	4.43	0.868	2.81	-0.088
	2	4.78	1.2171	2.81	-0.088
	3	4.96	1.4016	2.81	-0.088
	4	5.10	1.541	2.81	-0.088
	5	5.22	1.6614	2.81	-0.088
	6	5.30	1.7329	2.81	-0.088
	7	5.36	1.7954	2.81	-0.088
	8	5.43	1.8666	2.81	-0.088
	9	5.47	1.9028	2.81	-0.088
	10	5.50	1.9401	2.81	-0.088
	15	5.70	2.1414	2.81	-0.086
	20	5.81	2.248	2.81	-0.087
	25	5.93	2.362	2.81	-0.086
	30	6.00	2.4372	2.81	-0.085
	40	6.12	2.5584	2.81	-0.084
	50	6.22	2.6559	2.81	-0.082
1	60	6.30	2.7411	2.81	-0.082
	80	6.44	2.8795	2.82	-0.076
2	100	6.54	2.9745	2.82	-0.071
2	120	6.64	3.0782	2.83	-0.067
	140 160	6.71 6.78	3.1444 3.2177	2.83 2.84	-0.062 -0.054
3	180	6.81	3.2495	2.84	-0.054 -0.051
3	210	6.88	3.3139	2.84	-0.051
4	240	6.92	3.3588	2.86	-0.031
-	240	6.96	3.3978	2.86	-0.036
5	300	7.00	3.4394	2.86	-0.030
6	360	7.05	3.4872	2.87	-0.032
7	420	7.06	3.4961	2.87	-0.021
8	480	7.08	3.5166	2.87	-0.021
9	540	7.06	3.5	2.88	-0.012
10	600	7.08	3.515	2.90	0.001
11	660	7.12	3.5579	2.91	0.0129
12	720	7.18	3.6192	2.92	0.0278
13	780	7.28	3.7215	2.94	0.0437
14	840	7.35	3.7848	2.96	0.0647
15	900	7.40	3.8388	2.97	0.0739
16	960	7.45	3.8852	2.99	0.0934
17	1020	7.45	3.8853	3.00	0.104
18	1080	7.43	3.8645	3.00	0.109
19	1140	7.40	3.841	3.00	0.109
20	1200	7.36	3.7938	3.00	0.104


21	1260	7.30	3.741	3.00	0.104
22	1320	7.28	3.7171	2.98	0.0888
23	1380	7.28	3.7202	2.98	0.0888
24	1440	7.29	3.7315	2.98	0.0827
					0.0827
25	1500	7.60	4.041	2.99	
26	1560	7.68	4.1195	2.99	0.0979
27	1620	7.73	4.163	3.00	0.104
28 29	1680 1740	7.77 7.81	4.2068 4.2463	3.01	0.115 0.124
29 30	1800	7.80	4.2403	3.02 3.03	0.124
30 31	1860	7.81	4.249	3.03	0.135
32	1920	7.78	4.2209	3.03	0.138
33	1980	7.75	4.1907	3.04	0.14
34	2040	7.76	4.1927	3.04	0.141
35	2100	7.77	4.2071	3.04	0.144
36	2160	7.79	4.2265	3.05	0.159
37	2220	7.82	4.259	3.06	0.166
38	2280	7.88	4.3157	3.07	0.174
39	2340	7.92	4.3544	3.08	0.184
40	2400	7.85	4.2857	3.09	0.193
41	2460	8.07	4.5108	3.13	0.238
42	2520	8.09	4.5254	3.12	0.226
43	2580	8.08	4.5215	3.12	0.229
44	2640	8.05	4.4823	3.13	0.232
45	2700	8.06	4.5011	3.12	0.229
46	2760	8.06	4.4964	3.12	0.227
47	2820	8.22	4.655	3.12	0.227
48	2880	8.03	4.4696	3.12	0.226
49 50	2940	7.69	4.1261	3.12	0.223
50	3000	7.73	4.1658	3.15	0.253
51 52	3060 3120	7.74 7.74	4.1817 4.174	3.15 3.14	0.256 0.247
52 53	3120	7.74	4.174	3.14	0.247
53 54	3240	7.75	4.1897	3.14	0.230
55	3300	7.73	4.17	3.13	0.239
56	3360	7.69	4.1269	3.12	0.229
57	3420	7.66	4.1017	3.12	0.223
58	3480	7.62	4.0572	3.12	0.226
59	3540	7.62	4.0592	3.12	0.229
60	3600	7.66	4.1002	3.12	0.223
61	3660	7.73	4.1652	3.12	0.223
62	3720	7.79	4.2227	3.12	0.229
63	3780	7.86	4.292	3.13	0.238
64	3840	7.89	4.3286	3.15	0.259
65	3900	7.91	4.3438	3.16	0.269
66	3960	8.24	4.6783	3.18	0.287
67 68	4020	8.25	4.6884	3.15	0.25
68 60	4080	8.21	4.647	3.17	0.275
69 70	4140 4200	8.10 8.02	4.5333 4.4534	3.17 3.16	0.272 0.263
70 71	4200 4260	8.02 7.95	4.4534 4.3838	3.16	0.263
72	4200	7.95	4.3636 4.3607	3.15	0.25
14	7020	1.32	+.000 <i>1</i>	5.14	V.241





72 hr Pumping Test - PW1 Q = 131 m³/d (20 lgpm)

Water Level (m bgs)



72 hr Pumping Test - All Wells Q = 131 m³/d (20 lgpm)




Recovery Data

Static Water Levels: PW1 = 3.563 m bgs OW1 = 2.895 m bgs


location:	Murray Corner
date:	November 19 to 22, 2017

	Time since	Time since		PW1	residual	OW1	residual
	pump started	pump stopped	t/t'	Water Level	drawdown	Water Level	drawdown
hours	t (min)	ť (min)		(m)	s' (m)	(m)	s'
	0	0		3.563		2.895	
	4321	1	4321	7.15	3.59	3.15	0.253
	4322	2	2161	6.71	3.14	3.139	0.244
	4323	3	1441	6.48	2.92	3.139	0.244
	4324	4	1081	6.32	2.75	3.14	0.241
	4325	5	865	6.20	2.64	3.136	0.241
	4326	6	721	6.11	2.54	3.136	0.241
	4327	7	618	6.03	2.46	3.136	0.241
	4328	8	541	5.96	2.39	3.136	0.241
	4329	9	481	5.90	2.33	3.136	0.241
	4330	10	433	5.84	2.28	3.136	0.241
	4335	15	289	5.64	2.07	3.136	0.241
	4340	20	217	5.49	1.92	3.136	0.241
	4345	25	174	5.37	1.81	3.142	0.247
	4350	30	145	5.27	1.71	3.136	0.241
	4360	40	109	5.12	1.56	3.138	0.243
	4370	50	87	5.02	1.46	3.139	0.24
1	4380	60	73	4.92	1.35	3.138	0.24
	4400	80	55	4.77	1.21	3.133	0.24
	4420	100	44	4.66	1.10	3.129	0.23
2	4440	120	37	4.59	1.02	3.124	0.23
	4460	140	32	4.52	0.96	3.124	0.23
	4480	160	28	4.47	0.91	3.118	0.22
3	4500	180	25	4.42	0.86	3.118	0.22
	4530	210	22	4.38	0.81	3.026	0.13
4	4560	240	19	4.34	0.77	3.026	0.13
5	4620	300	15	4.28	0.72	2.935	0.04
6	4680	360	13	4.23	0.66	3.042	0.15
7	4740	420	11	4.17	0.61	3.036	0.14
8	4800	480	10	4.10	0.53	3.036	0.14
9	4860	540	9	4.01	0.45	3.036	0.14
10	4920	600	8	3.95	0.38	3.002	0.11
11	4980	660	8	3.91	0.35	2.978	0.08
12	5040	720	7	3.90	0.33	2.959	0.06
13	5100	780	7	3.89	0.33		
14	5160	840	6	3.92	0.36	2.938	0.04
15	5220	900	6	3.95	0.39	2.950	0.06
16	5280	960	6	3.98	0.42	2.941	0.05
17	5340	1020	5	3.98	0.41	2.944	0.05
18	5400	1080	5	3.96	0.40	2.947	0.05
19	5460	1140	5	3.96	0.40	2.944	0.05
20	5520	1200	5	3.93	0.37	2.944	0.05
21	5580	1260	4	3.905	0.34	2.944	0.05
22	5640	1320	4	3.8229	0.26	2.915	0.02
23	5700	1380	4	3.7149	0.15	2.890	-0.005
24	5760	1440	4	3.6331	0.07	2.865	-0.03
25	5820	1500	4	3.5832	0.02	2.853	-0.04
26	5880	1560	4	3.5315	-0.03	2.837	-0.06




PW1 Δs₁ = 0.70 m $T_{1 \text{ Rec}}$ = 2.3 Q = 34.22 m²/day 4πΔs

 $\Delta s_2 = 1.2 \text{ m}$ $T_{2 \text{ Rec}} = 2.3 \text{ Q} = 19.96 \text{ m}^2/\text{day}$ $4\pi\Delta s$



PW1 - Levelogger Temperature Readings (red)



APPENDIX E

Laboratory Certificates

Report/Rapport: 234480-MB Date: 12-May-17 Date Received/Reçu: 11-May-17

CERTIFICATE OF ANALYSIS / CERTIFICAT D'ANALYSE for/pour Strang Shore Camping Inc Linda Strang 89 Moore Rd Exten Otter Creek, NB E4M3V5 506-538-1015

rpc

150 Lutz St Moncton NB Canada E1C 5E9 Tel: 506.855.6472 Fax: 506.855.8294 www.rpc.ca

Project/Job #: HZ: 01, ST: 21, RN: 10 Location: EA327101 Examination of Water/Examen de l'eau

RPC Sample ID/No. d'échantilion de RPC): 			234480-1	
Client Sample ID/ID d'échantillon du clien	nt:			1639 Route 955	
				Little Shemogue	
				NB E4M3J5	
Date collected/Date du prélèvement:				10-May-17	
Time sampled/Heure du prélèvement:				8:45:00 AM	
Analytes/Paramètre(s)	Method Méthode	Date Analyzed Date Analysé	Units Unités		
Total Coliforms/Coliformes totaux	MB02	11-May-17	cfu/100mL	0	-
E. coli	MB02	11-May-17	cfu/100mL	0	-

This report relates only to the sample(s) and information provided to the laboratory.

Tests were performed according to the corresponding Compendium of Analytical Methods, Health Protection

Branch and/or AOAC Official Methods.

Le présent rapport ne s'applique qu'aux échantillons et à l'information transmis au laboratoire.

Les analyses ont été menées conformément au Compendium de méthodes pour l'analyse correspondant ou aux méthodes officielles

de la Direction générale de la protection de la santé ou de l'Association of Official Analytical Chemists (AOAC).

RL/SD = Reporting Limit/Seuil de déclaration cfu/ufc = Colony Forming Units/Unités formant des colonies

Nadine Godin Microbiology Supervisor Moncton Laboratory/Laboratoire de Moncton

SHANNON GARDNER Microbiology Technician Moncton Laboratory/Laboratoire de Moncton

Page 1 of/de 2

Report/Rapport: 234480-MB Date: 12-May-17 Date Received/Reçu: 11-May-17

CERTIFICATE OF ANALYSIS / CERTIFICAT D'ANALYSE

for/pour Strang Shore Camping Inc Linda Strang 89 Moore Rd Exten Otter Creek, NB E4M3V5 506-538-1015 rpc

150 Lutz St Moncton NB Canada E1C 5E9 Tel: 506.855.6472 Fax: 506.855.8294 www.rpc.ca

Project300 #. HZ: 01, 31. 21, KN. 10		
Location: EA327101		
Examination of Water/Examen de l'eau	3	
RPC Sample ID/No. d'échantillon de RPC:		234480-1
Client Sample ID/ID d'échantillon du client:		1639 Route 955
		Little Shemogue
		NB E4M3J5
Date collected/Date du prélèvement:		10-May-17
Time sampled/Heure du prélèvement:	- A(2)	8:45:00 AM

Acceptable/Acceptable

Project/ Job #: H7: 01 ST: 21 PN: 10

Coliforms (non-faecal) present. These bacteria are not by themselves considered harmful to human health. They do however indicate a possible route of contamination of a water supply. Further sampling or investigation is necessary to better understand the drinking water supply.

Coliformes (non fécaux) présents. Ces bacteries seules ne sont pas considérées comme nocives pour la santé des humains. Elles rélevents cependant un risque de contamination de la source d'approvisionnement en eau. Il faut prélever d'autres échantillons pour mieux comprendre la qualité de l'eau potable.

Unacceptable/Inacceptable

Contact Date \Date de contact Commen

Comments\Commentaires:

Authorization/Autorisation

Page 2 of/de 2

RPC Submission Reference: 234480

Strang Shore Camping Inc Linda Strang 89 Moore Rd Exten Otter Creek, NB E4M3V5 506-538-1015

Health Region: Moncton (01)Sample Type:Drilled Well (21)Reason:Accreditation / Licensing (10)



OFFICE OF THE CHIEF MEDICAL OFFICER OF HEALTH NEW BRUNSWICK DEPARTMENT OF HEALTH

INTERPRETATION OF BACTERIAL WATER TEST RESULTS

Water analysis done at the RPC Laboratory

The lab report will indicate if any **Total** coliform or **E-coli** bacteria were detected in your water sample. The box of the report shows the type and number of bacteria detected in 100 ml of water. The last column of this box shows the number of organisms detected or may have the letters **A** or **ND** indicating absent or none detected or, the letter **P** indicating a presence of the organism was detected. The end of the report will have a check mark indicating the microbiological safety of the water sample.

Results

Acceptable. If this line is checked off, this indicates the water is safe to drink.

Coliforms (non-faecal) present. If this line is checked off this indicates that there was a presence of Total coliform bacteria. Your water supply should be re-tested as soon as possible to determine if the Total coliform bacteria persist or if they were possibly introduced into the water sample at the time of sampling. (one coliform negative result after the presence of Total coliform is required to deem the water acceptable.)

Unacceptable. If this line is checked off, this indicates that:

- there were *E-coli* bacteria detected (bacteria that comes from the intestinal tract of humans and warm-blooded animals), or
- this is your first coliform negative result after a presence of E. coli. (two coliform negative results are required to deem the water acceptable after the presence of *E. coli*), or

 that this is the second consecutive water sample from your water supply showing the presence of Total coliform. <u>YOU SHOULD IMMEDIATELY BOIL</u> <u>DRINKING WATER AS PER THE ENCLOSED</u> <u>INFORMATION SHEET ON BOIL ADVISORIES</u>. In order to better understand the well water quality problem, you may wish to speak to a Public Health Inspector at your local Health Protection Branch.

NOTE : A single acceptable bacteriological report does not necessarily indicate that the water supply is always safe. It is recommended that private wells be tested for bacteria two times per year or after any event that may have contaminated the well or, if you detect a noticeable change in odor, color or taste of the water.

Because shallow wells, dug wells and springs have shallow protective soil cover over the water bearing formation, these types of water supplies are much more vulnerable to surface water infiltration than drilled wells. Regardless of the bacteria test results, this type of water supply is more at risk of being contaminated by microorganisms and consideration should be given to replacing these systems with properly constructed drilled wells or installing appropriate water treatment devices

If you have any questions or would like additional information, please contact a Public Health Inspector at 506-856-2814.

S:\Protection de la santé Nord\Campbellton\Water Log\Water\Interpretation des résultats de test d'eau - Français + Anglais



BUREAU DU MÉDECIN-HYGIÉNISTE EN CHEF MINISTÈRE DE LA SANTÉ DU NOUVEAU-BRUNSWICK

INTERPRÉTATION DES RÉSULTATS DES ESSAIS BACTÉRIOLOGIQUES Analyse de l'eau effectuée au laboratoire de RPC

Le rapport de laboratoire indiquera s'il y a présence de coliformes **totaux** ou de la bactérie *E. coli* dans votre échantillon d'eau. La boîte du rapport indique le type et le nombre de bactéries détectées dans une quantité de 100 ml d'eau. La dernière colonne de cette boîte indique le nombre d'organismes détectés ou pourrait porter les lettres A ou ND indiquant qu'il y absence d'organismes ou qu'aucun organisme n'a été détecté ou encore la lettre **P** indiquant la présence d'organismes. La fin du rapport portera un crochet indiquant la sécurité microbiologique de l'échantillon d'eau.

Résultats

Acceptable. Si cette ligne est cochée, l'eau est potable.

Coliformes (non fécaux) présents. Si cette ligne est cochée, des bactéries de coliformes totaux ont été détectées. Votre source d'approvisionnement en eau devrait être vérifiée à nouveau dès que possible afin de déterminer si les bactéries de coliformes totaux persistent ou si elles ont pu être introduites dans l'échantillon d'eau au moment de l'échantillonnage. (Il faut obtenir un résultat négatif pour les coliformes après que des coliformes totaux aient été détectés pour que l'eau soit jugée acceptable.)

Inacceptable. Si cette ligne est cochée :

- des bactéries *E. coli* ont été détectées (bactéries qui vivent seulement dans le tractus intestinal des humains et des animaux à sang chaud);
- c'est votre premier résultat négatif pour les coliformes après que la bactérie *E. coli* ait été détectée (Il faut obtenir deux résultats négatifs pour les coliformes après que la bactérie *E. coli* ait été détectée pour que l'eau soit jugée acceptable.);
- il s'agit du second échantillon d'eau consécutif de votre source d'approvisionnement en eau indiquant la présence de coliformes totaux. <u>VOUS DEVRIEZ</u> <u>IMMÉDIATEMENT FAIRE BOUILLIR L'EAU DE CONSOMMATION</u> <u>CONFORMÉMENT AU FEUILLET D'INFORMATION CI-ANNEXÉ</u> <u>CONCERNANT L'AVIS DE SÉCURITÉ.</u> Afin de mieux comprendre le problème quant à la qualité de l'eau de puits, vous devriez parler à un inspecteur de la santé publique au bureau local de la Protection de la santé.

NOTE : Un seul résultat acceptable aux essais bactériologiques n'indique pas nécessairement que la source d'approvisionnement en eau est toujours sécuritaire. Il est recommandé que les puits privés fassent l'objet d'une épreuve bactériologique deux fois par année ou après chaque situation qui aurait pu contaminer le puits ou encore si vous détectez un changement notable de l'odeur, de la couleur ou du goût de l'eau.

Étant donné que les puits peu profonds, les puits creusés et les sources naturelles n'ont qu'une mince couverture de sol protecteur au-dessus de la couche aquifère, ces types d'approvisionnement en eau sont plus vulnérables à l'infiltration des eaux de surface que les puits forés à la sondeuse. Peu importe les résultats des essais bactériologiques, ce type d'approvisionnement en eau est plus à risque d'être contaminé par les micro-organismes. Il faudrait envisager de remplacer ces systèmes par des puits forés bien aménagés ou d'installer des dispositifs de traitement de l'eau appropriés.

Si vous avez des questions ou si vous désirez de plus amples renseignements, veuillez communiquer avec un inspecteur de la santé publique au 506-856-2814.

S:\Protection de la santé Nord\Campbellton\Water Log\Water\Interpretation des résultats de test d'eau - Français + Anglais



CLIENT NAME: ROY CONSULTANTS 548 KING AVE BATHURST, NB E2A 4Z1 506-546-4484

ATTENTION TO: GINA BURTT

PROJECT: 278-17

AGAT WORK ORDER: 17X286210

MICROBIOLOGY ANALYSIS REVIEWED BY: Laura Baker, Inorganics Data Reporter

WATER ANALYSIS REVIEWED BY: Jason Coughtrey, Inorganics Supervisor

DATE REPORTED: Nov 30, 2017

PAGES (INCLUDING COVER): 11

VERSION*: 1

Should you require any information regarding this analysis please contact your client services representative at (902) 468-8718

*NOTES	

All samples will be disposed of within 30 days following analysis. Please contact the lab if you require additional sample storage time.

AGAT Laboratories (V1)

Member of: Association of Professional Engineers and Geoscientists of Alberta (APEGA) Western Enviro-Agricultural Laboratory Association (WEALA) Environmental Services Association of Alberta (ESAA) AGAT Laboratories is accredited to ISO/IEC 17025 by the Canadian Association for Laboratory Accreditation Inc. (CALA) and/or Standards Council of Canada (SCC) for specific tests listed on the scope of accreditation. AGAT Laboratories (Mississauga) is also accredited by the Canadian Association for Laboratory Accreditation Inc. (CALA) for specific drinking water tests. Accreditations are location and parameter specific. A complete listing of parameters for each location is available from www.cala.ca and/or www.scc.ca. The tests in this report may not necessarily be included in the scope of accreditation.

Page 1 of 11

Results relate only to the items tested and to all the items tested All reportable information as specified by ISO 17025:2005 is available from AGAT Laboratories upon request



AGAT WORK ORDER: 17X286210 PROJECT: 278-17

CLIENT NAME: ROY CONSULTANTS

SAMPLING SITE:

DATE RECEIVED: 2017-11-21

ATTENTION TO: GINA BURTT

SAMPLED BY:

	Total Coliforms and E.coli (MPN)	
		DATE REPORTED: 2017-11-22
SAMDI E DESCRIPTION.		

	SA	MPLE DES	CRIPTION:	PW-1 24 Hr
		SAM	PLE TYPE:	Water
		DATE	SAMPLED:	2017-11-20
Parameter	Unit	G/S	RDL	8921784
Total Coliforms (MPN)	MPN/100 mL		1	ABSENT
E. Coli (MPN)	MPN/100 mL		1	ABSENT

Comments: RDL - Reported Detection Limit; G / S - Guideline / Standard

Certified By:

Laura Balu

11 Morris Drive, Unit 122 Dartmouth, Nova Scotia CANADA B3B 1M2 TEL (902)468-8718 FAX (902)468-8924 http://www.agatlabs.com



AGAT WORK ORDER: 17X286210 PROJECT: 278-17

CLIENT NAME: ROY CONSULTANTS

SAMPLING SITE:

ATTENTION TO: GINA BURTT

SAMPLED BY:

MTL - TOC in Water DATE RECEIVED: 2017-11-21 **DATE REPORTED: 2017-11-27** SAMPLE DESCRIPTION: PW-1 24 Hr SAMPLE TYPE: Water DATE SAMPLED: 2017-11-20 Unit G/S RDL 8921784 Parameter Total Organic Carbon mg/L 0.5 <0.5

Comments: RDL - Reported Detection Limit; G / S - Guideline / Standard

8921784 TOC analysed at AGAT Montreal.

Certified By:

Jason Coto

11 Morris Drive, Unit 122 Dartmouth, Nova Scotia CANADA B3B 1M2 TEL (902)468-8718 FAX (902)468-8924 http://www.agatlabs.com



AGAT WORK ORDER: 17X286210 PROJECT: 278-17

CLIENT NAME: ROY CONSULTANTS

SAMPLING SITE:

ATTENTION TO: GINA BURTT

SAMPLED BY:

Standard Water Analysis + Dissolved Metals

DATE RECEIVED: 2017-11-21			
	SA	AMPLE DESCRIPTION:	PW-1 24 Hr
		SAMPLE TYPE:	Water
Parameter	Unit	DATE SAMPLED: G/S RDL	2017-11-20 8921784
pH	Onit	G/S KDL	8.01
Reactive Silica as SiO2	mg/L	0.5	10.8
Chloride	mg/L	1	24
Fluoride	mg/L	0.12	<0.12
Sulphate	mg/L	2	7
Alkalinity	mg/L	5	117
True Color	тси	5	6
Turbidity	NTU	0.1	0.5
Electrical Conductivity	umho/cm	1	332
Nitrate + Nitrite as N	mg/L	0.05	1.88
Nitrate as N	mg/L	0.05	1.88
Nitrite as N	mg/L	0.05	<0.05
Ammonia as N	mg/L	0.03	0.03
Ortho-Phosphate as P	mg/L	0.01	<0.01
Dissolved Sodium	mg/L	0.1	17.3
Dissolved Potassium	mg/L	0.1	1.6
Dissolved Calcium	mg/L	0.1	44.7
Dissolved Magnesium	mg/L	0.1	3.9
Bicarb. Alkalinity (as CaCO3)	mg/L	5	117
Carb. Alkalinity (as CaCO3)	mg/L	10	<10
Hydroxide	mg/L	5	<5
Calculated TDS	mg/L	1	177
Hardness	mg/L		128
Langelier Index (@20C)	NA		0.12
Langelier Index (@ 4C)	NA		-0.20
Saturation pH (@ 20C)	NA		7.89
Saturation pH (@ 4C)	NA		8.21
Anion Sum	me/L		3.30
Cation sum	me/L		3.35
% Difference/ Ion Balance (NS)	%		0.8

Certified By:

11 Morris Drive, Unit 122 Dartmouth, Nova Scotia CANADA B3B 1M2 TEL (902)468-8718 FAX (902)468-8924 http://www.agatlabs.com



AGAT WORK ORDER: 17X286210 **PROJECT: 278-17**

CLIENT NAME: ROY CONSULTANTS

SAMPLING SITE:

ATTENTION TO: GINA BURTT

SAMPLED BY:

Standard Water Analysis + Dissolved Metals

CANADA B3B 1M2 TEL (902)468-8718 FAX (902)468-8924 http://www.agatlabs.com

11 Morris Drive, Unit 122

Dartmouth, Nova Scotia

DATE RECEIVED: 2017-11-21				DATE REPORTED: 2017-11-27
	S	AMPLE DESCRIPTION:	PW-1 24 Hr	
		SAMPLE TYPE:	Water	
		DATE SAMPLED:	2017-11-20	
Parameter	Unit	G/S RDL	8921784	
Dissolved Aluminum	ug/L	5	<5	
Dissolved Antimony	ug/L	2	<2	
Dissolved Arsenic	ug/L	2	<2	
Dissolved Barium	ug/L	5	431	
Dissolved Beryllium	ug/L	2	<2	
Dissolved Bismuth	ug/L	2	<2	
Dissolved Boron	ug/L	5	34	
Dissolved Cadmium	ug/L	0.017	<0.017	
Dissolved Chromium	ug/L	1	3	
Dissolved Cobalt	ug/L	1	<1	
Dissolved Copper	ug/L	2	<2	
Dissolved Iron	ug/L	50	<50	
Dissolved Lead	ug/L	0.5	<0.5	
Dissolved Manganese	ug/L	2	72	
Dissolved Molybdenum	ug/L	2	<2	
Dissolved Nickel	ug/L	2	<2	
Dissolved Phosphorus	mg/L	0.02	<0.02	
Dissolved Selenium	ug/L	1	<1	
Dissolved Silver	ug/L	0.1	<0.1	
Dissolved Strontium	ug/L	5	633	
Dissolved Thallium	ug/L	0.1	<0.1	
Dissolved Tin	ug/L	2	<2	
Dissolved Titanium	ug/L	2	<2	
Dissolved Uranium	ug/L	0.1	2.3	
Dissolved Vanadium	ug/L	2	4	
Dissolved Zinc	ug/L	5	8	

RDL - Reported Detection Limit; G / S - Guideline / Standard Comments:

8921784 Metals analysis completed on a filtered sample.

Certified By:

Jason Court



Page 6 of 11

Quality Assurance

CLIENT NAME: ROY CONSULTANTS

PROJECT: 278-17

SAMPLING SITE:

AGAT WORK ORDER: 17X286210 ATTENTION TO: GINA BURTT SAMPLED BY:

Water Analysis

				vvate		laiys	5								
RPT Date:			D	UPLICATE	E		REFEREN	ICE MA	TERIAL	METHOD	BLANK	SPIKE	МАТ	RIX SPI	KE
PARAMETER	Batch	Sample	Dup #1	Dup #2	RPD	Method Blank	Measured		ptable nits	Recovery	Acceptable Limits		Recovery		ptable nits
PARAMETER	Batch	ld	Dup #1	Dup #2	RPD		Value			Recovery	Lower	Upper	Recovery	Lower	Upper
Standard Water Analysis + Dise	solved Metals														
pH	8921196		6.65	6.63	0.3%	<	102%	80%	120%	NA	80%	120%	NA	80%	120%
Reactive Silica as SiO2	1 89	21784	10.8	10.8	0.0%	< 0.5	105%	80%	120%		80%	120%	84%	80%	120%
Chloride	8921780		60	61	0.8%	< 1	97%	80%	120%	NA	80%	120%	NA	80%	120%
Fluoride	8921780		0.28	0.31	NA	< 0.12	112%	80%	120%	NA	80%	120%	97%	80%	120%
Sulphate	8921780		3	3	NA	< 2	110%	80%	120%	NA	80%	120%	96%	80%	120%
Alkalinity	8921196		94	93	0.8%	< 5	101%	80%	120%	NA	80%	120%	NA	80%	120%
True Color	8921202		11	13	NA	< 5	120%	80%	120%	NA			NA		
Turbidity	8921202		22.9	23.2	1.3%	< 0.1	99%	80%	120%	NA			NA		
Electrical Conductivity	8921196		3820	3810	0.3%	< 1	103%	80%	120%	NA	80%	120%	NA	80%	120%
Nitrate as N	8921780		<0.05	<0.05	NA	< 0.05	98%	80%	120%	NA	80%	120%	90%	80%	120%
Nitrite as N	8921780		0.08	0.09	NA	< 0.05	95%	80%	120%	NA	80%	120%	108%	80%	120%
Ammonia as N	1 89	16528	0.04	0.06	NA	< 0.03	115%	80%	120%		80%	120%	118%	80%	120%
Ortho-Phosphate as P	1 89	21784	<0.01	<0.01	NA	< 0.01	91%	80%	120%		80%	120%	116%	80%	120%
Dissolved Sodium	8921784 89	21784	17.3	15.7	9.4%	< 0.1	107%	80%	120%	104%	80%	120%	NA	70%	130%
Dissolved Potassium	8921784 89	21784	1.6	1.7	5.1%	< 0.1	108%	80%	120%	102%	80%	120%	NA	70%	130%
Dissolved Calcium	8921784 89	21784	44.7	42.0	6.2%	< 0.1	105%	80%	120%	102%	80%	120%	NA	70%	130%
Dissolved Magnesium	8921784 89	21784	3.9	3.9	0.5%	< 0.1	106%	80%	120%	103%	80%	120%	NA	70%	130%
Bicarb. Alkalinity (as CaCO3)	8921196		94	93	0.8%	< 5	NA	80%	120%	NA	80%	120%	NA	80%	120%
Carb. Alkalinity (as CaCO3)	8921196		<10	<10	NA	< 10	NA	80%	120%	NA	80%	120%	NA	80%	120%
Hydroxide	8921196		<5	<5	NA	< 5	NA	80%	120%	NA	80%	120%	NA	80%	120%
Dissolved Aluminum	8921784 89	21784	<5	<5	NA	< 5	103%	80%	120%	103%	80%	120%	94%	70%	130%
Dissolved Antimony	8921784 89	21784	<2	<2	NA	< 2	93%	80%	120%	100%	80%	120%	103%	70%	130%
Dissolved Arsenic	8921784 89	21784	<2	<2	NA	< 2	98%	80%	120%	97%	80%	120%	105%	70%	130%
Dissolved Barium	8921784 89	21784	431	419	2.8%	< 5	100%	80%	120%	101%	80%	120%	NA	70%	130%
Dissolved Beryllium	8921784 89	21784	<2	<2	NA	< 2	107%	80%	120%	107%	80%	120%	115%	70%	130%
Dissolved Bismuth	8921784 89	21784	<2	<2	NA	< 2	106%	80%	120%	110%	80%	120%	NA	70%	130%
Dissolved Boron	8921784 89	21784	34	34	0.3%	< 5	104%	80%	120%	96%	80%	120%	105%	70%	130%
Dissolved Cadmium	8921784 89	21784	<0.017	<0.017	NA	< 0.017	99%	80%	120%	98%	80%	120%	102%	70%	130%
Dissolved Chromium	8921784 89	21784	3	3	NA	< 1	95%	80%	120%	91%	80%	120%	89%	70%	130%
Dissolved Cobalt	8921784 89	21784	<1	<1	NA	< 1	98%	80%	120%	97%	80%	120%	95%	70%	130%
Dissolved Copper	8921784 89	21784	<2	<2	NA	< 2	100%	80%	120%	102%	80%	120%	100%	70%	130%
Dissolved Iron	8921784 89	21784	<50	<50	NA	< 50	94%	80%	120%	94%	80%	120%	76%	70%	130%
Dissolved Lead	8921784 89	21784	<0.5	<0.5	NA	< 0.5	104%	80%	120%	103%	80%	120%	97%	70%	130%
Dissolved Manganese	8921784 89	21784	72	72	0.0%	< 2	96%	80%	120%	94%	80%	120%	NA	70%	130%
Dissolved Molybdenum	8921784 89	21784	<2	<2	NA	< 2	95%	80%	120%	95%	80%	120%	84%	70%	130%
Dissolved Nickel	8921784 89	21784	<2	<2	NA	< 2	98%	80%	120%	97%	80%	120%	101%	70%	130%
Dissolved Phosphorus	8921784 89	21784	<0.02	<0.02	NA	< 0.02	101%	80%	120%	104%	80%	120%	71%	70%	130%
Dissolved Selenium	8921784 89	21784	<1	<1	NA	< 1	99%	80%	120%	98%	80%	120%	102%	70%	130%
Dissolved Silver	8921784 89	21784	<0.1	<0.1	NA	< 0.1	99%	80%	120%	102%	80%	120%	95%	70%	130%

AGAT QUALITY ASSURANCE REPORT (V1)

AGAT Laboratories is accredited to ISO/IEC 17025 by the Canadian Association for Laboratory Accreditation Inc. (CALA) and/or Standards Council of Canada (SCC) for specific tests listed on the scope of accreditation. AGAT Laboratories (Mississauga) is also accredited by the Canadian Association for Laboratory Accreditation Inc. (CALA) for specific drinking water tests. Accreditations are location and parameter specific. A complete listing of parameters for each location is available from www.cala.ca and/or www.scc.ca. The tests in this report may not necessarily be included in the scope of accreditation.



Quality Assurance

CLIENT NAME: ROY CONSULTANTS

PROJECT: 278-17

SAMPLING SITE:

AGAT WORK ORDER: 17X286210 ATTENTION TO: GINA BURTT SAMPLED BY:

Water Analysis (Continued)

						REFEREN			METHOD BLANK SPIKE			MATRIX SPIKE		
Batch	Sample	Dup #1	Dup #2	RPD	Method Blank	Measured	Acceptable Limits		Recovery	Acceptable Limits		Recoverv	Acceptable Limits	
	Ia	•				value	Lower	Upper		Lower	Upper		Lower	Upper
8921784	8921784	633	599	5.5%	< 5	94%	80%	120%	91%	80%	120%	NA	70%	130%
8921784	8921784	<0.1	<0.1	NA	< 0.1	106%	80%	120%	109%	80%	120%	106%	70%	130%
8921784	8921784	<2	<2	NA	< 2	98%	80%	120%	98%	80%	120%	90%	70%	130%
8921784	8921784	<2	<2	NA	< 2	104%	80%	120%	103%	80%	120%	89%	70%	130%
8921784	8921784	2.3	2.3	2.8%	< 0.1	104%	80%	120%	105%	80%	120%	NA	70%	130%
8921784	8921784	4	4	NA	< 2	92%	80%	120%	92%	80%	120%	101%	70%	130%
8921784	8921784	8	7	NA	< 5	97%	80%	120%	101%	80%	120%	116%	70%	130%
	8921784 8921784 8921784 8921784 8921784 8921784 8921784	Ld 8921784 8921784 8921784 8921784 8921784 8921784 8921784 8921784 8921784 8921784 8921784 8921784 8921784 8921784 8921784 8921784 8921784 8921784 8921784 8921784 8921784 8921784	Id Id 8921784 8921784 633 8921784 8921784 <0.1	Id I 8921784 8921784 633 599 8921784 8921784 <0.1	Id I I 8921784 8921784 633 599 5.5% 8921784 8921784 <0.1	Id I I 8921784 8921784 633 599 5.5% < 5	Id I I Value 8921784 8921784 633 599 5.5% < 5	Id I Value Lower 8921784 8921784 633 599 5.5% < 5	Id I	Id I	Id I	Id I	Id I	Id I I Value Lower Upper Lower Lower Lower Upper Lower Lower

Comments: If RPD value is NA, the results of the duplicates are less than 5x the RDL and the RPD will not be calculated.

MTL - TOC in Water											
Total Organic Carbon	2	NA	NA	NA	< 0.5	NA	80% 120%	92%	80% 120%	NA	80% 120%

Certified By:

Jasa Cought νų

AGAT QUALITY ASSURANCE REPORT (V1)

Page 7 of 11

AGAT Laboratories is accredited to ISO/IEC 17025 by the Canadian Association for Laboratory Accreditation Inc. (CALA) and/or Standards Council of Canada (SCC) for specific tests listed on the scope of accreditation. AGAT Laboratories (Mississauga) is also accredited by the Canadian Association for Laboratory Accreditation Inc. (CALA) for specific drinking water tests. Accreditations are location and parameter specific. A complete listing of parameters for each location is available from www.cala.ca and/or www.scc.ca. The tests in this report may not necessarily be included in the scope of accreditation.



Method Summary

CLIENT NAME: ROY CONSULTANTS

PROJECT: 278-17

AGAT WORK ORDER: 17X286210

ATTENTION TO: GINA BURTT

SAMPLING SITE:	SAMPLED BY:				
PARAMETER	AGAT S.O.P	LITERATURE REFERENCE	ANALYTICAL TECHNIQUE		
Microbiology Analysis	L	L			
Total Coliforms (MPN)	MIC-121-7000	Based on SM 9223B	INCUBATOR		
E. Coli (MPN)	MIC-121-7000	Based on SM 9223B	INCUBATOR		



Method Summary

CLIENT NAME: ROY CONSULTANTS

PROJECT: 278-17

AGAT WORK ORDER: 17X286210 ATTENTION TO: GINA BURTT

SAMDUNC SITE		SAMPLED DV.					
SAMPLING SITE:		SAMPLED BY:					
PARAMETER	AGAT S.O.P	LITERATURE REFERENCE	ANALYTICAL TECHNIQUE				
Water Analysis			- 4				
Total Organic Carbon	INOR-101-6049F	MA.300-C1.0	DÉTECTION INFRAROUGE				
рН	INOR-121-6001	SM 4500 H+B	PC TITRATE				
Reactive Silica as SiO2	INORG-121-6028	SM 4110 B	COLORIMETER				
Chloride	INORG-121-6005	SM 4110 B	ION CHROMATOGRAPH				
Fluoride	INORG-121-6005	SM 4110 B	ION CHROMATOGRAPH				
Sulphate	INORG-121-6005	SM 4110 B	ION CHROMATOGRAPH				
Alkalinity	INOR-121-6001	SM 2320 B					
True Color	INORG-121-6014	EPA 110.2	NEPHELOMETER				
Turbidity	INOR-121-6022	SM 2130 B	NEPHELOMETER				
Electrical Conductivity	INOR-121-6001	SM 2510 B	PC TITRATE				
Nitrate + Nitrite as N	INORG-121-6005	SM 4110 B	CALCULATION				
Nitrate as N	INORG-121-6005	SM 4110 B	ION CHROMATOGRAPH				
Nitrite as N	INORG-121-6005	SM 4110 B	ION CHROMATOGRAPH				
Ammonia as N	INORG-121-6003	SM 4500-NH3 G	COLORIMETER				
Ortho-Phosphate as P	INORG-121-6005	SM 4110 B	COLORIMETER				
Dissolved Sodium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS				
Dissolved Potassium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS				
Dissolved Calcium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS				
Dissolved Magnesium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS				
Bicarb. Alkalinity (as CaCO3)	INORG-121-6001	SM 2320 B	PC TITRATE				
Carb. Alkalinity (as CaCO3)	INORG-121-6001	SM 2320 B	PC TITRATE				
Hydroxide	INORG-121-6001	SM 2320 B	PC-TITRATE				
Calculated TDS	CALCULATION	SM 1030E	CALCULATION				
Hardness	CALCULATION	SM 2340B	CALCULATION				
Langelier Index (@20C)	CALCULATION	CALCULATION	CALCULATION				
Langelier Index (@ 4C)	CALCULATION	CALCULATION	CALCULATION				
Saturation pH (@ 20C)	CALCULATION	CALCULATION	CALCULATION				
Saturation pH (@ 4C)	CALCULATION	CALCULATION	CALCULATION				
Anion Sum	CALCULATION	SM 1030E	CALCULATION				
Cation sum	CALCULATION	SM 1030E	CALCULATION				
% Difference/ Ion Balance (NS)	CALCULATION	SM 1030E	CALCULATION				
Dissolved Aluminum	MET121-6104 & MET-121-6105	SM 3125	ICP-MS				
Dissolved Antimony	MET121-6104 & MET-121-6105	SM 3125	ICP-MS				
Dissolved Arsenic	MET121-6104 & MET-121-6105	SM 3125	ICP-MS				
Dissolved Barium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS				
Dissolved Beryllium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS				
Dissolved Bismuth	MET121-6104 & MET-121-6105	SM 3125	ICP-MS				
Dissolved Boron	MET121-6104 & MET-121-6105	SM 3125	ICP-MS				
Dissolved Cadmium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS				



Method Summary

		5									
CLIENT NAME: ROY CONSULTANTS		AGAT WORK ORDER: 17X286210									
PROJECT: 278-17		ATTENTION TO:	GINA BURTT								
SAMPLING SITE:		SAMPLED BY:									
PARAMETER	AGAT S.O.P	LITERATURE REFERENCE	ANALYTICAL TECHNIQUE								
Dissolved Chromium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS								
Dissolved Cobalt	MET121-6104 & MET-121-6105	SM 3125	ICP-MS								
Dissolved Copper	MET121-6104 & MET-121-6105	SM 3125	ICP-MS								
Dissolved Iron	MET121-6104 & MET-121-6105	SM 3125	ICP-MS								
Dissolved Lead	MET121-6104 & MET-121-6105	SM 3125	ICP-MS								
Dissolved Manganese	MET121-6104 & MET-121-6105	SM 3125	ICP-MS								
Dissolved Molybdenum	MET121-6104 & MET-121-6105	SM 3125	ICP-MS								
Dissolved Nickel	MET121-6104 & MET-121-6105	SM 3125	ICP-MS								
Dissolved Phosphorus	MET-121-6104 & MET-121-6105	SM 3125	ICP-MS								
Dissolved Selenium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS								
Dissolved Silver	MET121-6104 & MET-121-6105	SM 3125	ICP-MS								
Dissolved Strontium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS								
Dissolved Thallium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS								
Dissolved Tin	MET121-6104 & MET-121-6105	SM 3125	ICP-MS								
Dissolved Titanium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS								
Dissolved Uranium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS								
Dissolved Vanadium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS								
Dissolved Zinc	MET121-6104 & MET-121-6105	SM 3125	ICP-MS								

Chain of Custor		Γı	_abora	wobeartii,			Unit : s.com	- W1	Da ww.a	artmo B gatia	outh 3B 1 abs.c	NS M2	Ai Ai H	rival rival	l Ten Time	nditi nper :	on: atur	re:	Go	od			_		s)
Report Information	ay needra		Denert						_	-		_													
				nformation (Please print):					Rep	ort	Forn	nat			16	\mathcal{O}	n	1-	n	np	N				
Address: 364 Yar	Company: Roy Consultants Contact: Gina Burtt Address: 364 York St Site 201 Fredericton NB E3B 3P7			Multiple Samples						Turnaround Time Required (TAT)															
			a strength of the strength of the strength of the	goramile (croy can	5-11	or	s.ar			Includ		11	R	ush '	TAT			3am	e da	y []10	day			
Phone: <u>Sole 470</u> Client Project #: 2	18-17			ory Requirements (Check): uidelines on Report Do not lie	st Guid	elines	s on Repo	ort		Export			Da	ate R	leaui			2 da <u>y</u>	2	[]3 c	lays			
AGAT Quotation:	1490 1	II aniaa faa aaala		1 Res Pot			Coarse					_													
Please Note. If quotation number is			Tier	2 Com N/Pc	ot				Drink	king V	Vater	San	nple:	🗌 Ye	es [∃No		Sal	t Wat	ter Sa	mple	; 🗆	Yes		No
Invoice To	Same	Yes 🛛 / No	🗌 🗌 Gas	; 🗌 Fuel 🗌 Lube					Reg.	No.:							_								_
				□ CDWQ ustrial □ NSEQS-Cont Sites			able														AF				
				nmercial 🗌 HRM 101			□ Available					- 1										μR			
Address:				Storm Water			1 1		4	vss				natic						1	Z ve	8			
Phone:	Fax:			AL Waste water	eserved	Analysis	XDiss	6	CROD			0			TPH/BTEX					14.1	P/A X MPN	MPN			
PO/Credit Card#:					ed/Pr	Vater	otal		5	D TDS		ohoru	/RTE)	/BTE	TPH						Pse				N/W
Sample Identification	Date/Time Sampled	Sample Matrix	# Containers	Comments - Site/Sample Info. Sample Containment	Field Filtered/Preserved	Standard Water Analysis	Metals: Total Mercinor		H H		TKN	Total Phosphorus	Phenols Tier 1. TPH/RTFX (PIRI)	Tier 2: TPH	CCME-CWS 1	VOC	THM	HAA	PAH	1		0	Other:	Other:	Hazardous (Y/N)
Pw-124h-	20/11/7, 14:30	Water	3	Murray Corner		X	X														X	1			
TI+F(Pression				+	_		_	_	-		+	_	-	+	-	-			_	_				
TC+EC Matak	preserved				+	\vdash						-	-		-		-	-		-	+	+-	-	\vdash	_
1.000	1.2					1						-			1		1				+			\rightarrow	
																						-	-		
										-															
						_																			
					-	-		-	-	-	_	_	_	1	_	-									
					-	<u> </u>		-	_		_		_	-	-	-				_		_			
Samples Relinguished By (Print Name):		Date/T	imo, , , , , , , , , , , , , , , , , , ,	Samples Received By (Print Nome):	_					Da	te/Time			4		-									
Abram Les	2	20 Date/T	1117 1545		d	2				1	21	-1	DV		Pink Yellov					Page	• 	o	f		
Samples Rollinguished By (Sign):		Sor	re	Samples Received By (Sign):	0	e.	(d				08	5.0	25		Whit				Nº:	5	74	.57	2		



CLIENT NAME: ROY CONSULTANTS 548 KING AVE BATHURST, NB E2A 4Z1 506-546-4484

ATTENTION TO: GINA BURTT

PROJECT:

AGAT WORK ORDER: 17X286678

MICROBIOLOGY ANALYSIS REVIEWED BY: Laura Baker, Inorganics Data Reporter

WATER ANALYSIS REVIEWED BY: Laura Baker, Inorganics Data Reporter

DATE REPORTED: Nov 29, 2017

PAGES (INCLUDING COVER): 11

VERSION*: 1

Should you require any information regarding this analysis please contact your client services representative at (902) 468-8718

<u>*NOTES</u>	

All samples will be disposed of within 30 days following analysis. Please contact the lab if you require additional sample storage time.

AGAT Laboratories (V1)

Member of: Association of Professional Engineers and Geoscientists of Alberta (APEGA) Western Enviro-Agricultural Laboratory Association (WEALA) Environmental Services Association of Alberta (ESAA)

AGAT Laboratories is accredited to ISO/IEC 17025 by the Canadian Association for Laboratory Accreditation Inc. (CALA) and/or Standards Council of Canada (SCC) for specific tests listed on the scope of accreditation. AGAT Laboratories (Mississauga) is also accredited by the Canadian Association for Laboratory Accreditation Inc. (CALA) for specific drinking water tests. Accreditations are location and parameter specific. A complete listing of parameters for each location is available from www.cala.ca and/or www.scc.ca. The tests in this report may not necessarily be included in the scope of accreditation.

Page 1 of 11

Results relate only to the items tested and to all the items tested

All reportable information as specified by ISO 17025:2005 is available from AGAT Laboratories upon request



AGAT WORK ORDER: 17X286678 PROJECT:

CLIENT NAME: ROY CONSULTANTS

SAMPLING SITE:

ATTENTION TO: GINA BURTT

SAMPLED BY:

				Total Co	liforms and E.coli (MPN)
DATE RECEIVED: 2017-11-22					DATE REPORTED: 2017-11-29
	SA	MPLE DES	CRIPTION:	PW-1 48hr	
		SAM	PLE TYPE:	Water	
		DATE	SAMPLED:	2017-11-21	
Parameter	Unit	G/S	RDL	8924691	
Total Coliforms (MPN)	MPN/100 mL		1	<1	
E. Coli (MPN)	MPN/100 mL		1	<1	

Comments: RDL - Reported Detection Limit; G / S - Guideline / Standard

Certified By:

Lauro Balu

11 Morris Drive, Unit 122

Dartmouth, Nova Scotia

http://www.agatlabs.com

CANADA B3B 1M2

TEL (902)468-8718 FAX (902)468-8924



AGAT WORK ORDER: 17X286678 PROJECT:

CLIENT NAME: ROY CONSULTANTS

SAMPLING SITE:

ATTENTION TO: GINA BURTT

SAMPLED BY:

11 Morris Drive, Unit 122 Dartmouth, Nova Scotia CANADA B3B 1M2 TEL (902)468-8718 FAX (902)468-8924 http://www.agatlabs.com

MTL - TOC in Water DATE RECEIVED: 2017-11-22 **DATE REPORTED: 2017-11-29** SAMPLE DESCRIPTION: PW-1 48hr SAMPLE TYPE: Water

		DATE	SAMPLED:	2017-11-21
Parameter	Unit	G/S	RDL	8924691
Total Organic Carbon	mg/L		0.5	<0.5

Comments: RDL - Reported Detection Limit; G / S - Guideline / Standard

8924691 TOC analysed at AGAT Montreal.

Certified By:

Laura Balu



AGAT WORK ORDER: 17X286678 PROJECT:

CLIENT NAME: ROY CONSULTANTS

SAMPLING SITE:

ATTENTION TO: GINA BURTT

SAMPLED BY:

Standard Water Analysis + Dissolved Metals

DATE RECEIVED: 2017-11-22

DATE RECEIVED: 2017-11-22				DATE REPORTED: 2017-11-29
	SA	MPLE DESCRIPTION:	PW-1 48hr	
1		SAMPLE TYPE:	Water	
		DATE SAMPLED:	2017-11-21	
Parameter	Unit	G/S RDL	8924691	
pH	ä		7.96	
Reactive Silica as SiO2	mg/L	0.5	9.0	
Chloride	mg/L	1	24	
Fluoride	mg/L	0.12	<0.12	
Sulphate	mg/L	2	7	
Alkalinity	mg/L	5	118	
True Color	TCU	5	5	
Turbidity	NTU	0.1	1.3	
Electrical Conductivity	umho/cm	1	322	
Nitrate + Nitrite as N	mg/L	0.05	2.03	
Nitrate as N	mg/L	0.05	2.03	
Nitrite as N	mg/L	0.05	<0.05	
Ammonia as N	mg/L	0.03	0.05	
Ortho-Phosphate as P	mg/L	0.01	<0.01	
Dissolved Sodium	mg/L	0.1	15.6	
Dissolved Potassium	mg/L	0.1	1.5	
Dissolved Calcium	mg/L	0.1	42.8	
Dissolved Magnesium	mg/L	0.1	3.6	
Bicarb. Alkalinity (as CaCO3)	mg/L	5	118	
Carb. Alkalinity (as CaCO3)	mg/L	10	<10	
Hydroxide	mg/L	5	<5	
Calculated TDS	mg/L	1	174	
Hardness	mg/L		122	
Langelier Index (@20C)	NA		0.05	
Langelier Index (@ 4C)	NA		-0.27	
Saturation pH (@ 20C)	NA		7.91	
Saturation pH (@ 4C)	NA		8.23	
Anion Sum	me/L		3.33	
Cation sum	me/L		3.16	
% Difference/ Ion Balance (NS)	%		2.6	

Certified By:

Laura Balu

11 Morris Drive, Unit 122 Dartmouth, Nova Scotia CANADA B3B 1M2 TEL (902)468-8718 FAX (902)468-8924 http://www.agatlabs.com



SAMPLE DESCRIPTION:

Certificate of Analysis

AGAT WORK ORDER: 17X286678 PROJECT:

CLIENT NAME: ROY CONSULTANTS

SAMPLING SITE:

Dissolved Titanium

Dissolved Uranium

Dissolved Zinc

Dissolved Vanadium

DATE RECEIVED: 2017-11-22

ATTENTION TO: GINA BURTT

SAMPLED BY:

Standard Water Analysis + Dissolved Metals

SAMPLE TYPE: Water DATE SAMPLED: 2017-11-21 G/S RDL 8924691 Parameter Unit Dissolved Aluminum ug/L 5 11 Dissolved Antimony ug/L 2 <2 <2 Dissolved Arsenic ug/L 2 Dissolved Barium 5 421 ug/L Dissolved Beryllium ug/L 2 <2 2 <2 Dissolved Bismuth ug/L **Dissolved Boron** ug/L 5 32 0.017 Dissolved Cadmium ug/L < 0.017 Dissolved Chromium ug/L 3 1 Dissolved Cobalt ug/L <1 1 Dissolved Copper ug/L 2 <2 ug/L Dissolved Iron 50 <50 Dissolved Lead ug/L 0.5 <0.5 ug/L 2 22 **Dissolved Manganese** Dissolved Molybdenum ug/L 2 <2 Dissolved Nickel ug/L 2 <2 Dissolved Phosphorus mg/L 0.02 < 0.02 Dissolved Selenium ug/L <1 1 Dissolved Silver ug/L 0.1 < 0.1 5 **Dissolved Strontium** ug/L 583 Dissolved Thallium ug/L 0.1 < 0.1 2 Dissolved Tin ug/L <2

<2

2.2

4 9

2

0.1

2

5

PW-1 48hr

Comments: RDL - Reported Detection Limit; G / S - Guideline / Standard

ug/L

ua/L

ug/L

ug/L

8924691 Metals analysis completed on a filtered sample.

Certified By:

Lauro Balu

DATE REPORTED: 2017-11-29

11 Morris Drive, Unit 122 Dartmouth, Nova Scotia CANADA B3B 1M2 TEL (902)468-8718 FAX (902)468-8924 http://www.agatlabs.com



Page 6 of 11

Quality Assurance

CLIENT NAME: ROY CONSULTANTS

PROJECT:

SAMPLING SITE:

AGAT WORK ORDER: 17X286678 ATTENTION TO: GINA BURTT SAMPLED BY:

Water Analysis

				vvate		laiys	5								
RPT Date: Nov 29, 2017			D	UPLICATE	E		REFEREN	ICE MA	TERIAL	METHOD	BLANK	SPIKE	MAT	RIX SPI	KE
PARAMETER	Batch	Sample	Dup #1	Dup #2	RPD	Method Blank	Measured		ptable nits	Recovery	Lir	ptable nits	Recovery		ptable nits
		ld					Value	Lower	Upper			Upper		Lower	Upper
Standard Water Analysis + Dis	solved Meta	ls													
pН	8922706		7.11	7.13	0.3%	<	102%	80%	120%	NA	80%	120%	NA	80%	120%
Reactive Silica as SiO2	1	8923613	17.7	18.3	3.3%	< 0.5	114%	80%	120%		80%	120%	107%	80%	120%
Chloride	8924691	8924691	24	24	0.7%	< 1	97%	80%	120%	NA	80%	120%	NA	80%	120%
Fluoride	8924691	8924691	<0.12	<0.12	NA	< 0.12	111%	80%	120%	NA	80%	120%	104%	80%	120%
Sulphate	8924691	8924691	7	7	NA	< 2	111%	80%	120%	NA	80%	120%	93%	80%	120%
Alkalinity	8922706		93	93	0.6%	< 5	100%	80%	120%	NA	80%	120%	NA	80%	120%
True Color	8923386		13	11	NA	< 5	120%	80%	120%	NA			NA		
Turbidity	8923386		47.4	48.4	2.1%	< 0.1	99%	80%	120%	NA			NA		
Electrical Conductivity	8922706		191	191	0.1%	< 1	102%	80%	120%	NA	80%	120%	NA	80%	120%
Nitrate as N	8924691	8924691	2.03	1.99	2.0%	< 0.05	98%	80%	120%	NA	80%	120%	NA	80%	120%
Nitrite as N	8924691	8924691	<0.05	<0.05	NA	< 0.05	95%	80%	120%	NA	80%	120%	103%	80%	120%
Ammonia as N	1	8923613	0.06	0.11	NA	< 0.03	118%	80%	120%		80%	120%	120%	80%	120%
Ortho-Phosphate as P	1	8916528	<0.01	<0.01	NA	< 0.01	103%	80%	120%		80%	120%	111%	80%	120%
Dissolved Sodium	8924691	8924691	15.6	15.5	0.7%	< 0.1	102%	80%	120%	104%	80%	120%	NA	70%	130%
Dissolved Potassium	8924691	8924691	1.5	1.5	0.5%	< 0.1	104%	80%	120%	102%	80%	120%	NA	70%	130%
Dissolved Calcium	8924691	8924691	42.8	44.7	4.5%	< 0.1	103%	80%	120%	100%	80%	120%	NA	70%	130%
Dissolved Magnesium	8924691	8924691	3.6	3.7	1.5%	< 0.1	104%	80%	120%	104%	80%	120%	NA	70%	130%
Bicarb. Alkalinity (as CaCO3)	8922706		93	93	0.6%	< 5	NA	80%	120%	NA	80%	120%	NA	80%	120%
Carb. Alkalinity (as CaCO3)	8922706		<10	<10	NA	< 10	NA	80%	120%	NA	80%	120%	NA	80%	120%
Hydroxide	8922706		<5	<5	NA	< 5	NA	80%	120%	NA	80%	120%	NA	80%	120%
Dissolved Aluminum	8924691	8924691	11	5	NA	< 5	104%	80%	120%	101%	80%	120%	88%	70%	130%
Dissolved Antimony	8924691	8924691	<2	<2	NA	< 2	90%	80%	120%	97%	80%	120%	103%	70%	130%
Dissolved Arsenic	8924691	8924691	<2	<2	NA	< 2	96%	80%	120%	97%	80%	120%	115%	70%	130%
Dissolved Barium	8924691	8924691	421	424	0.8%	< 5	99%	80%	120%	99%	80%	120%	NA	70%	130%
Dissolved Beryllium	8924691	8924691	<2	<2	NA	< 2	107%	80%	120%	109%	80%	120%	118%	70%	130%
Dissolved Bismuth	8924691	8924691	<2	<2	NA	< 2	104%	80%	120%	108%	80%	120%	78%	70%	130%
Dissolved Boron	8924691	8924691	32	33	3.4%	< 5	103%	80%	120%	107%	80%	120%	112%	70%	130%
Dissolved Cadmium	8924691	8924691	<0.017	<0.017	NA	< 0.017	96%	80%	120%	95%	80%	120%	103%	70%	130%
Dissolved Chromium	8924691	8924691	3	3	NA	< 1	99%	80%	120%	100%	80%	120%	85%	70%	130%
Dissolved Cobalt	8924691	8924691	<1	<1	NA	< 1	100%	80%	120%	100%	80%	120%	98%	70%	130%
Dissolved Copper	8924691	8924691	<2	<2	NA	< 2	102%	80%	120%	103%	80%	120%	91%	70%	130%
Dissolved Iron	8924691	8924691	<50	<50	NA	< 50	101%	80%	120%	103%	80%	120%	88%	70%	130%
Dissolved Lead	8924691	8924691	<0.5	<0.5	NA	< 0.5	102%	80%	120%	101%	80%	120%	95%	70%	130%
Dissolved Manganese	8924691	8924691	22	22	1.5%	< 2	98%	80%	120%	98%	80%	120%	NA	70%	130%
Dissolved Molybdenum	8924691	8924691	<2	<2	NA	< 2	96%	80%	120%	97%	80%	120%	83%	70%	130%
Dissolved Nickel	8924691	8924691	<2	<2	NA	< 2	100%	80%	120%	100%	80%	120%	96%	70%	130%
Dissolved Phosphorus		8924691	<0.02	<0.02	NA	< 0.02	106%		120%	97%		120%	70%	70%	130%
Dissolved Selenium		8924691	<1	1	NA	< 1	97%		120%	96%		120%	113%	70%	130%
Dissolved Silver		8924691	<0.1	<0.1	NA	< 0.1	97%		120%	98%		120%	91%		130%

AGAT QUALITY ASSURANCE REPORT (V1)

AGAT Laboratories is accredited to ISO/IEC 17025 by the Canadian Association for Laboratory Accreditation Inc. (CALA) and/or Standards Council of Canada (SCC) for specific tests listed on the scope of accreditation. AGAT Laboratories (Mississauga) is also accredited by the Canadian Association for Laboratory Accreditation Inc. (CALA) for specific drinking water tests. Accreditations are location and parameter specific. A complete listing of parameters for each location is available from www.cala.ca and/or www.scc.ca. The tests in this report may not necessarily be included in the scope of accreditation.



Quality Assurance

CLIENT NAME: ROY CONSULTANTS

PROJECT:

SAMPLING SITE:

AGAT WORK ORDER: 17X286678 ATTENTION TO: GINA BURTT SAMPLED BY:

Water Analysis (Continued)

RPT Date: Nov 29, 2017			DUPLICATE				REFERENCE MATERIAL			METHOD	BLANK	SPIKE	MATRIX SPIKE		
PARAMETER	Batch	Sample	Dup #1	Dup #2	RPD	Method Blank	Measured	Acceptable Limits		Recovery	Lin	ptable nits	Recovery	Lie	ptable nits
		ld	•				Value	Lower	Upper		Lower	Upper	-	Lower	Upper
Dissolved Strontium	8924691	8924691	583	601	3.1%	< 5	94%	80%	120%	93%	80%	120%	NA	70%	130%
Dissolved Thallium	8924691	8924691	<0.1	<0.1	NA	< 0.1	104%	80%	120%	106%	80%	120%	103%	70%	130%
Dissolved Tin	8924691	8924691	<2	<2	NA	< 2	94%	80%	120%	96%	80%	120%	93%	70%	130%
Dissolved Titanium	8924691	8924691	<2	<2	NA	< 2	101%	80%	120%	101%	80%	120%	87%	70%	130%
Dissolved Uranium	8924691	8924691	2.2	2.2	1.4%	< 0.1	101%	80%	120%	101%	80%	120%	NA	70%	130%
Dissolved Vanadium	8924691	8924691	4	4	NA	< 2	93%	80%	120%	94%	80%	120%	98%	70%	130%
Dissolved Zinc	8924691	8924691	9	6	NA	< 5	104%	80%	120%	107%	80%	120%	112%	70%	130%

Comments: If RPD value is NA, the results of the duplicates are less than 5x the RDL and the RPD will not be calculated.

MTL - TOC in Water												
Total Organic Carbon	8932716	7.2	7.0	1.9%	< 0.5	NA	80% 120%	94%	80%	120%	NA	80% 120%

Certified By:

Lauro Balu

AGAT QUALITY ASSURANCE REPORT (V1)

AGAT Laboratories is accredited to ISO/IEC 17025 by the Canadian Association for Laboratory Accreditation Inc. (CALA) and/or Standards Council of Canada (SCC) for specific tests listed on the scope of accreditation. AGAT Laboratories (Mississauga) is also accredited by the Canadian Association for Laboratory Accreditation Inc. (CALA) for specific drinking water tests. Accreditations are location and parameter specific. A complete listing of parameters for each location is available from www.cala.ca and/or www.scc.ca. The tests in this report may not necessarily be included in the scope of accreditation.

Page 7 of 11



Method Summary

CLIENT NAME: ROY CONSULTANTS PROJECT:

AGAT WORK ORDER: 17X286678

ATTENTION TO: GINA BURTT

SAMPLING SITE:		SAMPLED B	SY:
PARAMETER	AGAT S.O.P	LITERATURE REFERENC	E ANALYTICAL TECHNIQUE
Microbiology Analysis			
Total Coliforms (MPN)	MIC-121-7000	Based on SM 9223B	INCUBATOR
E. Coli (MPN)	MIC-121-7000	Based on SM 9223B	INCUBATOR



Method Summary

CLIENT NAME: ROY CONSULTANTS PROJECT:

AGAT WORK ORDER: 17X286678 ATTENTION TO: GINA BURTT

SAMPLING SITE:		SAMPLED BY:								
PARAMETER	AGAT S.O.P	LITERATURE REFERENCE	ANALYTICAL TECHNIQUE							
Water Analysis										
Total Organic Carbon	INOR-101-6049F	MA.300-C1.0	DÉTECTION INFRAROUGE							
pH	INOR-121-6001	SM 4500 H+B	PC TITRATE							
Reactive Silica as SiO2	INORG-121-6028	SM 4110 B	COLORIMETER							
Chloride	INORG-121-6005	SM 4110 B	ION CHROMATOGRAPH							
Fluoride	INORG-121-6005	SM 4110 B	ION CHROMATOGRAPH							
Sulphate	INORG-121-6005	SM 4110 B	ION CHROMATOGRAPH							
Alkalinity	INOR-121-6001	SM 2320 B								
True Color	INORG-121-6014	EPA 110.2	NEPHELOMETER							
Turbidity	INOR-121-6022	SM 2130 B	NEPHELOMETER							
Electrical Conductivity	INOR-121-6001	SM 2510 B	PC TITRATE							
Nitrate + Nitrite as N	INORG-121-6005	SM 4110 B	CALCULATION							
Nitrate as N	INORG-121-6005	SM 4110 B	ION CHROMATOGRAPH							
Nitrite as N	INORG-121-6005	SM 4110 B	ION CHROMATOGRAPH							
Ammonia as N	INORG-121-6003	SM 4500-NH3 G	COLORIMETER							
Ortho-Phosphate as P	INORG-121-6005	SM 4110 B	COLORIMETER							
Dissolved Sodium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Potassium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Calcium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Magnesium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Bicarb. Alkalinity (as CaCO3)	INORG-121-6001	SM 2320 B	PC TITRATE							
Carb. Alkalinity (as CaCO3)	INORG-121-6001	SM 2320 B	PC TITRATE							
Hydroxide	INORG-121-6001	SM 2320 B	PC-TITRATE							
Calculated TDS	CALCULATION	SM 1030E	CALCULATION							
Hardness	CALCULATION	SM 2340B	CALCULATION							
Langelier Index (@20C)	CALCULATION	CALCULATION	CALCULATION							
Langelier Index (@ 4C)	CALCULATION	CALCULATION	CALCULATION							
Saturation pH (@ 20C)	CALCULATION	CALCULATION	CALCULATION							
Saturation pH (@ 4C)	CALCULATION	CALCULATION	CALCULATION							
Anion Sum	CALCULATION	SM 1030E	CALCULATION							
Cation sum	CALCULATION	SM 1030E	CALCULATION							
% Difference/ Ion Balance (NS)	CALCULATION	SM 1030E	CALCULATION							
Dissolved Aluminum	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Antimony	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Arsenic	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Barium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Beryllium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Bismuth	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Boron	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Cadmium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							



Method Summary

CLIENT NAME: ROY CONSULTAN PROJECT:	TS	AGAT WORK ORDER: 17X286678 ATTENTION TO: GINA BURTT								
SAMPLING SITE:		SAMPLED BY:	GINA BORTI							
PARAMETER	AGAT S.O.P	LITERATURE REFERENCE	ANALYTICAL TECHNIQUE							
Dissolved Chromium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Cobalt	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Copper	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Iron	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Lead	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Manganese	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Molybdenum	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Nickel	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Phosphorus	MET-121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Selenium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Silver	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Strontium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Thallium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Tin	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Titanium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Uranium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Vanadium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Zinc	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							

Chain of Custod	ly Record	Γι	.abora	webeartii.			Unit 1 .com •	ww	Da w.ag	rtmo B3 (atla	uth, N B 1N DS.CO	IS 12	Arriv Arriv	orat val Co val Te d Tim T Job	ondit mpe	ion: ratu	[ire:	□ Go 40	_				_	s)
Report Information			Report	nformation (Please print):					Pan	vrt E	orma	+		es:		,	10.0	0.	,					
		-	11	GINA BOOT				11				- 11		00	m	~	IY.	IPA	- 52					
Company: Roy (5			- mite	1		- [ingle \$ er pag	Sample e	16	-	-			-		_		_			
Contact: GINA				: sim burtte roycons		MIS	SICO	- ,	Ň	luitiple	Samp	les		naro						•				
Address: 364 York			2. Name	ABRAM LEE		h	12:0	- '		er pag			Reg	ular	ΓΑΤ	P	5 to	7 wc	orkin;	g da	ys			
FREDERIC	TON NB ESP	3 3 97	Email	abram. lee E ray const	1ton	15	.ca	= 1		xcel Fo nclude			Rus	h TA1			Sam	ie da	y I	01	day			
Phone: 506 470-	7473 Fax:		Regulat	ory Requirements (Check):					Ē	xport						\Box	2 da	iys		□3	days	5		
Oliveration of the				idelines on Report 🛛 🗆 Do not lis	t Guide	elines	on Repo	rt					Date	Req	ired									
AGAT Quotation:				1 🗌 Res 🗌 Pot			oarse					- 1	Date	- кеч	lieu							_		
Please Note: If quotation number is r	not provided client will be billed for	ull price for analys		$2 \square Com \square N/Pc$					Prinki	ng W	ater S	ampl	e: 🗌	Yes		5	Sal	It Wat	ter Sa	ampl	e [] Yes	; []	No
Invoice To	Same	Yes / No	Gas	Fuel Lube				F	leg. N	10.:							_				-			
Company:				CDWQ				T	1			1			T	T				T	T		T	T
			— 🗌 🗆 Ind				Available					i.	- -							ΨF				
				nmercial 🗌 HRM 101			Avai						🗆 low level	6							ME			-
Address:			□ Res	□ Storm water		6				VSS			0 D	onati						MPN				
Phone:	Fau		- FW	AL Waste water	erve	alysi	Diss						PIRI)	Fracti	5				2	≥ X .	Pseudomonas			
	Fax:		Sec	liment 🗌 Other	/Pres	ter Ar	N a	CBOD		SO	Drus		TEX (TEX						P/A	seud			(N)
PO/Credit Card#:					tered	d Wat	Iot			D TDS	osphe		PH/B	2: TPH/BTEX Fractionation										X) sn
Sample Identification	Date/Time Sampled	Sample Matrix	# Containers	Comments – Site/Sample Info. Sample Containment	Field Filtered/Preserved	Standard Water Analysis	Metals: 🗆 Total 🔀	□ BOD	Hd	D TSS	TKN Total Phosphorus	Phenols	Tier 1: TPH/BTEX (PIRI)	Tier 2: T	VOC VOC	THM	HAA	PAH	PCB	TC + EC	Eacal Coliform	Other:	Other:	Hazardous (Y/N)
Puir 1 48hr	21/11/17 14:30	Wate-	3	MURRAY CORNER		X	X													X				
							5.									_								
TC+ECPI	and the second										_													
METALS PRE	SERVED							-												_	_	_		
					-			+	-	_	_					-	-			_	_		-	
					+			+	-	-	-	-		_	-	-	-	-	_				-	
					+			+	-	-		-			+	-	-		-		-		-	
					+		_	+	-		-	-		-		+	-	+	-+-	-	+	+	+-	
					1							-				1		\square	T	+	+	+	1	1
·					1			-		1		1	-		-		-			-		-	-	
															1						_			
Samples Relinquished By (Print Name):		Date/Tr	1.2.1	Samples Received By (Print Name);							/Time			Die			iont			-		1	-	
ABRAN LE Samples Relinquisted By (Sign): Acre Coo	Ē	11VI7	Samples Received By (Sign):							22.	-NI)V		k Cop ow Co				Page	e		of			
Complete relinquisited by (Sign):		545	Samples Received By (Sign):	1	1					/Time	., 1						Nº:	F	71	15	2			
Hentles		195	Ornaue	ul	6-1					08	.4)			_			J	14	+0	2			

1

DIV-133 1501 004



CLIENT NAME: ROY CONSULTANTS 548 KING AVE BATHURST, NB E2A 4Z1 506-546-4484

ATTENTION TO: GINA BURTT

PROJECT: 278-17

AGAT WORK ORDER: 17X287561

MICROBIOLOGY ANALYSIS REVIEWED BY: Jason Coughtrey, Inorganics Supervisor

WATER ANALYSIS REVIEWED BY: Jason Coughtrey, Inorganics Supervisor

DATE REPORTED: Dec 01, 2017

PAGES (INCLUDING COVER): 11

VERSION*: 1

Should you require any information regarding this analysis please contact your client services representative at (902) 468-8718

*NOTES	

All samples will be disposed of within 30 days following analysis. Please contact the lab if you require additional sample storage time.

AGAT Laboratories (V1)

Member of: Association of Professional Engineers and Geoscientists of Alberta (APEGA) Western Enviro-Agricultural Laboratory Association (WEALA) Environmental Services Association of Alberta (ESAA) AGAT Laboratories is accredited to ISO/IEC 17025 by the Canadian Association for Laboratory Accreditation Inc. (CALA) and/or Standards Council of Canada (SCC) for specific tests listed on the scope of accreditation. AGAT Laboratories (Mississauga) is also accredited by the Canadian Association for Laboratory Accreditation Inc. (CALA) for specific drinking water tests. Accreditations are location and parameter specific. A complete listing of parameters for each location is available from www.cala.ca and/or www.scc.ca. The tests in this report may not necessarily be included in the scope of accreditation.

Page 1 of 11

Results relate only to the items tested and to all the items tested All reportable information as specified by ISO 17025:2005 is available from AGAT Laboratories upon request



AGAT WORK ORDER: 17X287561 PROJECT: 278-17

CLIENT NAME: ROY CONSULTANTS

SAMPLING SITE:

ATTENTION TO: GINA BURTT

SAMPLED BY:

Total Coliforms and E.coli (MPN) DATE RECEIVED: 2017-11-23 **DATE REPORTED: 2017-12-01** SAMPLE DESCRIPTION: PW-1 69hr SAMPLE TYPE: Water DATE SAMPLED: 2017-11-22 Unit G/S RDL 8929649 Parameter Total Coliforms (MPN) MPN/100 mL <1 1 E. Coli (MPN) MPN/100 mL 1 <1

Comments: RDL - Reported Detection Limit; G / S - Guideline / Standard

Certified By:

Jason Coto

11 Morris Drive, Unit 122 Dartmouth, Nova Scotia CANADA B3B 1M2 TEL (902)468-8718 FAX (902)468-8924 http://www.agatlabs.com



AGAT WORK ORDER: 17X287561 PROJECT: 278-17

CLIENT NAME: ROY CONSULTANTS

SAMPLING SITE:

17X287561 TEL (902)468-8718 FAX (902)468-8924 http://www.agatlabs.com ATTENTION TO: GINA BURTT SAMPLED BY:

DATE REPORTED: 2017-12-01

DATE RECEIVED: 2017-11-23

	-			
	S	AMPLE DES	CRIPTION:	PW-1 69hr
		SAM	PLE TYPE:	Water
		DATES	SAMPLED:	2017-11-22
Parameter	Unit	G/S	RDL	8929649
Total Organic Carbon	mg/L		0.5	<0.5

MTL - TOC in Water

Comments: RDL - Reported Detection Limit; G / S - Guideline / Standard

8929649 TOC analysed at AGAT Montreal.

Certified By:

11 Morris Drive, Unit 122

Dartmouth, Nova Scotia

CANADA B3B 1M2



AGAT WORK ORDER: 17X287561 PROJECT: 278-17

CLIENT NAME: ROY CONSULTANTS

SAMPLING SITE:

DATE RECEIVED: 2017-11-23

ATTENTION TO: GINA BURTT

SAMPLED BY:

Standard Water Analysis + Dissolved Metals

SAMPLE DESCRIPTION: PW-1 69hr SAMPLE TYPE: Water DATE SAMPLED: 2017-11-22 Unit G/S RDL 8929649 Parameter bН 8.09 Reactive Silica as SiO2 mg/L 0.5 11.7 Chloride 25 mg/L 1 Fluoride 0.12 mg/L < 0.12 Sulphate mg/L 2 7 Alkalinity 5 118 mg/L True Color TCU 5 14 NTU Turbidity 0.1 0.8 Electrical Conductivity umho/cm 332 1 Nitrate + Nitrite as N mg/L 0.05 1.91 Nitrate as N mg/L 0.05 1.91 Nitrite as N 0.05 < 0.05 mg/L Ammonia as N mg/L 0.03 < 0.03 Ortho-Phosphate as P mg/L 0.01 < 0.01 **Dissolved Sodium** mg/L 0.1 17.7 Dissolved Potassium mg/L 0.1 1.7 **Dissolved Calcium** mg/L 0.1 43.7 Dissolved Magnesium mg/L 0.1 4.1 Bicarb. Alkalinity (as CaCO3) mg/L 5 118 10 Carb. Alkalinity (as CaCO3) mg/L <10 Hydroxide mg/L 5 <5 178 Calculated TDS mg/L 1 Hardness mg/L 126 Langelier Index (@20C) NA 0.19 Langelier Index (@ 4C) NA -0.13 Saturation pH (@ 20C) NA 7.90

8.22

3.35 3.33

0.2

Jasar Cotoghtray

DATE REPORTED: 2017-12-01

AGAT CERTIFICATE OF ANALYSIS (V1)

NA

me/L

me/L

%

Saturation pH (@ 4C)

% Difference/ Ion Balance (NS)

Anion Sum

Cation sum

Certified By:

11 Morris Drive, Unit 122 Dartmouth, Nova Scotia CANADA B3B 1M2 TEL (902)468-8718 FAX (902)468-8924 http://www.agatlabs.com



AGAT WORK ORDER: 17X287561 PROJECT: 278-17

CLIENT NAME: ROY CONSULTANTS

SAMPLING SITE:

ATTENTION TO: GINA BURTT

SAMPLED BY:

Standard Water Analysis + Dissolved Metals

DATE RECEIVED: 2017-11-2	3			DATE REPORTED: 2017-12
Parameter	SA Unit	MPLE DESCRIPTION: SAMPLE TYPE: DATE SAMPLED: G/S RDL	PW-1 69hr Water 2017-11-22 8929649	
Dissolved Aluminum	ug/L	5	<5	
Dissolved Antimony	ug/L	2	<2	
Dissolved Arsenic	ug/L	2	<2	
Dissolved Barium	ug/L	5	413	
Dissolved Beryllium	ug/L	2	<2	
Dissolved Bismuth	ug/L	2	<2	
Dissolved Boron	ug/L	5	28	
Dissolved Cadmium	ug/L	0.017	<0.017	
Dissolved Chromium	ug/L	1	<1	
Dissolved Cobalt	ug/L	1	<1	
Dissolved Copper	ug/L	2	<2	
Dissolved Iron	ug/L	50	<50	
Dissolved Lead	ug/L	0.5	<0.5	
Dissolved Manganese	ug/L	2	21	
Dissolved Molybdenum	ug/L	2	<2	
Dissolved Nickel	ug/L	2	<2	
Dissolved Phosphorus	mg/L	0.02	<0.02	
Dissolved Selenium	ug/L	1	<1	
Dissolved Silver	ug/L	0.1	<0.1	
Dissolved Strontium	ug/L	5	521	
Dissolved Thallium	ug/L	0.1	<0.1	
Dissolved Tin	ug/L	2	<2	
Dissolved Titanium	ug/L	2	<2	
Dissolved Uranium	ug/L	0.1	2.1	
Dissolved Vanadium	ug/L	2	4	
Dissolved Zinc	ug/L	5	<5	

Comments: RDL - Reported Detection Limit; G / S - Guideline / Standard

8929649 Metals analysis completed on a filtered sample.

Certified By:

Jason Coto

11 Morris Drive, Unit 122 Dartmouth, Nova Scotia CANADA B3B 1M2 TEL (902)468-8718 FAX (902)468-8924 http://www.agatlabs.com



Quality Assurance

CLIENT NAME: ROY CONSULTANTS

PROJECT: 278-17

SAMPLING SITE:

AGAT WORK ORDER: 17X287561 ATTENTION TO: GINA BURTT SAMPLED BY:

Water Analysis

PET Date: Dec 01, 2017 UPLICATE Refressence Matterial Methods Section Matterial Section Matterial Section Matterial Section Standard Water Analysis + Dissolved Metals Basich Sample Days 1 Days 2 RPD Matterial Section Name Matterial Section Recovery Matterial Section					vvate	er An	laiys	IS								
PARAMETER Battering Dup #1 Dup #2 ParD Blattering Limits Value Recovery Value Limits Value Va	RPT Date: Dec 01, 2017	RPT Date: Dec 01, 2017						REFEREN	ICE MA	TERIAL	METHOD	BLANK	SPIKE	MAT	RIX SPI	KE
Standard Water Analysis + Dissolved Metals 9829720 7.99 8.06 0.9% <	PARAMETER	Batch		Dup #1	Dup #2	RPD					Recovery	Lir		Recovery		
pH B822720 7.90 8.00 0.9% <								value	Lower	Upper	-	Lower	Upper	-	Lower	Upper
Reader 1 891622 4.2 5.2 2.3% < 0.5 120% 80% 120% <t< td=""><td>Standard Water Analysis + Diss</td><td>solved Meta</td><td>s</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></t<>	Standard Water Analysis + Diss	solved Meta	s													
Choinde 8829648 8929649 925 24 2.3% <1 100% 80% 120% NA 80%	pH	8929720		7.99	8.06	0.9%	<	102%	80%	120%	NA	80%	120%	NA	80%	120%
Flucinde 8828648 8928649 90.1 0.12 17.4 80.7 1207 NA <22 112% 80% 120% NA 80%	Reactive Silica as SiO2	1	8916529	4.2	5.2	21.3%	< 0.5	120%	80%	120%		80%	120%	105%	80%	120%
Sulphate 8929649 9270 7 NA <2 112% 80% 120% NA 80% 120% 80% 120% 80% 120% 80% 120% NA 80% 120% 120% 120% 120% 120% 120% 120% 120% 120% 120% 120% 120% 120% 120% 120% 120	Chloride	8929649	8929649	25	24	2.3%	< 1	100%	80%	120%	NA	80%	120%	NA	80%	120%
Akalinity 8929720 170 170 0.1% < 5 102% NA 80% 120% NA B0% 120% NA Turbidity 8927417 26 22 NA < 5	Fluoride	8929649	8929649	<0.12	<0.12	NA	< 0.12	113%	80%	120%	NA	80%	120%	105%	80%	120%
True Color 8927417 26 22 NA <5 11% 80% 120% NA Image: NA Turbidity 8927477 03.9 94.4 0.5% <0.1	Sulphate	8929649	8929649	7	7	NA	< 2	112%	80%	120%	NA	80%	120%	93%	80%	120%
Turbidity 892717 93.9 94.4 0.5% < 0.1 99% 80% 120% NA Eventical Conductivity Nitrate as N 8292649 8292649 929649 8292649 0.00 <0.00	Alkalinity	8929720		170	170	0.1%	< 5	102%	80%	120%	NA	80%	120%	NA	80%	120%
Electrical Conductivity 8929720 915 916 0.1% <1 105% 80% 120% NA 70% 120% NA 70% 120% NA 70% 120% NA 80% 120	True Color	8927417		26	22	NA	< 5	115%	80%	120%	NA			NA		
Nitrate as N 8929649 929649 1.91 1.85 3.0% < 0.05 101% 80% 120% NA 70% 120% 100% 80% 120% NA 70% 130% 120% 100% 80% 120% NA 70% 130% 120% NA 80% 120% NA 70% 130% 130% 120% NA 80% 120% NA 70% 130% 130% 120% NA 80% 120% NA 80% 120% NA 80% 120% NA 100% 120% NA	Turbidity	8927417		93.9	94.4	0.5%	< 0.1	99%	80%	120%	NA			NA		
Nitrite as N 8929649 8929649 8929649 40.05 40.05 97% 80% 120% Na 60% 120% Na 60% 120% Na 60% 120% Na 60% 120% 80%	Electrical Conductivity	8929720		915	916	0.1%	< 1	105%	80%	120%	NA	80%	120%	NA	80%	120%
Ammonia as N 1 892649 <0.03 <0.03 NA <0.03 9% 80% 120% 80% 120% 80% 120% 80% 120% 80% 120% 80% 120% 80% 120% 80% 120% 100% 80% 120% 100% 80% 120% 100% 80% 120% 100% 80% 120% 100% 80% 120% 100% 80% 120% 100% 80% 120% 100% 80% 120% NA 70% 130% Dissolved Otassium 8929649 8929649 4.1 3.7 11.4% <0.1	Nitrate as N	8929649	8929649	1.91	1.85	3.0%	< 0.05	101%	80%	120%	NA	80%	120%	NA	80%	120%
Ortho-Phosphate as P 1 8916529 <0.01 <0.01 NA <0.01 102% 80% 120% 103% 80% 120% 103% 80% 120% 103% 80% 120% 103% 80% 120% 104% 80% 120% 104% 80% 120% 103% 80% 120% 103% 80% 120% 103% 80% 120% 103% 80% 120% 103% 80% 120% 103% 80% 120% 103% 80% 120% 104% 80% 120% 103% 80% 120% 103% 80% 120% NA 70% 130% Dissolved Magnesium 8929649 8929649 4.1 3.7 11.4% <.01	Nitrite as N	8929649	8929649	<0.05	<0.05	NA	< 0.05	97%	80%	120%	NA	80%	120%	101%	80%	120%
Dissolved Sodium 8929649 8929649 17.7 14.9 17.1 < 10.5 80% 120% 104% 80% 120% NA 70% 130% Dissolved Potassium 8929649 8929649 8929649 8929649 43.7 42.2 3.5% <	Ammonia as N	1	8929649	<0.03	<0.03	NA	< 0.03	99%	80%	120%		80%	120%	88%	80%	120%
Dissolved Potassium 8929649 92.7 1.6 6.4% < 0.1 105% 80% 120% NA 7.0% 130% Dissolved Calcium 8929649 8929649 4.1 3.7 11.4% <0.1	Ortho-Phosphate as P	1	8916529	<0.01	<0.01	NA	< 0.01	102%	80%	120%		80%	120%	103%	80%	120%
Dissolved Calcium 8929649 8929649 43.7 42.2 3.5% < 0.1 103% 80% 120% NA 70% 130% Dissolved Magnesium 8929649 8929649 4.1 3.7 11.4% < 0.1	Dissolved Sodium	8929649	8929649	17.7	14.9	17.1%	< 0.1	105%	80%	120%	104%	80%	120%	NA	70%	130%
Dissolved Magnesium 8929649 8929649 4.1 3.7 11.4% <0.1 105% 80% 120% NA 80% 120% 101% 80% 120% 101% 80% 120% 101% 80% 120% 101% 80% 120% 101% 80% 120% 101% 80% 120% 101% 80% 120% 101% 80%	Dissolved Potassium	8929649	8929649	1.7	1.6	6.4%	< 0.1	105%	80%	120%	106%	80%	120%	NA	70%	130%
Bicarb. Alkalinity (as CaCO3) 8929720 170 170 0.1% < 5 NA 80% 120% NA 101% 70% 130% 130% 130% 130% 130% 130% 130% 130% 120% 80% 120% <t< td=""><td>Dissolved Calcium</td><td>8929649</td><td>8929649</td><td>43.7</td><td>42.2</td><td>3.5%</td><td>< 0.1</td><td>103%</td><td>80%</td><td>120%</td><td>103%</td><td>80%</td><td>120%</td><td>NA</td><td>70%</td><td>130%</td></t<>	Dissolved Calcium	8929649	8929649	43.7	42.2	3.5%	< 0.1	103%	80%	120%	103%	80%	120%	NA	70%	130%
Carb. Alkalinity (as CaCO3) 8929720 <10 <10 NA <10 NA 80% 120% 101% 80% 120% 101% 70% 130% 130% 130% 130% 120% 101% 80% 120% 101% 70% 130% 130% 120% 101% 80% 120% 101% 80% 120% 101% 80% 120% 101% 80% 120% 101% 80% 120% 120% 101% 70% 130% 130% 130% 130%	Dissolved Magnesium	8929649	8929649	4.1	3.7	11.4%	< 0.1	105%	80%	120%	106%	80%	120%	NA	70%	130%
Hydroxide8929720<5<5NA<5NA80%120%NA80%120%NA80%120%Dissolved Aluminum89296498929649<2	Bicarb. Alkalinity (as CaCO3)	8929720		170	170	0.1%	< 5	NA	80%	120%	NA	80%	120%	NA	80%	120%
Dissolved Aluminum 8929649 8929649 <5 NA <5 105% 80% 120% 101% 80% 120% 101% 80% 120% 101% 80% 120% 101% 80% 120% 101% 80% 120% 101% 80% 120% 101% 80% 120% 101% 70% 130% Dissolved Arsenic 8929649 8929649 42 -2 NA <5	Carb. Alkalinity (as CaCO3)	8929720		<10	<10	NA	< 10	NA	80%	120%	NA	80%	120%	NA	80%	120%
Dissolved Antimony 8929649 8929649 822 22 NA < 2 92% 80% 120% 101% 80% 120% 101% 70% 130% Dissolved Arsenic 8929649 8929649 413 406 1.8% < 5	Hydroxide	8929720		<5	<5	NA	< 5	NA	80%	120%	NA	80%	120%	NA	80%	120%
Dissolved Arsenic Dissolved Barium8929649 8929649424242NA4299% 4380%120%100% 100%80%120%101% 100%70%130% 130%Dissolved Baryllium892964989296494242ANA42100%80%120%111%80%120%111%70%130% 130%130%Dissolved Bismuth892964989296494242NA42106%80%120%101%80%120%111%70%130%Dissolved Boron8929649892964935337.8%<5	Dissolved Aluminum	8929649	8929649	<5	<5	NA	< 5	105%	80%	120%	107%	80%	120%	92%	70%	130%
Dissolved Barium Dissolved Beryllium8929649 8929649413 2406 21.8% 2<5 NA100% 280% 120%120% 111%10% 80%120% 111%NA 80%70% 130%130% 130%Dissolved Bismuth Dissolved Boron8929649 892964922 8929649<2 35<2	Dissolved Antimony	8929649	8929649	<2	<2	NA	< 2	92%	80%	120%	101%	80%	120%	101%	70%	130%
Dissolved Beryllium 8929649 8929649 822 2 NA < 2 10% 80% 120% 111% 80% 120% 113% 70% 130% Dissolved Bismuth 8929649 8929649 35 33 7.8% < 5	Dissolved Arsenic	8929649	8929649	<2	<2	NA	< 2	99%	80%	120%	98%	80%	120%	101%	70%	130%
Dissolved Bismuth 8929649 8929649 32 2 2 NA < 2 106% 80% 120% NA 70% 130% Dissolved Boron 8929649 8929649 35 33 7.8% < 5	Dissolved Barium	8929649	8929649	413	406	1.8%	< 5	100%	80%	120%	100%	80%	120%	NA	70%	130%
Dissolved Boron 8929649 8929649 35 33 7.8% < 5 104% 80% 120% 106% 80% 120% 100% 70% 130% Dissolved Cadmium 8929649 8929649 2 1 NA <0.017	Dissolved Beryllium	8929649	8929649	<2	<2	NA	< 2	109%	80%	120%	111%	80%	120%	113%	70%	130%
Dissolved Cadmium 8929649 8929649 <0.017 <0.017 NA < 0.017 98% 80% 120% 99% 80% 120% 102% 70% 130% Dissolved Chromium 8929649 8929649 2 1 NA <1	Dissolved Bismuth	8929649	8929649	<2	<2	NA	< 2	106%	80%	120%	108%	80%	120%	NA	70%	130%
Dissolved Chromium 8929649 8929649 2 1 NA < 1 91% 80% 120% 95% 80% 120% 87% 70% 130% Dissolved Cobalt 8929649 8929649 2 <1	Dissolved Boron	8929649	8929649	35	33	7.8%	< 5	104%	80%	120%	106%	80%	120%	100%	70%	130%
Dissolved Cobalt 8929649 8929649 2 <1 NA <1 96% 80% 120% 99% 80% 120% 82% 70% 130% Dissolved Copper 8929649 8929649 <2	Dissolved Cadmium	8929649	8929649	<0.017	<0.017	NA	< 0.017	98%	80%	120%	99%	80%	120%	102%	70%	130%
Dissolved Copper 8929649 8929649 <2 <2 NA <2 99% 80% 120% 99% 80% 120% 101% 70% 130% Dissolved Iron 8929649 8929649 <50	Dissolved Chromium	8929649	8929649	2	1	NA	< 1	91%	80%	120%	95%	80%	120%	87%	70%	130%
Dissolved Iron 8929649 8929649 <50 <50 NA < 50 90% 80% 120% 95% 80% 120% 73% 70% 130% Dissolved Lead 8929649 8929649 <0.5	Dissolved Cobalt	8929649	8929649	2	<1	NA	< 1	96%	80%	120%	99%	80%	120%	82%	70%	130%
Dissolved Lead 8929649 8929649 <0.5 <0.5 NA < 0.5 100% 80% 120% 80% 120% 88% 70% 130% Dissolved Manganese 8929649 8929649 21 21 21 0.0% <2	Dissolved Copper	8929649	8929649	<2	<2	NA	< 2	99%	80%	120%	99%	80%	120%	101%	70%	130%
Dissolved Manganese 8929649 21 21 21 0.0% < 2 91% 80% 120% 91% 80% 120% NA 70% 130% Dissolved Molybdenum 8929649 8929649 <2	Dissolved Iron	8929649	8929649	<50	<50	NA	< 50	90%	80%	120%	95%	80%	120%	73%	70%	130%
Dissolved Molybdenum 8929649 8929649 <2 <2 NA <2 91% 80% 120% 94% 80% 120% 83% 70% 130% Dissolved Nickel 8929649 8929649 <2	Dissolved Lead	8929649	8929649	<0.5	<0.5	NA	< 0.5	100%	80%	120%	100%	80%	120%	88%	70%	130%
Dissolved Nickel 8929649 8929649 <2 <2 NA <2 97% 80% 120% 100% 80% 120% 96% 70% 130% Dissolved Phosphorus 8929649 8929649 <0.02	Dissolved Manganese	8929649	8929649	21	21	0.0%	< 2	91%	80%	120%	91%	80%	120%	NA	70%	130%
Dissolved Phosphorus 8929649 8929649 <0.02 <0.02 NA < 0.02 98% 80% 120% 111% 70% 130% Dissolved Selenium 8929649 8929649 1 <1	Dissolved Molybdenum	8929649	8929649	<2	<2	NA	< 2	91%	80%	120%	94%	80%	120%	83%	70%	130%
Dissolved Selenium 8929649 8929649 1 <1 NA <1 101% 80% 120% 95% 80% 120% 110% 70% 130%	Dissolved Nickel	8929649	8929649	<2	<2	NA	< 2	97%	80%	120%	100%	80%	120%	96%	70%	130%
	Dissolved Phosphorus	8929649	8929649	<0.02	<0.02	NA	< 0.02	98%	80%	120%	103%	80%	120%	111%	70%	130%
Dissolved Silver 8929649 8929649 <0.1 <0.1 NA < 0.1 99% 80% 120% 101% 80% 120% 88% 70% 130%	Dissolved Selenium	8929649	8929649	1	<1		< 1	101%	80%	120%	95%	80%	120%	110%	70%	130%
	Dissolved Silver	8929649	8929649	<0.1	<0.1	NA	< 0.1	99%	80%	120%	101%	80%	120%	88%	70%	130%

AGAT QUALITY ASSURANCE REPORT (V1)

AGAT Laboratories is accredited to ISO/IEC 17025 by the Canadian Association for Laboratory Accreditation Inc. (CALA) and/or Standards Council of Canada (SCC) for specific tests listed on the scope of accreditation. AGAT Laboratories (Mississauga) is also accredited by the Canadian Association for Laboratory Accreditation Inc. (CALA) for specific drinking water tests. Accreditations are location and parameter specific. A complete listing of parameters for each location is available from www.cala.ca and/or www.scc.ca. The tests in this report may not necessarily be included in the scope of accreditation.

Page 6 of 11



Quality Assurance

CLIENT NAME: ROY CONSULTANTS

PROJECT: 278-17

SAMPLING SITE:

AGAT WORK ORDER: 17X287561 ATTENTION TO: GINA BURTT SAMPLED BY:

Water Analysis (Continued)

RPT Date: Dec 01, 2017			DUPLICATE				REFEREN	ICE MA	TERIAL	METHOD	BLANK	SPIKE	MATRIX SPIKE			
PARAMETER	Batch	Sample	Dup #1	Dup #2	RPD	Method Blank	Measured		ptable nits	Recovery	Lir	ptable nits	Recovery	Lin	eptable nits	
						Value	Lower Upper		-	Lower	Upper	-	Lower	Upper		
Dissolved Strontium	8929649	8929649	521	519	0.4%	< 5	87%	80%	120%	88%	80%	120%	NA	70%	130%	
Dissolved Thallium	8929649	8929649	<0.1	<0.1	NA	< 0.1	108%	80%	120%	111%	80%	120%	99%	70%	130%	
Dissolved Tin	8929649	8929649	<2	<2	NA	< 2	99%	80%	120%	98%	80%	120%	90%	70%	130%	
Dissolved Titanium	8929649	8929649	<2	<2	NA	< 2	105%	80%	120%	106%	80%	120%	92%	70%	130%	
Dissolved Uranium	8929649	8929649	2.2	2.2	0.2%	< 0.1	105%	80%	120%	106%	80%	120%	NA	70%	130%	
Dissolved Vanadium	8929649	8929649	4	4	NA	< 2	90%	80%	120%	92%	80%	120%	96%	70%	130%	
Dissolved Zinc	8929649	8929649	<5	<5	NA	< 5	95%	80%	120%	98%	80%	120%	116%	70%	130%	

Comments: If RPD value is NA, the results of the duplicates are less than 5x the RDL and the RPD will not be calculated.

MTL - TOC in Water											
Total Organic Carbon	8932716	7.2	7.0	1.9%	< 0.5	NA	80% 120%	94%	80% 120%	NA	80% 120%

Certified By:

Jasa Cought νų

AGAT QUALITY ASSURANCE REPORT (V1)

Page 7 of 11

AGAT Laboratories is accredited to ISO/IEC 17025 by the Canadian Association for Laboratory Accreditation Inc. (CALA) and/or Standards Council of Canada (SCC) for specific tests listed on the scope of accreditation. AGAT Laboratories (Mississauga) is also accredited by the Canadian Association for Laboratory Accreditation Inc. (CALA) for specific drinking water tests. Accreditations are location and parameter specific. A complete listing of parameters for each location is available from www.cala.ca and/or www.scc.ca. The tests in this report may not necessarily be included in the scope of accreditation.



Method Summary

CLIENT NAME: ROY CONSULTANTS

PROJECT: 278-17

AGAT WORK ORDER: 17X287561

ATTENTION TO: GINA BURTT

SAMPLING SITE:		SAMPLED BY:	
PARAMETER	AGAT S.O.P	LITERATURE REFERENCE	ANALYTICAL TECHNIQUE
Microbiology Analysis	·		
Total Coliforms (MPN)	MIC-121-7000	Based on SM 9223B	INCUBATOR
E. Coli (MPN)	MIC-121-7000	Based on SM 9223B	INCUBATOR



Method Summary

CLIENT NAME: ROY CONSULTANTS

AGAT WORK ORDER: 17X287561 ATTENTION TO: GINA BURTT

DO LEOT ATO AT										
PROJECT: 278-17		ATTENTION TO: GINA BURTT								
SAMPLING SITE:		SAMPLED BY:								
PARAMETER	AGAT S.O.P	LITERATURE REFERENCE	ANALYTICAL TECHNIQUE							
Water Analysis										
Total Organic Carbon	INOR-101-6049F	MA.300-C1.0	DÉTECTION INFRAROUGE							
рН	INOR-121-6001	SM 4500 H+B	PC TITRATE							
Reactive Silica as SiO2	INORG-121-6028	SM 4110 B	COLORIMETER							
Chloride	INORG-121-6005	SM 4110 B	ION CHROMATOGRAPH							
Fluoride	INORG-121-6005	SM 4110 B	ION CHROMATOGRAPH							
Sulphate	INORG-121-6005	SM 4110 B	ION CHROMATOGRAPH							
Alkalinity	INOR-121-6001	SM 2320 B								
True Color	INORG-121-6014	EPA 110.2	NEPHELOMETER							
Turbidity	INOR-121-6022	SM 2130 B	NEPHELOMETER							
Electrical Conductivity	INOR-121-6001	SM 2510 B	PC TITRATE							
Nitrate + Nitrite as N	INORG-121-6005	SM 4110 B	CALCULATION							
Nitrate as N	INORG-121-6005	SM 4110 B	ION CHROMATOGRAPH							
Nitrite as N	INORG-121-6005	SM 4110 B	ION CHROMATOGRAPH							
Ammonia as N	INORG-121-6003	SM 4500-NH3 G	COLORIMETER							
Ortho-Phosphate as P	INORG-121-6005	SM 4110 B	COLORIMETER							
Dissolved Sodium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Potassium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Calcium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Magnesium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Bicarb. Alkalinity (as CaCO3)	INORG-121-6001	SM 2320 B	PC TITRATE							
Carb. Alkalinity (as CaCO3)	INORG-121-6001	SM 2320 B	PC TITRATE							
Hydroxide	INORG-121-6001	SM 2320 B	PC-TITRATE							
Calculated TDS	CALCULATION	SM 1030E	CALCULATION							
Hardness	CALCULATION	SM 2340B	CALCULATION							
Langelier Index (@20C)	CALCULATION	CALCULATION	CALCULATION							
Langelier Index (@ 4C)	CALCULATION	CALCULATION	CALCULATION							
Saturation pH (@ 20C)	CALCULATION	CALCULATION	CALCULATION							
Saturation pH (@ 4C)	CALCULATION	CALCULATION	CALCULATION							
Anion Sum	CALCULATION	SM 1030E	CALCULATION							
Cation sum	CALCULATION	SM 1030E	CALCULATION							
% Difference/ Ion Balance (NS)	CALCULATION	SM 1030E	CALCULATION							
Dissolved Aluminum	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Antimony	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Arsenic	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Barium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Beryllium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Bismuth	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Boron	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							
Dissolved Cadmium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS							



Method Summary

CLIENT NAME: ROY CONSULTAN PROJECT: 278-17	TS	AGAT WORK OF ATTENTION TO:	RDER: 17X287561 GINA BURTT
SAMPLING SITE:		SAMPLED BY:	
PARAMETER	AGAT S.O.P	LITERATURE REFERENCE	ANALYTICAL TECHNIQUE
Dissolved Chromium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS
Dissolved Cobalt	MET121-6104 & MET-121-6105	SM 3125	ICP-MS
Dissolved Copper	MET121-6104 & MET-121-6105	SM 3125	ICP-MS
Dissolved Iron	MET121-6104 & MET-121-6105	SM 3125	ICP-MS
Dissolved Lead	MET121-6104 & MET-121-6105	SM 3125	ICP-MS
Dissolved Manganese	MET121-6104 & MET-121-6105	SM 3125	ICP-MS
Dissolved Molybdenum	MET121-6104 & MET-121-6105	SM 3125	ICP-MS
Dissolved Nickel	MET121-6104 & MET-121-6105	SM 3125	ICP-MS
Dissolved Phosphorus	MET-121-6104 & MET-121-6105	SM 3125	ICP-MS
Dissolved Selenium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS
Dissolved Silver	MET121-6104 & MET-121-6105	SM 3125	ICP-MS
Dissolved Strontium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS
Dissolved Thallium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS
Dissolved Tin	MET121-6104 & MET-121-6105	SM 3125	ICP-MS
Dissolved Titanium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS
Dissolved Uranium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS
Dissolved Vanadium	MET121-6104 & MET-121-6105	SM 3125	ICP-MS
Dissolved Zinc	MET121-6104 & MET-121-6105	SM 3125	ICP-MS

AGAT L	aborato	ories				Dartı	orris mout B3B tlabs	n, NS 1M2	Aı Aı H	rival old T	Con Terr	iditio nper	on: atur	e:	Go Go			oor (s		_	
Chain of Custody Record		P: 90	2.468	871	8 = F:	902.	468.	8924	A A	GAT J	ob N	lum	ber:		1	7x	2	87:	56	(.	
Report Information		rmation (Please print):			R	epor	t For	mat		lotes		5.	. r	\mathcal{N}	PN)					
Company: Roy Consummers Contact: GITNA BOETT Address: 364 Yonk ST Solo Forestation NB F3B 3P4 Phone: Solo 470 7473 Fax: Client Project #: 278 17 AGAT Quotation: 1749 7473 Please Note: If quotation number is not provided client will be billed full price for analysis Invoice To Same Yes N / No C Company:	Email: 94 2. Name: 4 Email: 4 Regulatory I List Guidelir PIRI DIRI Tier 1 Tier 2	Com N/Pot Fuel Lube CDWQ at NSEQS-Cont Sites rcial HRM 101	elines or Coa Fine	rse		per Mul per Exc Incl Exp	el Forn uded ort g Wate	ample nat	s Tu Re Re	arna egula ush T ate Re	roui ar T/ TAT equi	nd 1 AT		e Re 5 to Sam 2 day	ə qui 7 wo e da ys	red (rrking (((((((((((((((((((g day	/s day	Yes	1	No
Phone: Fax: PO/Credit Card#: Sample	Agricultu	ural 🗌 Waste Water	er Analysis		D CBOD			Total Phosphorus	H/RTFX (PIRI)		CCME-CWS TPH/BTEX							Coliform Coliform			Hazardous (Y/N)
Lab Matrix	# containers	Sample Containment	Stan	Merc	□ BOD	Ha	TKN	Total	Phenols Tier 1. TP	Tier	CCMI	VOC	THM	HAA	PAH	PCB		Eeca	Other:	Other:	Haza
	3 H	turray Corner	XX													>					
TCHEL PRESERVED METALS PRESERVED.																					
Samples Relinquished By (Print Name): A BRANN LEE Samples Relinquished By (Sign): Date/Time 12 Counsent ID: DIV 133-1501,004	11117	es Received By (Print Name): The period of the second of the second By (Sign);					Date/Tin	-N	OV 15	-	Yellov	v Сор	- Clie y - AG y- AG	GAT	Nº:	Page	*	of 5 4	1	: May 1	19, 2016 11

D

APPENDIX F

Environment Canada Daily Data Report and Tide Tables



<u>Home</u> \rightarrow <u>Environment and natural resources</u> \rightarrow <u>Weather, Climate and Hazard</u> \rightarrow <u>Past weather and climate</u> \rightarrow <u>Historical Data</u>

Daily Data Report for November 2017

MONCTON INTL A NEW BRUNSWICK

Latitude:	46 <u>°</u> 06 <u>'</u> 44.000 <u>" N</u>
Longitude:	64 <u>°</u> 40 <u>'</u> 43.000 <u>" W</u>
Elevation:	70.70 <u>m</u>
Climate ID:	8103201
WMO ID:	71705
<u>TC ID</u> :	YQM

	<u>Max</u> <u>Temp</u> ℃	<u>Min</u> Temp °C	<u>Mean</u> <u>Temp</u> <u>°C</u> ⊿	<u>Heat Deg</u> <u>Days</u> Lull	<u>Cool Deg</u> <u>Days</u> ull	<u>Total</u> <u>Rain</u> <u>mm</u> Juli	<u>Total</u> <u>Snow</u> <u>cm</u> เมป	<u>Total</u> <u>Precip</u> <u>mm</u> ابایا	Snow on <u>Grnd</u> cm	<u>Dir of Max</u> <u>Gust</u> <u>10's deg</u>	Spd of <u>Max Gust</u> <u>km/h</u> Lill
DAY											
<u>01 ±</u>	10.0	-0.8	4.6	13.4	0.0	0.0	0.0	0.0		23	43
<u>02 ±</u>	14.5	1.5	8.0	10.0	0.0	0.2	0.0	0.2		15	39
<u>03 ±</u>	19.7	5.8	12.8	5.2	0.0	9.2	0.0	9.2		20	61
<u>04 ‡</u>	8.7	-2.5	3.1	14.9	0.0	0.0	0.0	0.0		32	50
<u>05 ±</u>	11.9	-3.5	4.2	13.8	0.0	0.0	0.0	0.0		17	59
<u>06 ±</u>	19.8	2.3	11.1	6.9	0.0	23.0	0.0	23.0		21	72
<u>07 ±</u>	5.2	-0.4	2.4	15.6	0.0	0.2	0.4	1.4		32	33
<u>08 ±</u>	M	-1.2 <u>E</u>	M	M	<u>M</u>	0.0	0.0	0.0		1	33
<u>09 ±</u>	6.0	-3.4	1.3	16.7	0.0	0.0	0.0	0.0		24	20
<u>10 ±</u>	10.3	-6.9	1.7	16.3	0.0	4.2	0.2	4.2		25	69
<u>11 ±</u>	1.5	-7.2	-2.9	20.9	0.0	0.0	0.0	0.0		24	57
<u>12 ‡</u>	-0.3	-9.0	-4.7	22.7	0.0	0.0	0.0	0.0		28	26
<u>13 ±</u>	4.6	-9.0	-2.2	20.2	0.0	0.0	0.0	0.0		21	15

	<u>Max</u> <u>Temp</u> <u>°C</u>	<u>Min</u> <u>Temp</u> <u>°C</u> ⊿∡	<u>Mean</u> <u>Temp</u> <u>°C</u>	<u>Heat Deg</u> <u>Days</u> ull	<u>Cool Deg</u> <u>Days</u> ull	<u>Total</u> <u>Rain</u> <u>mm</u>	<u>Total</u> <u>Snow</u> <u>cm</u> Lıll	<u>Total</u> Precip <u>mm</u> ایابا	<u>Snow on</u> <u>Grnd</u> دانيا	<u>Dir of Max</u> <u>Gust</u> <u>10's deg</u>	<u>Spd o Max Gus</u> <u>km/ł</u> ایا
<u>14 ‡</u>	3.5	0.1	1.8	16.2	0.0	I	0.0	I		1	50
<u>15 ‡</u>	1.5	-2.8	-0.7	18.7	0.0	Ţ	0.0	I		35	24
<u>16 ±</u>	5.8	-3.3	1.3	16.7	0.0	4.8	0.0	4.8		7	44
<u>17 ±</u>	7.7	-2.2	2.8	15.2	0.0	4.5	0.5	5.0		28	59
<u>18 ±</u>	2.2	-3.9	-0.9	18.9	0.0	0.0	0.0	0.0		26	48
<u>19 ‡</u>	14.8	-0.1	7.4	10.6	0.0	9.8	0.0	9.8		26	5
<u>20 ±</u>	1.2	-8.0	-3.4	21.4	0.0	0.0	0.0	0.0		25	5
<u>21 ±</u>	6.5	-9.7	-1.6	19.6	0.0	0.0	0.0	0.0		24	5
<u>22 ‡</u>	14.4	3.2	8.8	9.2	0.0	36.8	0.0	36.8		34	5
<u>23 ±</u>	3.4	-4.5	-0.6	18.6	0.0	3.6	1.8	5.8	2	28	6
<u>24 ‡</u>	4.4	-4.2	0.1	17.9	0.0	0.0	0.0	0.0	1	26	3
<u>25 ±</u>	12.7	3.8	8.3	9.7	0.0	0.0	0.0	0.0		21	5
<u>26 ±</u>	6.5	-4.4	1.1	16.9	0.0	4.5	0.3	4.7	I	29	5
<u>27 ‡</u>	-1.9	-8.1	-5.0	23.0	0.0	0.2	Ţ	0.2	Ţ	25	4
<u>28 ±</u>	3.2	-10.6	-3.7	21.7	0.0	0.0	0.0	0.0		20	4
<u>29 ‡</u>	10.1	-3.7	3.2	14.8	0.0	0.8	0.0	0.8		23	5
<u>30 ‡</u>	1.5	-6.4	-2.5	20.5	0.0	0.0	0.0	0.0		29	2
Sum				466.2 <u>^</u>	0.0 <u>^</u>	101.8	3.2	105.9			
Avg	7.2 <u>^</u>	-3.3	1.9 <u>^</u>								
<u>Xtrm</u>	19.8 <u>^</u>	-10.6								21	7

Summary, average and extreme values are based on the data above.

Legend

- A = Accumulated
- C = Precipitation occurred, amount uncertain
- E = Estimated
- F = Accumulated and estimated
- L = Precipitation may or may not have occurred
- M = Missing
- N = Temperature missing but known to be > 0
- S = More than one occurrence
- T = Trace
- Y = Temperature missing but known to be < 0

CAPE TORMENTINE AST Z+4

2017

TIDE TABLES

		Janu	lary	-ja r	vier		February-février						March-mars										
Day	Time	Metres	Feet			mètres	pieds			Metres	Feet	jour	heure	mètres	pieds	Day	Time	Metres	Feet	0		mètres	pieds
	0013 0733 1420 1943	2.2 0.8 2.0 1.6	7.2 2.6 6.6 5.2	мо	0111 0808 1446 2042	2.3 0.6 2.1 1.1	7.5 2.0 6.9 3.6	WE	0148 0829 1442 2055	2.2 0.9 2.2 1.2	7.2 3.0 7.2 3.9	TH	0240 0858 1501 2134	2.1 1.1 2.1 1.0	6.9 3.6 6.9 3.3	WE	0059 0731 1324 1948	2.3 1.0 2.2 1.0	7.5 3.3 7.2 3.3	ТН	0141 0756 1343 2024	2.2 1.1 2.1 0.9	7.2 3.6 6.9 3.0
мо	0056 0807 1450 2027	2.2 0.9 2.1 1.5	7.2 3.0 6.9 4.9	TU	0203 0849 1522 2126	2.2 0.7 2.1 1.1	7.2 2.3 6.9 3.6	TH	0239 0909 1518 2142	2.2 1.0 2.2 1.1	7.2 3.3 7.2 3.6	FR	0330 0930 1528 2214	2.0 1.2 2.0 1.0	6.6 3.9 6.6 3.3	TH	0149 0811 1400 2032	2.3 1.0 2.2 1.0	7.5 3.3 7.2 3.3	FR	0228 0829 1410 2101	2.1 1.2 2.1 0.9	6.9 3.9 6.9 3.0
ΤU	0143 0844 1523 2115	2.2 0.9 2.1 1.4	7.2 3.0 6.9 4.6	WE	0253 0927 1553 2209	2.1 0.9 2.0 1.1	6.9 3.0 6.6 3.6	FR	0335 0950 1554 2232	2.1 1.1 2.2 1.1	6.9 3.6 7.2 3.6	SA	0425 1004 1557 2259	1.9 1.4 2.0 1.1	6.2 4.6 6.6 3.6	FR	0238 0850 1436 2115	2.2 1.1 2.2 0.9	7.2 3.6 7.2 3.0	SA	0318 0902 1438 2140	2.0 1.3 2.1 0.9	6.6 4.3 6.9 3.0
WE	0235 0925 1559 2207	2.1 1.0 2.1 1.3	6.9 3.3 6.9 4.3	ТН	0345 1003 1623 2253	2.0 1.1 2.0 1.1	6.6 3.6 6.6 3.6	SA	0437 1032 1634 2326	2.0 1.2 2.2 1.0	6.6 3.9 7.2 3.3	SU	0532 1043 1631 2354	1.9 1.5 2.0 1.1	6.2 4.9 6.6 3.6	SA	0329 0929 1513 2200	2.1 1.2 2.2 0.9	6.9 3.9 7.2 3.0	SU	0413 0936 1505 2221	1.9 1.5 2.0 1.0	6.2 4.9 6.6 3.3
TH	0335 1009 1637 2303	2.0 1.1 2.2 1.3	6.6 3.6 7.2 4.3	FR	0444 1040 1654 2342	1.9 1.2 2.0 1.1	6.2 3.9 6.6 3.6		0549 1118 1718	1.9 1.3 2.2	6.2 4.3 7.2		0651 1132 1715	1.8 1.6 2.0	5.9 5.2 6.6	SU	0424 1009 1554 2251	2.0 1.3 2.2 0.9	6.6 4.3 7.2 3.0	мо	0517 1012 1533 2308	1.9 1.6 2.0 1.1	6.2 5.2 6.6 3.6
	0447 1057 1718	2.0 1.2 2.2	6.6 3.9 7.2		0552 1124 1732	1.8 1.4 2.0	5.9 4.6 6.6	мо	0029 0709 1213 1810	1.0 1.9 1.4 2.3	3.3 6.2 4.6 7.5	TU	0102 0822 1241 1814	1.1 1.8 1.7 2.0		мо	0529 1055 1642 2352	1.9 1.4 2.2 0.9	6.2 4.6 7.2 3.0	41	0631 1054 1606	1.9 1.7 2.0	6.2 5.6 6.6
SA	0004 0611 1150 1802	1.2 1.9 1.3 2.2	3.9 6.2 4.3 7.2	SU	0042 0712 1219 1819	1.1 1.8 1.5 2.0	3.6 5.9 4.9 6.6	TU	0138 0828 1320 1910	0.9 1.9 1.5 2.3	3.0 6.2 4.9 7.5	WE	0217 0943 1422 1926	1.1 1.9 1.8 2.0	3.6 6.2 5.9 6.6		0643 1152 1741	1.9 1.4 2.2	6.2 4.6 7.2	WE	0005 0750 1159 1701	1.2 1.9 1.8 1.9	3.9 6.2 5.9 6.2
SU	0110 0735 1248 1850	1.1 1.9 1.4 2.3	3.6 6.2 4.6 7.5	мо	0151 0838 1330 1913	1.1 1.9 1.6 2.0	3.6 6.2 5.2 6.6	WE	0247 0939 1437 2015	0.8 2.0 1.5 2.3	2.6 6.6 4.9 7.5	TH	0320 1030 1538 2034	1.1 1.9 1.7 2.0		WE	0105 0802 1305 1850	0.9 1.9 1.5 2.2	3.0 6.2 4.9 7.2	ТН	0115 0852 1347 1842	1.2 1.9 1.8 1.9	3.9 6.2 5.9 6.2
мо	0215 0852 1352 1941	0.9 1.9 1.5 2.3	3.0 6.2 4.9 7.5		0258 0955 1453 2009	1.1 1.9 1.7 2.0	3.6 6.2 5.6 6.6	TH	0350 1038 1553 2119	0.7 2.0 1.5 2.3	2.3 6.6 4.9 7.5	FR	0409 1057 1623 2134	1.1 2.0 1.7 2.1	3.6 6.6 5.6 6.9	-	0221 0914 1429 2003	0.8 2.0 1.5 2.2	2.6 6.6 4.9 7.2	FR	0223 0926 1504 2014	1.2 1.9 1.7 2.0	3.9 6.2 5.6 6.6
TU	0315 0959 1459 2036	0.8 2.0 1.5 2.3	2.6 6.6 4.9 7.5	WE	0355 1053 1602 2102	1.0 2.0 1.7 2.1	3.3 6.6 5.6 6.9	FR	0445 1129 1659 2220	0.6 2.1 1.4 2.4	2.0 6.9 4.6 7.9	SA	0451 1120 1700 2228	1.0 2.0 1.5 2.2	3.3 6.6 4.9 7.2	FR	0330 1014 1545 2113	0.7 2.0 1.4 2.3	2.3 6.6 4.6 7.5	SA	0321 0952 1552 2124	1.2 2.0 1.5 2.1	3.9 6.6 4.9 6.9
WE	0410 1056 1607 2131	0.6 2.1 1.5 2.4	2.0 6.9 4.9 7.9	ТН	0442 1137 1650 2151	0.9 2.0 1.7 2.1	3.0 6.6 5.6 6.9	SA	0536 1215 1756 2318	0.5 2.1 1.3 2.4	1.6 6.9 4.3 7.9	SU	0530 1145 1739 2319	1.0 2.0 1.4 2.3	3.3 6.6 4.6 7.5	SA	0428 1103 1648 2217	0.7 2.1 1.3 2.3	2.3 6.9 4.3 7.5	SU	0411 1020 1634 2223	1.1 2.0 1.4 2.2	3.6 6.6 4.6 7.2
TH	0501 1148 1710 2228	0.5 2.1 1.4 2.4	1.6 6.9 4.6 7.9	FR	0523 1210 1728 2237	0.9 2.0 1.6 2.2	3.0 6.6 5.2 7.2		0624 1257 1847	0.5 2.1 1.2	1.6 6.9 3.9		0609 1215 1821	1.0 2.1 1.3	3.3 6.9 4.3	SU	0519 1145 1740 2314	0.7 2.1 1.1 2.3	2.3 6.9 3.6 7.5	мо	0457 1052 1717 2317	1.1 2.1 1.2 2.3	3.6 6.9 3.9 7.5
FR	0550 1236 1808 2323	0.4 2.2 1.3 2.4	1.3 7.2 4.3 7.9	SA	0559 1238 1803 2323	0.9 2.0 1.6 2.2	3.0 6.6 5.2 7.2	MO	0012 0708 1334 1933	2.3 0.6 2.1 1.1	7.5 2.0 6.9 3.6	TU	0010 0650 1249 1904	2.3 1.0 2.1 1.1		13 MO LU	0605 1220 1826	0.7 2.1 1.0	2.3 6.9 3.3	-0	0542 1127 1759	1.1 2.1 1.0	3.6 6.9 3.3
	0637 1322 1903	0.4 2.2 1.3	1.3 7.2 4.3		0635 1305 1842	0.9 2.0 1.5	3.0 6.6 4.9	TU	0103 0748 1407 2016	2.3 0.7 2.1 1.0	7.5 2.3 6.9 3.3					TU	0005 0646 1250 1908	2.3 0.8 2.1 0.9	7.5 2.6 6.9 3.0	WE	0008 0626 1204 1843	2.3 1.1 2.2 0.9	7.5 3.6 7.2 3.0
SU	0018 0724 1406 1954	2.3 0.5 2.2 1.2	7.5 1.6 7.2 3.9	мо	0009 0712 1335 1924	2.3 0.9 2.1 1.4	7.5 3.0 6.9 4.6	WE	0152 0825 1435 2056	2.2 0.9 2.1 1.0	7.2 3.0 6.9 3.3					WE	0054 0723 1317 1947	2.2 1.0 2.1 0.9	7.2 3.3 6.9 3.0	ΤН	0057 0709 1241 1925	2.3 1.1 2.2 0.8	7.5 3.6 7.2 2.6
				TU	0058 0750 1408 2009	2.3 0.9 2.1 1.3	7.5 3.0 6.9 4.3													FR	0145 0750 1319 2007	2.3 1.2 2.2 0.8	7.5 3.9 7.2 2.6

Copyright Canadian Hydrographic Service, Reproduction without permission prohibited Copyright Service hydrographique du Canada, Toute reproduction non-autorisée est interdite

1

TABLE DES MARÉES

2017

CAPE TORMENTINE HNA Z+4

		A	pril	-avi	·il		May-mai						ieds Day Time Metres Feet jour heure mètres pieds										
Day	Time	Metres	Feet	ÿ		mètres	pieds	Day	Time	Metres	Feet	0		mètres	pieds	Day	Time	Metres	Feet	Ū		mètres	pieds
1 SA SA	0233 0830 1357 2049	2.2 1.2 2.3 0.7	7.2 3.9 7.5 2.3	SU	0311 0840 1354 2111	2.0 1.5 2.1 0.9	6.6 4.9 6.9 3.0		0313 0855 1412 2113	2.2 1.3 2.3 0.6	7.2 4.3 7.5 2.0	16 TU MA	0354 0859 1346 2117	2.0 1.7 2.1 0.9	6.6 5.6 6.9 3.0		0440 1031 1551 2241	2.1 1.3 2.1 0.8	6.9 4.3 6.9 2.6	FR	0423 1001 1502 2203	2.0 1.6 2.0 1.1	6.6 5.2 6.6 3.6
	0321 0910 1438 2133	2.1 1.3 2.3 0.7	6.9 4.3 7.5 2.3	мо	0406 0915 1420 2147	2.0 1.6 2.0 1.0	6.6 5.2 6.6 3.3	-	0403 0944 1503 2204	2.1 1.3 2.2 0.7	6.9 4.3 7.2 2.3		0437 0934 1418 2149	2.0 1.7 2.0 1.0	6.6 5.6 6.6 3.3	FR	0531 1130 1657 2339	2.0 1.3 2.0 1.0	6.6 4.3 6.6 3.3	SA	0455 1058 1614 2252	2.1 1.5 1.9 1.2	6.9 4.9 6.2 3.9
3 MO LU	0413 0952 1523 2224	2.1 1.3 2.2 0.8	6.9 4.3 7.2 2.6	18 TU MA	0503 0950 1446 2224	1.9 1.7 2.0 1.1	6.2 5.6 6.6 3.6		0459 1038 1601 2302	2.0 1.3 2.2 0.8	6.6 4.3 7.2 2.6		0514 1018 1501 2228	1.9 1.7 2.0 1.1	6.2 5.6 6.6 3.6	3 SA SA	0623 1234 1812	2.0 1.3 1.9	6.6 4.3 6.2	18 SU DI	0533 1203 1751 2350	2.1 1.4 1.9 1.3	6.9 4.6 6.2 4.3
	0513 1043 1617 2324	2.0 1.4 2.2 0.8	6.6 4.6 7.2 2.6	WE	0559 1030 1519 2309	1.9 1.7 2.0 1.1	6.2 5.6 6.6 3.6	-	0559 1142 1709	2.0 1.4 2.1	6.6 4.6 6.9		0549 1119 1609 2321	2.0 1.6 1.9 1.2	6.6 5.2 6.2 3.9	-	0042 0712 1341 1931	1.1 2.0 1.2 1.9	3.6 6.6 3.9 6.2		0617 1312 1926	2.2 1.3 1.9	7.2 4.3 6.2
5 WE ME	0622 1145 1721	1.9 1.4 2.2	6.2 4.6 7.2	20 TH JE	0651 1136 1617	1.9 1.7 1.9	6.2 5.6 6.2	FR	0009 0703 1254 1827	0.9 2.0 1.3 2.0	3.0 6.6 4.3 6.6	20 SA SA	0626 1235 1801	2.0 1.6 1.9	6.6 5.2 6.2		0147 0757 1445 2045	1.2 2.0 1.1 2.0	3.9 6.6 3.6 6.6	TU	0055 0704 1419 2047	1.4 2.2 1.1 2.0	4.6 7.2 3.6 6.6
	0036 0735 1301 1837	0.9 1.9 1.4 2.1	3.0 6.2 4.6 6.9		0007 0733 1308 1813	1.2 1.9 1.7 1.9	3.9 6.2 5.6 6.2		0122 0804 1409 1947	1.0 2.0 1.3 2.0	3.3 6.6 4.3 6.6		0027 0708 1348 1944	1.3 2.1 1.4 1.9	4.3 6.9 4.6 6.2		0249 0837 1539 2150	1.3 2.0 1.0 2.0	4.3 6.6 3.3 6.6	21 WE ME	0202 0752 1517 2155	1.4 2.3 0.9 2.1	4.6 7.5 3.0 6.9
, FR	0154 0843 1423 1956	0.9 2.0 1.4 2.1	3.0 6.6 4.6 6.9	SA	0117 0810 1425 1959	1.3 2.0 1.6 1.9	4.3 6.6 5.2 6.2	, SU	0233 0855 1515 2100	1.1 2.0 1.2 2.1	3.6 6.6 3.9 6.9		0137 0752 1451 2103	1.3 2.1 1.2 2.0	4.3 6.9 3.9 6.6		0343 0915 1627 2246	1.4 2.1 0.9 2.1	4.6 6.9 3.0 6.9	22 TH JE	0307 0840 1609 2253	1.5 2.3 0.7 2.1	4.9 7.5 2.3 6.9
	0306 0941 1534 2109	0.9 2.0 1.3 2.2	3.0 6.6 4.3 7.2		0226 0847 1521 2115	1.3 2.0 1.4 2.1	4.3 6.6 4.6 6.9	8 MO LU	0334 0936 1608 2203	1.1 2.0 1.1 2.1	3.6 6.6 3.6 6.9	23 TU MA	0244 0837 1545 2208	1.4 2.2 1.0 2.1	4.6 7.2 3.3 6.9	8 TH JE	0430 0953 1711 2339	1.4 2.1 0.8 2.1	4.6 6.9 2.6 6.9	23 FR VE	0407 0928 1656 2344	1.5 2.3 0.6 2.2	4.9 7.5 2.0 7.2
	0406 1026 1631 2212	0.9 2.0 1.1 2.2	3.0 6.6 3.6 7.2		0327 0925 1610 2217	1.3 2.1 1.2 2.2	4.3 6.9 3.9 7.2	9 TU MA	0424 1009 1654 2257	1.2 2.0 0.9 2.1	3.9 6.6 3.0 6.9	24 WE ME	0346 0920 1633 2304	1.4 2.3 0.8 2.2	4.6 7.5 2.6 7.2		0515 1031 1753	1.5 2.2 0.7	4.9 7.2 2.3	24 SA SA	0504 1017 1742	1.5 2.4 0.5	4.9 7.9 1.6
	0456 1102 1719 2307	0.9 2.1 1.0 2.2	3.0 6.9 3.3 7.2	25 TU MA	0422 1003 1655 2312	1.2 2.2 1.0 2.3	3.9 7.2 3.3 7.5	WE	0506 1039 1735 2346	1.2 2.1 0.8 2.2	3.9 6.9 2.6 7.2	25 TH JE	0441 1002 1717 2355	1.4 2.3 0.7 2.2	4.6 7.5 2.3 7.2	SA	0029 0559 1110 1835	2.1 1.5 2.2 0.7	6.9 4.9 7.2 2.3		0031 0558 1109 1827	2.2 1.4 2.4 0.4	7.2 4.6 7.9 1.3
TU	0539 1132 1801 2356	1.0 2.1 0.9 2.2	3.3 6.9 3.0 7.2		0513 1043 1739	1.2 2.2 0.8	3.9 7.2 2.6		0545 1110 1815	1.3 2.1 0.7	4.3 6.9 2.3		0532 1045 1801	1.4 2.3 0.6	4.6 7.5 2.0	SU	0119 0643 1147 1914	2.1 1.6 2.2 0.7	6.9 5.2 7.2 2.3	мо	0116 0651 1201 1912	2.2 1.4 2.4 0.4	7.2 4.6 7.9 1.3
12 WE ME	0617 1159 1840	1.1 2.1 0.8	3.6 6.9 2.6	ТН	0003 0600 1122 1821	2.3 1.3 2.3 0.7	7.5 4.3 7.5 2.3	FR	0035 0624 1143 1854	2.1 1.4 2.2 0.7	6.9 4.6 7.2 2.3	SA	0043 0620 1130 1843	2.2 1.4 2.3 0.5		мо	0207 0725 1222 1950	2.0 1.6 2.2 0.8	6.6 5.2 7.2 2.6	TU	0201 0743 1255 1959	2.2 1.3 2.3 0.5	7.2 4.3 7.5 1.6
TH	0043 0653 1226 1918	2.2 1.2 2.1 0.8	7.2 3.9 6.9 2.6	FR	0052 0645 1202 1903	2.3 1.3 2.3 0.6	7.5 4.3 7.5 2.0	SA	0124 0703 1217 1933	2.1 1.5 2.2 0.7	6.9 4.9 7.2 2.3	SU	0129 0707 1216 1926	2.2 1.4 2.3 0.5	7.2 4.6 7.5 1.6	TU	0251 0803 1255 2022	2.0 1.6 2.1 0.8	6.6 5.2 6.9 2.6	WE	0245 0834 1349 2045	2.2 1.2 2.3 0.6	7.2 3.9 7.5 2.0
FR	0131 0728 1256 1956	2.1 1.3 2.1 0.8	6.9 4.3 6.9 2.6	SA	0139 0728 1243 1944	2.3 1.3 2.3 0.6	7.5 4.3 7.5 2.0	SU	0215 0743 1249 2011	2.1 1.5 2.2 0.8	6.9 4.9 7.2 2.6	мо	0215 0755 1305 2011	2.2 1.3 2.3 0.5	7.2 4.3 7.5 1.6	WE	0326 0838 1329 2051	2.0 1.6 2.1 0.9	6.6 5.2 6.9 3.0	ТН	0329 0924 1444 2132	2.1 1.2 2.2 0.7	6.9 3.9 7.2 2.3
SA	0220 0803 1326 2034	2.1 1.4 2.1 0.8	6.9 4.6 6.9 2.6	SU	0225 0811 1326 2027	2.2 1.3 2.3 0.6	7.2 4.3 7.5 2.0	MO	0306 0822 1319 2046	2.0 1.6 2.1 0.8	6.6 5.2 6.9 2.6	TU	0302 0845 1357 2058	2.2 1.3 2.3 0.6	7.2 4.3 7.5 2.0	TH	0356 0915 1410 2123	2.0 1.6 2.0 1.0	6.6 5.2 6.6 3.3	FR	0412 1015 1541 2218	2.1 1.2 2.1 0.9	6.9 3.9 6.9 3.0
												WE	0350 0937 1451 2148	2.1 1.3 2.2 0.7	6.9 4.3 7.2 2.3								

 $Copyright\ Canadian\ Hydrographic\ Service,\ Reproduction\ without\ permission\ prohibited$

Copyright Service hydrographique du Canada, Toute reproduction non-autorisée est interdite

CAPE TORMENTINE AST Z+4

2017

TIDE TABLES

	July-juillet									Aı	igus	t-ao	ût				Se	ptem	ıber	-sep	temb	ore	
Day	Time	Metres	Feet	5	heure	mètres		Day	Time	Metres	Feet	-		mètres	pieds	Day	Time	Metres	Feet	0	heure	mètres	pieds
	0453 1106 1642 2304	2.0 1.2 2.0 1.1	6.6 3.9 6.6 3.6		0409 1032 1616 2229	2.2 1.3 2.0 1.2	7.2 4.3 6.6 3.9	1 TU MA	0508 1212 1840 2353	2.0 1.1 1.8 1.5	6.6 3.6 5.9 4.9	WE	0449 1156 1841 2345	2.2 1.0 1.9 1.5	7.2 3.3 6.2 4.9	1 FR VE	0020 0552 1349 2116	1.7 2.0 1.1 1.9	5.6 6.6 3.6 6.2		0031 0612 1341 2041	1.5 2.2 0.9 1.9	4.9 7.2 3.0 6.2
SU	0532 1200 1751 2354	2.0 1.2 1.9 1.2	6.6 3.9 6.2 3.9	11/	0448 1130 1738 2320	2.2 1.2 1.9 1.3	7.2 3.9 6.2 4.3	-	0551 1318 2004	2.0 1.1 1.8	6.6 3.6 5.9	17 TH JE	0538 1303 2001	2.2 0.9 1.9	7.2 3.0 6.2		0204 0710 1502 2218	1.7 2.0 1.1 1.9	5.6 6.6 3.6 6.2		0153 0727 1452 2141	1.5 2.2 0.8 2.0	4.9 7.2 2.6 6.6
3 MO LU	0611 1301 1906	2.0 1.2 1.9	6.6 3.9 6.2		0532 1235 1905	2.2 1.1 1.9	7.2 3.6 6.2	тн	0056 0646 1431 2127	1.6 2.0 1.1 1.9	5.2 6.6 3.6 6.2		0049 0637 1413 2113	1.5 2.2 0.8 1.9	4.9 7.2 2.6 6.2		0333 0825 1559 2253	1.7 2.0 1.1 1.9	5.6 6.6 3.6 6.2	18 MO LU	0313 0842 1555 2232	1.4 2.2 0.7 2.1	4.6 7.2 2.3 6.9
TU	0049 0653 1405 2024	1.4 2.0 1.1 1.9	4.6 6.6 3.6 6.2		0017 0619 1343 2027	1.4 2.2 1.0 1.9	4.6 7.2 3.3 6.2		0220 0747 1535 2235	1.7 2.0 1.0 1.9	5.6 6.6 3.3 6.2		0204 0742 1518 2213	1.6 2.3 0.7 2.0	5.2 7.5 2.3 6.6	4 MO LU	0423 0928 1644 2316	1.7 2.1 1.1 2.0	5.6 6.9 3.6 6.6	19 TU MA	0419 0950 1650 2315	1.3 2.3 0.7 2.1	4.3 7.5 2.3 6.9
	0151 0739 1507 2137	1.5 2.0 1.0 1.9	4.9 6.6 3.3 6.2		0121 0711 1447 2138	1.5 2.3 0.9 2.0	4.9 7.5 3.0 6.6		0342 0847 1629 2325	1.7 2.1 0.9 2.0	5.6 6.9 3.0 6.6		0322 0848 1616 2303	1.5 2.3 0.6 2.1	4.9 7.5 2.0 6.9	5 TU MA	0457 1020 1722 2336	1.6 2.1 1.0 2.0	5.2 6.9 3.3 6.6	20 WE ME	0515 1051 1739 2353	1.1 2.3 0.7 2.1	3.6 7.5 2.3 6.9
TH	0257 0827 1601 2239	1.6 2.1 0.9 2.0	5.2 6.9 3.0 6.6	21 FR VE	0230 0806 1544 2237	1.6 2.3 0.7 2.0	5.2 7.5 2.3 6.6	U	0440 0942 1714	1.7 2.1 0.9	5.6 6.9 3.0	21 MO LU	0431 0953 1709 2347	1.4 2.3 0.6 2.1	4.6 7.5 2.0 6.9	6 WE ME	0529 1108 1757 2358	1.4 2.2 1.0 2.0	4.6 7.2 3.3 6.6	21 TH JE	0604 1147 1824	1.0 2.3 0.8	3.3 7.5 2.6
	0359 0916 1650 2334	1.6 2.1 0.8 2.0	5.2 6.9 2.6 6.6	SA	0339 0903 1636 2327	1.5 2.3 0.6 2.1	4.9 7.5 2.0 6.9		0004 0524 1031 1753	2.0 1.6 2.2 0.9	6.6 5.2 7.2 3.0		0530 1054 1758	1.3 2.4 0.6	4.3 7.9 2.0		0604 1155 1834	1.3 2.3 1.0	4.3 7.5 3.3	22 FR VE	0027 0648 1239 1905	2.1 0.9 2.3 0.9	6.9 3.0 7.5 3.0
8 SA SA	0454 1002 1735	1.6 2.2 0.8	5.2 7.2 2.6		0444 1000 1725	1.5 2.4 0.5	4.9 7.9 1.6	TU	0034 0559 1115 1828	2.0 1.6 2.2 0.9	6.6 5.2 7.2 3.0	WE	0029 0622 1151 1844	2.2 1.1 2.4 0.6	7.2 3.6 7.9 2.0	FR	0026 0642 1242 1911	2.1 1.2 2.3 1.0	6.9 3.9 7.5 3.3	23 SA SA	0057 0729 1327 1941	2.1 0.8 2.2 1.1	6.9 2.6 7.2 3.6
SU	0023 0542 1046 1816	2.0 1.6 2.2 0.8	6.6 5.2 7.2 2.6	24 MO LU	0013 0542 1058 1813	2.2 1.4 2.4 0.5	7.2 4.6 7.9 1.6		0058 0633 1158 1901	2.0 1.5 2.2 0.9	6.6 4.9 7.2 3.0		0108 0710 1245 1928	2.2 1.0 2.3 0.7	7.2 3.3 7.5 2.3		0059 0724 1330 1950	2.1 1.1 2.3 1.1	6.9 3.6 7.5 3.6	24 SU DI	0124 0807 1414 2015	2.1 0.8 2.1 1.2	6.9 2.6 6.9 3.9
	0107 0624 1127 1854	2.0 1.6 2.2 0.8	6.6 5.2 7.2 2.6	25 TU MA	0056 0637 1154 1859	2.2 1.3 2.4 0.5	7.2 4.3 7.9 1.6		0122 0708 1243 1935	2.0 1.4 2.2 0.9	6.6 4.6 7.2 3.0		0143 0755 1337 2008	2.1 1.0 2.2 0.9	6.9 3.3 7.2 3.0	10 SU DI	0134 0807 1419 2030	2.2 1.0 2.2 1.1	7.2 3.3 7.2 3.6	25 MO LU	0150 0844 1503 2048	2.1 0.8 2.0 1.3	6.9 2.6 6.6 4.3
TU	0145 0702 1205 1927	2.0 1.6 2.2 0.8	6.6 5.2 7.2 2.6	WE	0139 0729 1250 1945	2.2 1.2 2.3 0.6	7.2 3.9 7.5 2.0	FR	0148 0748 1329 2010	2.1 1.3 2.2 1.0	6.9 4.3 7.2 3.3	SA	0214 0837 1426 2045	2.1 0.9 2.1 1.0	6.9 3.0 6.9 3.3	мо	0211 0851 1510 2109	2.2 0.9 2.1 1.2	7.2 3.0 6.9 3.9	TU	0218 0921 1555 2122	2.1 0.8 2.0 1.5	6.9 2.6 6.6 4.9
WE	0215 0737 1245 1958	2.0 1.6 2.2 0.9	6.6 5.2 7.2 3.0	ТН	0220 0817 1344 2029	2.2 1.1 2.3 0.7	7.2 3.6 7.5 2.3	SA	0218 0830 1418 2048	2.1 1.2 2.2 1.0	6.9 3.9 7.2 3.3	SU	0242 0916 1515 2118	2.1 0.9 2.0 1.2	6.9 3.0 6.6 3.9	TU	0248 0936 1605 2149	2.2 0.9 2.1 1.3	7.2 3.0 6.9 4.3		0248 1001 1654 2201	2.1 0.9 1.9 1.6	6.9 3.0 6.2 5.2
TH	0241 0813 1326 2030	2.0 1.5 2.1 0.9	6.6 4.9 6.9 3.0	FR	0258 0904 1436 2111	2.1 1.1 2.2 0.8	6.9 3.6 7.2 2.6	SU	0252 0916 1512 2127	2.2 1.1 2.1 1.1	7.2 3.6 6.9 3.6	мо	0308 0954 1606 2150	2.1 0.9 2.0 1.3	6.9 3.0 6.6 4.3	WE	0327 1024 1706 2232	2.2 0.9 2.0 1.4	7.2 3.0 6.6 4.6	тн	0319 1047 1804 2250	2.0 1.0 1.9 1.7	6.6 3.3 6.2 5.6
FR	0306 0853 1414 2105	2.1 1.4 2.1 1.0	6.9 4.6 6.9 3.3	SA	0332 0948 1529 2149	2.1 1.0 2.0 1.0	6.9 3.3 6.6 3.3	МО	0328 1004 1612 2209	2.2 1.1 2.0 1.2	7.2 3.6 6.6 3.9	TU	0336 1036 1706 2226	2.0 1.0 1.9 1.5	6.6 3.3 6.2 4.9	TH	0412 1120 1816 2324	2.2 0.9 1.9 1.5	7.2 3.0 6.2 4.9		0355 1144 1924	2.0 1.1 1.9	6.6 3.6 6.2
SA	0335 0940 1508 2144	2.1 1.4 2.0 1.1	6.9 4.6 6.6 3.6	SU	0403 1032 1624 2226	2.0 1.1 2.0 1.2	6.6 3.6 6.6 3.9	TU	0406 1057 1722 2254	2.2 1.0 1.9 1.3	7.2 3.3 6.2 4.3	WE	0409 1126 1819 2312	2.0 1.0 1.8 1.6	6.6 3.3 5.9 5.2	15 FR VE	0506 1226 1931	2.2 0.9 1.9	7.2 3.0 6.2		0004 0449 1255 2038	1.7 1.9 1.2 1.9	5.6 6.2 3.9 6.2
				мо	0433 1118 1726 2305	2.0 1.1 1.9 1.3	6.6 3.6 6.2 4.3					-	0452 1231 1946	2.0 1.1 1.8	6.6 3.6 5.9								

Copyright Canadian Hydrographic Service, Reproduction without permission prohibited

Copyright Service hydrographique du Canada, Toute reproduction non-autorisée est interdite

TABLE DES MARÉES

2017

CAPE TORMENTINE HNA Z+4

		Octo	ber	-oct	obre				N	ovem	ber	-nov	emb	re			D	ecem	ber	-déc	emb	re	
	Time	Metres		3	heure							0						Metres		0		mètres	
SU	0155 0629 1409 2122	1.7 1.9 1.2 1.9	5.6 6.2 3.9 6.2	мо	0146 0719 1425 2104	1.4 2.1 0.9 2.0	4.6 6.9 3.0 6.6	WE ME	0306 0857 1503 2059	1.4 2.0 1.3 2.1	4.6 6.6 4.3 6.9	TH	0344 0939 1556 2145	1.0 2.1 1.2 2.1	3.3 6.9 3.9 6.9	FR VE	0318 0946 1515 2051	1.1 2.1 1.5 2.2	3.6 6.9 4.9 7.2	SA	0408 1029 1606 2131	0.9 2.0 1.4 2.1	3.0 6.6 4.6 6.9
мо	0309 0804 1511 2145	1.7 1.9 1.2 1.9	5.6 6.2 3.9 6.2	TU	0302 0838 1531 2154	1.3 2.1 0.9 2.1	4.3 6.9 3.0 6.9	TH	0349 0959 1557 2136	1.2 2.1 1.3 2.1	3.9 6.9 4.3 6.9	FR	0434 1039 1644 2218	0.9 2.1 1.2 2.1	3.0 6.9 3.9 6.9	SA	0408 1044 1614 2136	0.9 2.2 1.5 2.3	3.0 7.2 4.9 7.5	SU	0454 1123 1653 2211	0.8 2.0 1.5 2.2	2.6 6.6 4.9 7.2
TU	0350 0914 1559 2206	1.6 2.0 1.2 2.0	5.2 6.6 3.9 6.6	WE	0404 0947 1627 2234	1.1 2.2 0.9 2.1	3.6 7.2 3.0 6.9	FR	0432 1053 1648 2215	1.0 2.2 1.3 2.2	3.3 7.2 4.3 7.2	SA	0518 1131 1725 2250	0.8 2.1 1.3 2.2	2.6 6.9 4.3 7.2	SU	0455 1137 1708 2221	0.7 2.2 1.5 2.3	2.3 7.2 4.9 7.5		0537 1214 1738 2251	0.7 2.1 1.5 2.2	2.3 6.9 4.9 7.2
WE	0423 1010 1641 2231	1.4 2.1 1.2 2.0	4.6 6.9 3.9 6.6	ТН	0457 1047 1715 2308	1.0 2.2 1.0 2.1	3.3 7.2 3.3 6.9	SA SA	0516 1145 1737 2256	0.9 2.3 1.3 2.3	3.0 7.5 4.3 7.5	SU	0559 1221 1804 2323	0.7 2.1 1.4 2.2	2.3 6.9 4.6 7.2	-	0540 1227 1759 2306	0.6 2.2 1.5 2.3	2.0 7.2 4.9 7.5	19 TU MA	0619 1304 1825 2332	0.7 2.0 1.6 2.2	2.3 6.6 5.2 7.2
TH	0459 1101 1723 2302	1.2 2.2 1.2 2.1	3.9 7.2 3.9 6.9	FR	0542 1140 1757 2338	0.9 2.2 1.1 2.1	3.0 7.2 3.6 6.9	SU	0559 1234 1824 2337	0.7 2.3 1.3 2.3	2.3 7.5 4.3 7.5	мо	0638 1310 1844 2358	0.6 2.1 1.5 2.2	2.0 6.9 4.9 7.2	TU	0623 1314 1847 2353	0.5 2.2 1.4 2.3	1.6 7.2 4.6 7.5		0701 1353 1911	0.7 2.0 1.6	2.3 6.6 5.2
FR	0538 1150 1805 2337	1.1 2.3 1.2 2.2	3.6 7.5 3.9 7.2		0623 1230 1836	0.8 2.2 1.2	2.6 7.2 3.9	_	0642 1323 1909	0.6 2.3 1.4	2.0 7.5 4.6		0718 1359 1926	0.6 2.1 1.5	2.0 6.9 4.9		0706 1358 1934	0.5 2.2 1.4	1.6 7.2 4.6	TH	0012 0740 1440 1957	2.2 0.7 2.0 1.6	7.2 2.3 6.6 5.2
	0620 1239 1848	0.9 2.3 1.2	3.0 7.5 3.9	SU	0007 0702 1317 1912	2.1 0.7 2.1 1.3	6.9 2.3 6.9 4.3	TU	0019 0724 1410 1952	2.3 0.6 2.2 1.4	7.5 2.0 7.2 4.6	WE	0034 0757 1451 2010	2.2 0.7 2.0 1.6	7.2 2.3 6.6 5.2	TH	0041 0750 1442 2022	2.3 0.5 2.2 1.3	7.5 1.6 7.2 4.3	FR	0049 0816 1520 2038	2.2 0.8 2.0 1.6	7.2 2.6 6.6 5.2
SU	0015 0703 1328 1930	2.2 0.8 2.3 1.2	7.2 2.6 7.5 3.9	мо	0036 0740 1405 1947	2.2 0.7 2.1 1.4	7.2 2.3 6.9 4.6	WE	0102 0806 1456 2035	2.3 0.6 2.2 1.4	7.5 2.0 7.2 4.6	TH	0108 0835 1542 2056	2.1 0.8 2.0 1.6	6.9 2.6 6.6 5.2	FR	0131 0835 1526 2111	2.3 0.5 2.1 1.3	7.5 1.6 6.9 4.3	SA	0125 0847 1551 2115	2.1 0.9 2.0 1.6	6.9 3.0 6.6 5.2
мо	0054 0745 1416 2011	2.2 0.8 2.2 1.3	7.2 2.6 7.2 4.3	TU	0106 0817 1456 2025	2.1 0.7 2.0 1.5	6.9 2.3 6.6 4.9	TH	0147 0850 1543 2121	2.3 0.6 2.1 1.4	7.5 2.0 6.9 4.6	FR	0141 0910 1629 2140	2.1 0.9 2.0 1.7	6.9 3.0 6.6 5.6	SA	0225 0922 1612 2203	2.2 0.6 2.1 1.3	7.2 2.0 6.9 4.3	SU	0201 0915 1615 2152	2.0 1.0 2.0 1.6	6.6 3.3 6.6 5.2
ΤU	0133 0827 1505 2051	2.3 0.7 2.2 1.3	7.5 2.3 7.2 4.3	WE	0138 0855 1549 2106	2.1 0.8 2.0 1.6	6.9 2.6 6.6 5.2	FR	0235 0937 1634 2212	2.2 0.7 2.1 1.4	7.2 2.3 6.9 4.6	SA	0212 0943 1709 2224	2.0 1.0 2.0 1.7	6.6 3.3 6.6 5.6	SU	0322 1013 1700 2259	2.2 0.7 2.1 1.2	7.2 2.3 6.9 3.9	мо	0244 0946 1637 2236	2.0 1.1 2.0 1.5	6.6 3.6 6.6 4.9
WE	0213 0910 1555 2132	2.3 0.7 2.1 1.4	7.5 2.3 6.9 4.6	ТН	0209 0933 1646 2150	2.1 0.9 1.9 1.7	6.9 3.0 6.2 5.6	SA	0330 1030 1728 2310	2.2 0.7 2.0 1.4	7.2 2.3 6.6 4.6	SU	0248 1017 1741 2314	1.9 1.1 2.0 1.7	6.2 3.6 6.6 5.6	мо	0426 1108 1750	2.1 0.9 2.0	6.9 3.0 6.6	TU	0345 1026 1706 2331	1.9 1.2 2.1 1.4	6.2 3.9 6.9 4.6
TH	0256 0957 1651 2219	2.2 0.8 2.0 1.4	7.2 2.6 6.6 4.6	FR	0239 1013 1745 2242	2.0 1.0 1.9 1.7	6.6 3.3 6.2 5.6		0434 1132 1827	2.1 0.8 2.0	6.9 2.6 6.6		0343 1059 1809	1.9 1.2 2.0	6.2 3.9 6.6		0000 0539 1208 1840	1.2 2.0 1.0 2.0	3.9 6.6 3.3 6.6	WE	0514 1117 1744	1.9 1.3 2.1	6.2 4.3 6.9
FR	0345 1052 1753 2315	2.2 0.8 2.0 1.4	7.2 2.6 6.6 4.6	SA	0311 1057 1841 2350	1.9 1.1 1.9 1.7	6.2 3.6 6.2 5.6	мо	0018 0549 1240 1926	1.3 2.1 0.9 2.0	4.3 6.9 3.0 6.6	TU	0016 0525 1155 1843	1.6 1.8 1.3 2.0	5.2 5.9 4.3 6.6	WE	0108 0657 1312 1928	1.2 1.9 1.2 2.0	3.9 6.2 3.9 6.6	тн	0036 0652 1218 1830	1.3 1.9 1.4 2.2	4.3 6.2 4.6 7.2
	0445 1156 1859	2.2 0.8 2.0	7.2 2.6 6.6		0359 1151 1925	1.9 1.2 1.9	6.2 3.9 6.2	TU	0132 0711 1352 2020	1.3 2.0 1.0 2.0	4.3 6.6 3.3 6.6	WE	0122 0715 1302 1922	1.5 1.9 1.4 2.1	4.9 6.2 4.6 6.9	TH	0216 0816 1416 2012	1.1 1.9 1.3 2.0	3.6 6.2 4.3 6.6	FR	0144 0819 1326 1920	1.1 1.9 1.5 2.2	3.6 6.2 4.9 7.2
SU	0025 0558 1310 2005	1.4 2.1 0.9 2.0	4.6 6.9 3.0 6.6	мо	0112 0548 1256 1957	1.7 1.8 1.3 1.9	5.6 5.9 4.3 6.2	WE	0243 0830 1459 2107	1.2 2.0 1.1 2.0	3.9 6.6 3.6 6.6	TH	0223 0838 1410 2006	1.3 2.0 1.4 2.2	4.3 6.6 4.6 7.2	FR	0316 0927 1514 2052	1.0 2.0 1.4 2.1	3.3 6.6 4.6 6.9	SA	0247 0932 1435 2011	1.0 2.0 1.5 2.3	3.3 6.6 4.9 7.5
				TU	0218 0740 1402 2027	1.6 1.9 1.3 2.0	5.2 6.2 4.3 6.6													SU	0343 1034 1541 2102	0.8 2.1 1.6 2.3	2.6 6.9 5.2 7.5

Copyright Canadian Hydrographic Service, Reproduction without permission prohibited

Copyright Service hydrographique du Canada, Toute reproduction non-autorisée est interdite

APPENDIX G

NBDELG Documentation

	al Study – General Requirements	Included in Report? ($$ = yes)	Page Number								
Site Description	Site Description	Yes	2								
	Wellfield Description	N/A									
	Description of Intended Water Use	Yes	1								
	Groundwater Withdrawal Details	Yes	1 & 3								
	Description of Existing and Previous Water Withdrawal Approvals	N/A									
Description of Hydrogeology	Regional and Local Geology	Yes	4								
	Regional and Local Hydrogeology	Yes	4								
	Surface Water Features	Yes	4								
Pumping Test Information	Pumping Test Description and Analysis	Yes	5 to 12								
	Water Quality Analysis	Yes	12 to 14								
Evaluation of Potential Impacts	Design Safe Yield	Yes	11 & 12								
	Well Interference Effects	Yes	15 & 16								
	Water Quality Effects	Yes	12 to 14								
	Groundwater Under Direct Influence (GUDI)	Yes	17 & 18								
	Salt Water Intrusion	Yes	16 & 17								
	Open Loop Earth Energy System Information	N/A									
Supporting Figures and Data	Site Location Map and Site Plan	Yes	Appendix A	A							
	Well Logs	Yes	Appendix (C							
	Pumping Test Data and Graphs	Yes	6 to 16, A	App. 1							
	Laboratory Reports	Yes	Appendix	E							
Notes on General Requirements:											
Water Supply Source Assessments and EIA Registrations are required for groundwater wells with a capacity for water withdrawals greater than 50,000 L/day (50 m ³ /day).											
	signed and professionally sealed by a qualified Eng nal Engineers and Geoscientists of New Brunswick.		ntist registered								
Reports and data must be submitted in hard copy and electronic copy.											
A constant rate pumping test and	analysis is required for each pumping well included	I in the EIA Regist	tration.								

Submission Checklist for the Hydrogeological Study

Production well(s) must be pump tested at a rate greater than or equal to the requested withdrawal rate.

Well interference effects should be evaluated for wells within a minimum radius of 500 m.

Salt water intrusion effects should be evaluated if the production well is within 500 m of a salt water body.

Potential for groundwater under the direct influence of surface water (GUDI) should be evaluated for each proposed production well.

Any work that is to be completed within 30 m of a watercourse or regulated wetland first requires a Watercourse and Wetland Alteration (WAWA) Permit.



NEW BRUNSWICK DEPARTMENT OF ENVIRONMENT AND LOCAL GOVERNMENT

Environmental Impact Assessment

WATER SUPPLY SOURCE ASSESSMENT GUIDELINES

Department of Environment and Local Government April 2017

Table of Contents

1.0 Introduction	3
1.1 Authority	3
1.2 Water Supply Source Assessment Process	4
2.0 WSSA Initial Application	4
2.1 Municipal Water Supplies	5
2.2 Subdivision Developments	
2.3 Open Loop Earth Energy Systems	5
3.1 Well Construction and Development	6
3.2 Step Testing	6
3.3 Constant Rate Pumping Test	7
3.3.1 Municipal, Industrial and Communal Wells	
3.3.2 Subdivision Developments	
3.4 Timing of Pumping Test(s)	8
3.5 Water Quality	
4.0 Reporting Requirements	9
4.1 Project Description	9
4.2 Existing Site Conditions1	0
4.2.1 Site Description1	0
4.2.2 Current Groundwater Use1	0
<i>4.2.3 Geology</i> 1	0
4.2.4 Hydrogeology1	0
4.3 Pumping Test(s)1	0
4.3.1 Description1	0
4.3.2 Data Presentation1	1
4.3.3 Data Analysis 1	1
4.4 Discussion1	2
4.4.1 Land Use1	
4.4.2 Groundwater Resource Evaluation1	
4.4.3 Well Interference1	2
4.4.4 Water Quality1	
4.4.5 Groundwater Under the Direct Influence of Surface Water (GUDI) 1	
4.4.6 Salt Water Intrusion and Relic Seawater1	
4.4.7 Open Loop Earth Energy System Information1	3
4.4.8 Final Well Design1	3
4.4.9 Well Head Protection Measures1	14
4.4.10 Monitoring and/or Contingency Plan1	4
4.4.11 Decommissioning Plans1	
Appendix A 1	6
Appendix B 1	8
Appendix C 2	20

1.0 Introduction

These guidelines have been developed to assist both the public and private sectors engaging in projects requiring a Water Supply Source Assessment (WSSA) through the Environmental Impact Assessment (EIA) process. Projects typically requiring a WSSA include the construction and/or modification of municipal, industrial or communal water supply sources, large scale subdivision developments in unincorporated areas, and open loop earth energy systems using more than 120 m³ of water/day.

WSSAs are conducted to evaluate the sustainability of the water supply, to assess the water quality, and to evaluate potential impacts to existing water users. These guidelines outline the WSSA process and provide information on the hydrogeological assessment and reporting that is required for various types of projects. These guidelines describe the minimum requirements, however, it is expected that the registered professional engineer or geoscientist responsible for conducting a WSSA will use their professional judgment to determine if any additional requirements are warranted.

1.1 Authority

The legislative authority for evaluating a potential water supply is found in the *Water Quality Regulation (82-126)* and the *Environmental Impact Assessment (EIA) Regulation (87-83)* of the <u>Clean Environment Act</u>.

The *Water Quality Regulation* states that all waterworks using greater than 50 cubic meters of water daily require a permit to operate, except in the case of a domestic well not connected to a distribution system. It also states in **3**(5): "No person shall, without an approval, which approval must include approval of the supply and quality of water, construct, modify or operate or permit the construction, modification or operation of any waterworks".

The *EIA Regulation* (Schedule A) indicates the specific undertakings that require a project to be registered under the *EIA Regulation* and a WSSA to be completed. These undertakings are:

- (1) The development of a waterworks with a capacity greater than 50 cubic meters of water daily (Schedule A, Section (s)). This could include, but is not limited to, water supply wells for municipalities or industries, as well as, communal wells for housing developments.
- (2) All major residential developments outside incorporated areas (Schedule A, Section (t)). A WSSA would be required in cases where the area is not serviced by a municipal water supply.

Prior to registering a project, it is advisable to discuss it with the Sustainable Development, Planning & Impact Evaluation Branch, Department of Environment and Local Government (see Appendix A for contact information) in order to: a) obtain advice and guidance on the registration submission and the review process, and b) obtain information with respect to the possible timing and duration of the review. **Note:** If at any time the proponent requires an additional water supply, a new EIA Registration and WSSA may be required. A WSSA may be required for certain projects, even if the water supply was not the specific EIA trigger.

1.2 Water Supply Source Assessment Process

The WSSA process begins with the submission of an EIA Registration document and a completed WSSA Initial Application (see Section 2.0) for a proposed project. These documents must be submitted to the Manager of the Environmental Assessment Section (see Appendix A for contact information) and an EIA Project Manager will be assigned to the file.

The Initial Application must be reviewed and approved by the Department of Environment and Local Government before commencement of any hydrogeological fieldwork (i.e. cutting access roads, drilling, pumping test). Following approval of the Initial Application, the proponent may proceed to the Hydrogeological Assessment (Section 3.0). The Hydrogeological Assessment includes field work, data analysis and reporting. Upon submission, the Hydrogeological Assessment will be reviewed by a Technical Review Committee (TRC), at which time additional information may be requested. The WSSA process is done concurrently with the EIA review process. Following the review process, an EIA Certificate of Determination will be issued which may contain conditions for the project (i.e. maximum pumping rate, monitoring).

WSSAs must be completed to the satisfaction of the Department of Environment and Local Government. Incomplete or inadequate submissions will be returned to the applicant for completion. The Hydrogeological Assessment and yield testing must be completed under the direct supervision of a qualified Professional Engineer or Geoscientist registered with the Association of Professional Engineers and Geoscientists of New Brunswick. All final work must be signed and professionally sealed.

2.0 WSSA Initial Application

The WSSA Initial Application form can be found in Appendix B. The purpose of the Initial Application is to allow the Department of Environment and Local Government to evaluate the proposed drilling target sites and hydrogeological testing, along with the environment surrounding the proposed water supply prior to the commencement of invasive field work (i.e. clearing, temporary road access, drilling, etc.).

The Initial Application must provide information on the proposed water supply, including the location of proposed drilling targets and the Parcel Identifier Number (PID) for the properties. The Application must discuss the intended use of the water supply, the quantity of water required, and any alternate water supplies that may be available. It must also discuss the hydrogeology of the area as it relates to the project and identify any existing pollution or contamination hazards within a minimum radius of 500 m from the proposed drill targets. Historical land uses (i.e. tannery, industrial, waste disposal, etc.) that might pose a risk of contamination should also be flagged. If groundwater use problems (quantity or quality) have occurred in the area, then these should be identified.

An appropriately scaled map (i.e. 1:10,000) clearly identifying all proposed drill target locations must be included and should also indicate the location of any significant hydrologic features in the area (i.e. watercourses, wetlands, surface water bodies) and existing wells and water users.

2.1 Municipal Water Supplies

It is necessary to consider the implications of the *Wellfield Protected Area Designation Order* - *Clean Water Act* at the earliest planning stages when locating a new municipal water supply well.

When dealing with the siting of municipal production wells, the proponent should examine and fully exhaust potential locations within the municipal boundaries prior to investigating outside the municipal limits. The Initial Application must provide details of land uses in the vicinity of the proposed production well and outline any land uses that may conflict with the *Wellfield Protected Area Designation Order*.

DELG policy requires that all municipalities formally request Wellfield Protection Designation by passing a Resolution of Council prior to bringing a new municipal well on-line. For more information on this policy and the Wellfield Protection Program, please contact the Drinking Water Source Protection Section of the DELG (see Appendix A for contact information).

2.2 Subdivision Developments

Many subdivision development projects are completed in phases and although an initial phase of the project may not appear to trigger an EIA Registration, the size of the entire potential development must be evaluated for water use. Where there is a reasonable expectation that future phases of the subdivision development project may be undertaken, the future phases must be included in the scope of the subdivision development project being reviewed.

The Initial Application must include a description of the proposed hydrogeological testing that will be undertaken for the initial subdivision development phase. Specific details related to hydraulic testing of potential future phases will be determined as each phase of the project is undertaken.

2.3 Open Loop Earth Energy Systems

Projects with open loop earth energy systems that require more than 120 m³ of water per day are required to register for an Environmental Impact Assessment and conduct a WSSA according to the Guidelines outlined in this document. A WSSA Initial Application must be submitted and approved before any invasive field work is conducted, including well drilling and aquifer testing.

As part of the WSSA Initial Application, a Contingency Plan must be submitted for review and approval. The Contingency Plan must address such issues as artesian flowing wells, insufficient return well capacity, potential reduced return well capacity due to biofouling, known poor water quality groundwater (e.g. saline groundwater), and leakage of the refrigerant. If there is the potential for saltwater to be encountered during drilling activities, the Contingency Plan must outline the mitigation measures that will be undertaken during well construction, aquifer testing and installation phases to ensure re-injection occurs in the same or similar quality aquifer and to minimize the risk of contaminating freshwater aquifers. The Contingency Plan must be prepared by a Canadian Geo-Exchange Coalition (CGC) certified industry professional in conjunction with either a New Brunswick licensed water well driller or a Professional Engineer and/or Geoscientist registered in New Brunswick.

Additional testing and reporting requirements for open loop earth energy systems are identified in Sections 3.0 and 4.0 of this document.

3.0 Hydrogeological Assessment

Following approval of the Initial Application by the EIA Project Manager, the Hydrogeological Assessment may commence, including field investigations and development of the water supply source. The primary objective of the hydrogeological assessment is to determine if the water supply source can provide adequate water quantity and acceptable water quality for the intended purpose over the short- and long-term. The investigation must collect sufficient site specific data to evaluate the water supply and any potential impacts to existing groundwater users in the area.

Specific requirements for the field component of the Hydrogeological Assessment are presented in this section, while the reporting requirements for the Hydrogeological Assessment are presented in Section 4.0.

3.1 Well Construction and Development

All wells (pumping, observation or test wells) must be identified and clearly labeled on a 1:10,000 scale map. A more detailed site map showing all wells must also be provided. The GPS coordinates of all new wells (pumping, observation and/or test wells) must be included, along with the Parcel Identifier Number (PID) for the property. All test wells should be numbered in a consistent and standard way with no two wells having the same number. The standard for this shall be the year drilled followed by the sequential number of the well drilled on this project. For example, the fifth well in a project occurring in 2011 would be 11-5. All test wells must be constructed by a Water Well Contractor/Driller licensed in the Province of New Brunswick as per the standards outlined in the *Water Well* and *Potable Water Regulations – Clean Water Act*. For a complete list of licensed well drillers contact the DELG Drinking Water Source Protection Section (Appendix A).

Well logs must include, but not be limited to, information on lithology and/or stratigraphy, depth and estimated yields of water-bearing fractures, static water level elevations, and well construction details. Well locations must be surveyed with elevations measured to ground surface and to the top of casing. Well depths should refer to the depth below top of casing (btoc).

Wells should be fully developed before yield tests are performed, with a minimum recommendation of two hours development. The improvement in the well development can be estimated by the change in specific capacity at a fixed pumping rate. These observations should be included with the raw data submitted to the DELG.

3.2 Step Testing

In order to determine the appropriate pumping rate for the constant rate pumping test, a step pumping test (step test) is recommended. This step test shall have a minimum of three steps with increasing pumping rates. Before proceeding to the constant rate test, the water level in the pumped well must be allowed to recover to a static level.

3.3 Constant Rate Pumping Test

The Hydrogeological Assessment must include a minimum of one constant rate pumping test. For all pumping tests the observation wells must be located within the same hydrogeological unit as the pumping well and within the drawdown cone. Constant rate pumping tests shall only be considered to be constant rate if the measured flows fall within \pm 5% of the average flow over the entire test.

3.3.1 Municipal, Industrial and Communal Wells

For municipal, industrial, and communal wells a constant rate pumping test with a minimum duration of 72 hours is usually required. In certain situations the length of the constant rate test may be altered with prior approval from the DELG.

For municipal water supplies, drawdown and recovery measurements must be taken in a minimum of two observation wells (exclusive from the production well) within the drawdown cone. For industrial and communal water supplies, a minimum of one observation well is required but more may be necessary depending on the situation. The recovery measurements must be continued until the original static water level is reached, or a period equal to one-half the length of the constant rate pumping test is completed (minimum 24 hours), whichever occurs first.

The DELG does not approve pumping rates for new wells that are higher than the pumping rate used during the constant rate pumping test.

3.3.2 Subdivision Developments

This section refers to subdivision developments where each lot will have an individual water supply well. For subdivision developments where a communal well(s) is proposed, refer to Section 3.3.1.

For subdivision developments with individual water supply wells, a single 72-hour constant rate pumping test may not be appropriate for assessing the suitability of the water supply source. The hydrogeological testing conducted for a proposed subdivision must evaluate if the local aquifer is capable of providing a water supply of sufficient quantity and suitable quality. In addition, the hydrogeological testing must assess the cumulative impacts of the entire subdivision development on the aquifer and neighboring water users. Along with pumping tests, groundwater modelling may be used in order to evaluate the water supply and potential impacts.

For the hydrogeological testing, a minimum of three test wells must be used, with at least one well located on the proposed site (unless otherwise approved by the Department of Environment and Local Government). The total number of wells required for hydrogeological testing is dependent on the hydrogeological conditions of the site and the size of the development. As a general rule, there should be one well for every 10 acres of development. The pumping well and observation wells must be appropriately located spatially to test the various hydrogeological conditions across the site and must also be appropriately grouped to obtain data during the pumping test.

A least one of the wells must be subjected to a constant rate pumping test for 24 hours. The total number of wells requiring a pumping test will depend on site conditions and the size of the development.

The water requirements for a subdivision lot with a single family home are based on a perperson water requirement of 450 L/day with a peak demand rate of 3.75 L/min/person. It is assumed that peak demand occurs for a period of 120 minutes each day. The number of people per household is calculated as the number of bedrooms in the house to be developed plus one. These values should be used when calculating the water requirements of the proposed development.

If groundwater heat pumps are intended to be used in the subdivision, then the water requirements of groundwater heat pumps must be evaluated as part of the hydrogeological study.

3.3.3 Open Loop Earth Energy Systems

For open loop earth energy systems, each water supply well must be subjected to a constant rate pumping test for a minimum of 24 hours. A minimum of one observation well is required but more may be necessary depending on the project. The recovery measurements must be continued until the original static water level is reached, or a period equal to one-half the length of the constant rate pumping test is completed (minimum 24 hours), whichever occurs first. Water from the pumping test must be properly discharged to the environment and not to any return well. If the water supply well is also going to be used as a potable water supply, then the testing needs to account for the water required to supply both the earth energy system and potable water needs.

If the location and construction of the observation well is appropriate, it may be used as a return well for the system.

The capacity of the return well(s) must also be evaluated and discussed in the WSSA report. The site professional should determine the appropriate method for evaluating the capacity of the return well(s) for the earth energy system. The return well(s) must also be constructed so that water is returned to an appropriate location within the aquifer, which is protective of any nearby drinking water wells.

3.4 Timing of Pumping Test(s)

Pumping tests should not be conducted during groundwater recharge seasons, which have historically occurred from October to December and mid-March to the end of May. Given changing climate conditions, these dates may fluctuate and are dependent on actual weather conditions. Pumping tests may be conducted during the dates listed above if it can be clearly documented that groundwater recharge has not begun.

In addition, pumping tests that have been carried out in an unconfined or partially confined aquifer within 10 days of 40 mm of rain or during a month of abnormally (>130 % normal) high rainfall may be considered unsuitable. It is the registered professional's responsibility to ensure that hydrogeological testing is carried out under suitable conditions and to evaluate issues such as spring freshet, snow melt, ground thaw and winter rain storms.

3.5 Water Quality

3.5.1 Municipal, industrial, communal and subdivision wells

As part of the WSSA process, the quality of the proposed water supply must be evaluated. A water sample must be collected from each pumping well at the beginning, middle and end of the pumping test (i.e. at 24, 48 and 72 hours for a 72 hour pumping test). Depending on the situation, water samples may also be required from observation or monitoring wells.

The water quality analysis must include, as a minimum, general chemistry, trace metals and microbiology (total coliforms and E.coli). Water samples must be analysed by an accredited laboratory. The supervising site professional should use their judgment in determining if additional water testing is required due to present or historical land use or contamination issues (i.e. hydrocarbon spill, pesticide application, past industrial use, etc.) or the end use of the water supply (i.e. drinking water, industry, aquaculture, etc.).

Copies of water quality laboratory reports must be included in the WSSA report.

3.5.2 Open Loop Earth Energy Systems

A water quality sample must collected from the water supply well and the return well(s) following completion of the wells. The water quality analysis must include, as a minimum, general chemistry and trace metals. Water samples must be analysed by an accredited laboratory. If the water supply well is also going to be used for potable water, a sample needs to be collected for microbiological analysis.

Copies of the laboratory reports must be included in the WSSA report.

4.0 Reporting Requirements

The Hydrogeological Assessment report should include the information described in this section and summarized in Table 1 (page 14). A submission checklist of the minimum general requirements to be included in the hydrogeological report can be found in Appendix C. The checklist must be completed and submitted with the hydrogeological report. The hydrogeological report must be submitted in both electronic format and hard copy to the Manager of the Environmental Assessment Section or the specific EIA Project Manager (Appendix A) for review. WSSAs must be completed to the satisfaction of the DELG. Incomplete or inadequate submissions will be returned to the applicant for completion.

4.1 Project Description

This section should include a description of the proposed project, intended water use and water requirements.

4.2 Existing Site Conditions

4.2.1 Site Description

A description of the site, including: site location, PID number, topography, drainage, and proximity to surface water bodies (watercourses, wetlands, etc). Also include information on the location of all neighbouring wells, the land use zoning and land use within a minimum radius of 500 m from the proposed project. This information should also be clearly identified on a 1:10 000 scale map.

4.2.2 Current Groundwater Use

The location and description of all existing wells on the property or in the wellfield, including: GPS coordinates of any wells (UTM coordinates - NAD83), well log details, wellhead completion, current water usage, pumping rate(s) and schedule(s), water levels, and history of any well interference or other concerns/complaints.

4.2.3 Geology

A detailed description of the local and regional bedrock and surficial geology, including, but not limited to: stratigraphy, depth of surficial deposits, formation thickness, composition, texture, known relevant weathering/alteration/structural features (i.e. joints, fractures, faults, or bedding planes), water-bearing potential and lateral continuity. Standard geological cross-sections should be included for the proposed site. Whenever possible, soils or geological information generated by the investigation should be described graphically.

4.2.4 Hydrogeology

A detailed description of the local hydrogeology, including, but not limited to: aquifer types, identification of hydrostratigraphic units and the hydraulic characteristics of each unit. The description of hydraulic characteristics must include a discussion of: hydraulic conductivity, porosity, effective porosity, transmissivity, storativity/specific storage, anisotropy, hydraulic head, seasonal fluctuations, vertical and horizontal hydraulic gradients, groundwater flow direction, boundary conditions, recharge, discharge and overall groundwater quality.

4.3 Pumping Test(s)

4.3.1 Description

The details of the pumping test must be outlined in the report and must include the following:

- Name of well driller and supervising site professional
- Construction details of any pumping and observation wells
- Pumping test set-up details (i.e. pump size, pump depth, flow control and water level measuring device, etc.)
- Type of test (step, constant rate, recovery)
- Information on other monitoring stations (i.e. stream station, tidal monitoring, etc.)
- Static water levels for the pumping well and observation wells

- Date and time when pumping started and ended
- Field observations and measurements (i.e. pH, conductivity, temperature)
- Weather observations during tests (i.e. precipitation, barometric pressure, etc.)
- Pumping flow rate ajustements

Logs should be presented in tabular and columnar format including any geophysical logs that may have been collected. Well construction details and information of hydrogeological interest should be combined in a similar way. The report should also indicate whether a well video was taken.

Variations from the approved plan submitted in the WSSA Initial Application should be identified, explained and justified.

4.3.2 Data Presentation

Copies of the original pumping test data sheets should be appended in the report. An electronic copy of the pumping test data should be submitted with the electronic report.

All pumping test data should be presented graphically (i.e. time-drawdown, recovery, and distance-drawdown) and the slope of the graph should be easily measurable in the trend-setting region. Any trend lines drawn for analysis should be clearly marked. All graphs should include test information (date, time, observation point, well identifier, and pumping rate if applicable) and should have clearly labeled axes.

4.3.3 Data Analysis

The step test and constant rate pumping test data should be analysed using standard, accepted data interpretation methods (i.e. Cooper-Jacob method, Theis method, etc.). Describe any assumptions made and deviations from standard methods.

Determine estimates of the following aquifer properties: transmissivity, hydraulic conductivity, storativity and specific yield. Evaluate if the pumping test data indicates any boundary conditions.

The following guidelines may be used to determine the total available drawdown in a well:

- depth to the first water-bearing fracture in bedrock
- bottom of confining layer in a confined aquifer
- sea level (in coastal settings)
- bottom of casing or top of the well screen in unconsolidated aquifers

Safe allowable drawdown is based on the total available drawdown plus an appropriate factor of safety. Use the above information, along with the safe available drawdown in the well, to determine the design safe yield of the pumping well or wells.

In areas that already have substantial water usage, groundwater modelling may be required to assess the safe yield, the potential for well interference and a water balance. Groundwater modelling may also be required for subdivisions in order to assess the potential effects of the entire development on the aquifer.

4.4 Discussion

The report must include discussion of the following items (as applicable): land use, groundwater resource evaluation, well interference, water quality, groundwater under the direct influence of surface water, salt water intrusion and relic sea water, open loop earth energy system information, final well and wellfield design, wellhead protection measures, monitoring and/or contingency plans, and decommissioning plans. These items are described in detail in the following sections.

4.4.1 Land Use

The report should identify any conflicting land uses in the area within a minimum distance of 500 m. Any potentially adverse impacts on the proposed water supply due to current or historical land uses must also be identified and discussed.

4.4.2 Groundwater Resource Evaluation

The report must include a detailed determination and discussion of the design safe yield of any proposed production well(s) as it relates to the geological and hydrogeological characteristics of the aquifer, including any boundary conditions indicated by the hydraulic testing.

The sustainability of the water supply aquifer must be evaluated using all available information (i.e. hydrogeology, available well logs, hydraulic properties of the aquifer, pumping test data, potential boundary conditions, climate variations, etc.). Evaluation of the cumulative effect of all water withdrawals on the aquifer and the potential for effects on surface waters must also be included.

4.4.3 Well Interference

Discuss the relationship between the proposed production well or wells and other water users in the area (i.e. private water wells, industry, commercial, etc.) and the potential for well interference effects.

4.4.4 Water Quality

The New Brunswick Drinking Water Quality Guidelines issued by the NB Department of Health are used as the standard for assessing drinking water quality. In the report, water quality results must be tabulated and compared to the appropriate Drinking Water Quality Guidelines. If there are exceedances of the Guidelines for health or aesthetic parameters then any potential treatment systems to render the water potable must be discussed along with the potential costs of water treatment.

For open loop earth energy systems, the water quality data must be evaluated for potential impacts to the function of the system and impacts to the groundwater quality from water being returned to the aquifer. If the water supply well is also going to be used as a potable water supply, the water quality (including microbiology) needs to be evaluated according to the guidelines listed in the above paragraph.

4.4.5 Groundwater Under the Direct Influence of Surface Water (GUDI)

The report must include an evaluation of the potential influence of surface water or shallow groundwater on the proposed groundwater source. This must include, as a minimum, an evaluation of the setting of the well and its sensitivity to surface water influence (i.e. spring, infiltration gallery, shallow screened well, horizontal collection well, wells in karst aquifers, wells in unconfined sand and gravel aquifers, fractured bedrock aquifers, floodplains or flood prone aquifers, etc.). The distance between the water supply and the nearest surface water body should be considered, along with the well construction in relation to the hydrogeology of the site and potential for surface water influence. For bedrock wells, the positioning of shallow water-bearing fractures should be evaluated in relation to the well construction and casing length. Finally, assess any initial water quality data from the well to see if there are any early indications of surface water influence.

Additional water quality monitoring and/or sampling parameters may be required where the potential for a direct connection between the surface or surface water and groundwater is possible or indicated.

The potential for flooding should be examined if it may be an issue given the location of the proposed water supply.

4.4.6 Salt Water Intrusion and Relic Seawater

An evaluation of the potential for salt water intrusion and reduction of freshwater head (i.e. Ghyben Herzberg relation) should be provided if the well is located within 500 m of a salt water source. Pumping wells located within 500 m of sea water should not lower the water level below sea level elevation, unless it can be demonstrated that a permanent hydraulic divide exists between the well and the sea water. Salt water sources may include, but are not limited to, the ocean, estuaries, tidal marshes and tidal influenced rivers.

Inland areas that may be affected by relic seawater should also be evaluated.

4.4.7 Open Loop Earth Energy System Information

The report must include information on the open loop earth energy system, such as the well drillers name, type of system, and type of refrigerant to be used.

The report must also include information on the capacity of any return well(s) for the system and discuss any potential for negative impacts to the aquifer or neighbouring water users from returned water.

4.4.8 Final Well Design

Provide final design drawings (including GPS coordinates) of the permanent well structure for municipal, industrial and communal wells. A map indicating the proposed locations of water supply piping may be required.

4.4.9 Well Head Protection Measures

Measures for water supply source protection should be discussed along with any unusual site conditions. It is recommended that a minimum land area of one acre be reserved for each production well and that the well be located toward the center of this land parcel. Well head protection measures could include measures such as locks, gates, well houses, limiting access, etc.

4.4.10 Monitoring and/or Contingency Plan

A water quantity and/or quality monitoring plan should be prepared identifying the type and frequency of parameters to be monitored (i.e. physical, chemical, microbiological, etc.). At a minimum, all water supply wells requiring an Approval to Operate will be required to maintain flow monitoring records. On-going monitoring data may need to be submitted to the DELG.

A contingency plan with specific strategies, actions or mitigation measures may be required to deal with any water supply issues such as malfunctions or service disruptions.

4.4.11 Decommissioning Plans

Wells drilled as part of the WSSA process (including observation and test wells) that will not be used for monitoring or any other reasonable purpose should be decommissioned according to the DELG *Guidelines for the Decommissioning (Abandonment) of Water Wells*.

For open loop earth energy systems, a decommissioning plan must be developed for the system that conforms to the DELG *Guidelines for the Decommissioning (Abandonment) of Water Wells*.

The Guideline may be obtained from the EA Section or found on-line at:

http://www2.gnb.ca/content/dam/gnb/Departments/env/pdf/Water-Eau/GuidelinesWaterWells.pdf

Study Information	Description		
1. Site Description	 Site Description Wellfield Description Intended Water Use Groundwater Withdrawal Details Existing and Previous Approvals 		
2. Description of Hydrogeology	 Local and Regional Geology Local and Regional Hydrogeology Local Surface Water Features 		
3. Pumping Test Information	Pumping Test AnalysisWater Quality Analysis		
4. Evaluation of Potential Impacts	 Design Safe Yield Well Interference Effects Groundwater Quality Effects Salt Water Intrusion Groundwater Under the Direct Influence of Surface Water (GUDI) 		
5. Monitoring and Contingency Plans	 Monitoring Plan (recommendations) Contingency Plan (recommendations) Decommissioning Plan 		
6. Supporting Figures and Data	 Site Location Map Site Plan and GPS Coordinates of Wells Aerial Photos Well Logs (test, pumping & return wells) Pumping Test Data and Graphs Laboratory Reports Groundwater Level Data Well Production Records 		

Table 1. Summary of Hydrogeological Assessment Information

Appendix A

Department of Environment and Local Government Select Contact Information For additional EIA information, please contact:

Department of Environment and Local Government Environmental Assessment Section, c/o Manager Tel: (506) 444-5382 Fax: (506) 453-2627

Physical Address: 20 McGloin Street, Marysville Place Fredericton, New Brunswick E3A 5T8

Mailing Address: P. O. Box 6000 Fredericton, New Brunswick E3B 5H1

For questions pertaining to:

EIA Regulations or Submissions	Environmental Assessment	(506) 444-5382
Hydraulic Testing (Pumping Tests)	Water and Wastewater Management	(506) 453-7945
Watercourse and Wetland Alteration Program	Surface Water Protection	(506) 457-4850
We ll fie l d Protection and Open Loop Earth Energy Systems	Drinking Water Source Protection	(506) 453 - 2171
Property Searches	Remediation and Materials Management	(506) 453-7945
Land Use Zoning & Subdivision Reviews	Provincial and Community Planning	(506) 453-2171

Appendix B

WSSA Initial Application Form

Water Supply Source Assessment Initial Application

Please provide the following information:

- 1) Name of proponent.
- 2) Location of drill targets (including property PID) and purpose of the proposed water supply.
- 3) Required water quantity (in m³/day) and/or required pumping rate.
- 4) List alternate water supply sources in area (including municipal systems).
- 5) Discuss area hydrogeology as it relates to the project requirements.
- 6) Outline the proposed hydrogeological testing and work schedule.
- 7) Identify any existing pollution or contamination hazards within a minimum radius of 500 m from the proposed drill targets. Historical land use that might pose a contamination hazard (i.e. tannery, industrial, waste disposal, etc.) should also be discussed.
- 8) Identify any groundwater use problems (quantity or quality) that have occurred in the area.
- 9) Identify any watercourse(s) (stream, brook, river, wetland, etc.) within 60 m of the proposed drill targets.
- **10)** Identify site supervisory personnel involved in the source development (municipal officials, consultants and drillers).
- **11)** Attach a 1:10000 map and/or recent air photo clearly identifying the following:
 - proposed location of drill targets and property PID
 - domestic or production wells within a 500 m radius from the drill target(s)
 - any potential hazards identified in question 7.
- 12) Attach a land use/ zoning map of the area (if any). Superimpose drill targets on this map.
- 13) Contingency plan for open loop earth energy systems (see Section 2.3).

Submit WSSA Initial Application: c/o Manager Department of Environment and Local Government Environmental Assessment Section Tel: (506) 444-5382 Fax: (506) 453-2627

Mailing Address: P.O. Box 6000 Fredericton, New Brunswick E3B 5H1

Physical Address: 20 McGloin Street, Marysville Place Fredericton, New Brunswick E3A 5T8

Appendix C

Submission Checklist

Hydrogeologica	al Study – General Requirements	Included in Report? (√ = yes)	Page Number
Site Description	Site Description		
	Wellfield Description		
	Description of Intended Water Use		
	Groundwater Withdrawal Details		
	Description of Existing and Previous Water Withdrawal Approvals		
Description of Hydrogeology	Regional and Local Geology		
	Regional and Local Hydrogeology		
	Surface Water Features		
Pumping Test Information	Pumping Test Description and Analysis		
	Water Quality Analysis		
Evaluation of Potential Impacts	Design Safe Yield		
	Well Interference Effects		
	Water Quality Effects		
	Groundwater Under Direct Influence (GUDI)		
	Salt Water Intrusion		
	Open Loop Earth Energy System Information		
Supporting Figures and Data	Site Location Map and Site Plan		
	Well Logs		
	Pumping Test Data and Graphs		
	Laboratory Reports		
Notes on General Requirements:			
withdrawals greater than 50,000			
	signed and professionally sealed by a qualified Eng nal Engineers and Geoscientists of New Brunswick.	ineer or Geoscien	tist registered
Reports and data must be submi	ted in hard copy and electronic copy.		
A constant rate pumping test and	analysis is required for each pumping well included	l in the EIA Regist	ration.
Production well(s) must be pump	tested at a rate greater than or equal to the request	ed withdrawal rate	э.
Well interference effects should b	e evaluated for wells within a minimum radius of 50	0 m.	
Salt water intrusion effects should	d be evaluated if the production well is within 500 m	of a salt water bo	dy.
Potential for groundwater under t production well.	he direct influence of surface water (GUDI) should b	e evaluated for ea	ach proposed
Any work that is to be completed Wetland Alteration (WAWA) Perr	within 30 m of a watercourse or regulated wetland f	irst requires a Wa	tercourse and

Submission Checklist for the Hydrogeological Study