

2012 - 02

## FIRE TECHNOTE

## NOTE TECHNIQUES DES INCENDIE

**From:** Technical Inspection Services  
**Date:** May 2012  
**Subject:** **Tamper Seals for Portable Fire Extinguishers**

Tamper seals required after applicable maintenance procedures are completed must display the year the maintenance procedures were completed. Refer to NFPA 10 7.3.2.2. Seals or Tamper Indicators.

**Origine :** Services d'inspection technique  
**Date :** Mai 2012  
**Objet :** **Sceaux de manipulation pour extincteurs d'incendie portatifs**

Les sceaux de manipulation requis à la suite des activités d'entretien applicables doivent préciser l'année où l'entretien a été effectué. Veuillez consulter l'article 7.3.2.2, Sceaux ou indicateurs de manipulation, de la norme 10 de la NFPA.